



# Resilience Optimization Proceeding



January 21-22, 2021

Optimization - Workshop #1



# Agenda – Day 1

- Introduction
- Presentation – Overview of Analytical Approach
- Discussion
- Presentation – Load Segmentation
- Discussion
- Break
- Presentation – MG Transmission Elements and DER Options / Solutions
- Discussion
- Wrap-up Day 1



# Agenda – Day 2

- Recap – Day 1
- Discussion – Observations Day 1
- Presentation – Guiding Principles for Optimization / Cost Effectiveness Metrics
- Discussion
- Break
- Presentation – DER Resiliency Placeholder Value
- Discussion
- Wrap-up Day 2 / Workshop #1



# Introduction



# Resiliency of PREPA's Grid

*The goal is for the electric power system to exhibit a degree of resilience such that for severe transmission system disruptions, likely coupled with extensive distribution system disruption, load service (especially for critical load at essential facilities, but also for other load) is minimally interrupted or not interrupted at all.*

- *“...this proceeding will be the forum to further explore the costs, benefits, and alternative configurations of combinations of wires (i.e., hardened T&D assets) and local distributed resources that best serve Puerto Ricans in safeguarding against the effects of short-term and extended electric system outages that can occur as a result of severe weather events.” [IRP Order ¶117]*



# Optimization Proceeding Objective


- Determine a reasonable, near-optimal mix of:
  - additional transmission investment for the PREPA identified MiniGrid regions; and
  - local distributed resource deployment.
- Determine the way resiliency investments would be made:
  - Direct customer installation
    - energy or energy/capacity resources behind the meter,
    - with or without PREPA tariff-based or procurement-based support;
  - PREPA resource procurement (direct RFPs/PPOA, DR tariffs, other forms of feed-in tariffs);
  - PREPA installation of transmission or distribution equipment (traditional); or,
  - A combination of these mechanisms.



# Two Types of Resiliency Solutions

## Not Mutually Exclusive

### T&D System Hardening Approach




### MiniGrid Approach

- Undergrounding of existing/new transmission infrastructure
- Selective substation hardening
- \$5.9B in MG Tx expenditures, + additional distribution \$
- Ensure sufficient capacity to meet critical/other load

Optimization - Workshop #1

### VS. Distributed Resource Approach



### DER Deployment

- Site-specific DG or microgrids serving critical (& other?) load during grid outage
- Distributed resiliency
- Avoids some level of T&D expenditure



# Workshop Objectives

## Workshop 1

- **Engagement and discussion** – stakeholders/PREPA – **informal**
- Define resiliency or need
  - Electrical service to critical / essential facilities, and other load (to what extent?)
  - MW, MWh? Load Factor (how much is critical)? Time horizons (duration)?
- Specify forms of resiliency solutions and how they overlap with “blue sky” needs
  - Distributed resources at load (capacity, energy) - including microgrids, and single site DER
  - Transmission & distribution upgrades delivering capacity, energy – blue sky & storms
- How will resiliency solutions be procured and paid for, and how does that affect optimization?
  - Practicalities: time horizons? who pays/what services? costs allocated? what’s fair?
  - Methods to rapidly deploy DER as resiliency solution
  - Funding sources – any impact?
- Define/discuss/refine analytical approach
  - Load segmentation to determine need – at what granularity? Why?
  - Determine/estimate costs of alternatives – in aggregate - T, D, GIS, microgrids, stand-alone DER
  - Means to determine which resiliency solution will be used for which loads, and where
- End result: Guiding principles for optimization – practicality, not perfection
  - determine which transmission to proceed with
  - determine DER deployments

## Issues Summary and Remaining Workshops

- Next slide



# Issues and Remaining Workshops

- Issues – How does optimization address:
  - “Blue sky” and resiliency needs – all DER resources service both normal and weather event circumstances
  - Consideration of the avoided costs of T, D for DER solutions
  - Uncertainty of costs for both forms of solutions
  - Transmission grid is integrated – MiniGrid and “Non-MiniGrid” infrastructure
    - How does optimization address “other” transmission?
- Remaining Workshops
  - Review transmission projects/categories; determine which are reasonable to proceed
  - San Juan / Bayamon projects first
  - Distributed resources for balance of resiliency need



# Workshop Day 1 Topics

- Analytical Approach
- Load Segmentation
- MiniGrid (MG) Transmission Elements
- Distributed Resource Options



# Questions & Discussion

- Objectives
- Agenda Items
- Process



# Overview of Analytical Approach



# Analytical Objective

- Determine reasonably lowest cost mix of MiniGrid transmission assets and DERs to enhance grid resiliency
- Identify “no regrets” solutions for:
  - Transmission infrastructure hardening
  - Microgrid or stand-alone distributed generation
- Refine analysis for more difficult transmission vs DG cases
  
- Recognize that DER resources for grid resiliency are also available for “blue sky” days; conversely, DERs that support capacity and energy needs can be doubly-purposed to also provide resiliency.
- Transmission reinforcement needed for “blue sky” operation in addition to serving as “MiniGrid” resource in severe weather/islanded mode.



# Analytical Framework for Resilient Grid

1. Identify and define classes of customers regarding the criticality of electricity service and associated expected levels of resiliency.
2. Identify and describe the customers' roles in providing capacity and energy supply for resiliency.
3. Provide microgrid and related single-site (individually, or in the aggregate as VPPs) local capacity and energy solutions for both resiliency and normal energy/capacity needs.
4. Determine transmission costs, avoided transmission costs.
5. Optimize transmission and distribution (T&D) system expenditures for resiliency, including aspects of PREPA's MiniGrid concept.



# Detailed Analytical Approach

- Segment the load
- Determine the resiliency need by segment
  - Define what is critical – type of load (e.g., essential facilities) – and the importance of “other” load (e.g., refrigeration and water pumps)
  - Quantitative metrics to define capacity/energy need (e.g., MW, MWh, load coverage to provide resiliency)
- Assess cost of DER solutions
- Assess cost of transmission system to serve dense critical load clusters, other?
- Split resiliency approach into two groups:
  - MiniGrid approach (T&D system hardening)
  - DER approach (microgrid and stand-alone, single site DER)
- What works quickly? What’s best for long-term?
- Test cost-effectiveness
- Determine transmission builds
- Determine DER builds



# Data Inputs to Analytical Approach

- Load inputs – for segmentation – capacity, energy, by segment
- Requirements – resiliency need for essential facilities, other load (% ?)
- Cost, and coverage (kW, kWh), for DER solutions (data source: Sandia? NREL? Actual installations?)
  - PV/BESS standalone / Other generation?
  - Microgrid
- Cost, and coverage for transmission & distribution solutions under MiniGrid approach, from IRP Order, Appendix 1
  - Tx costs by component and type (minigrid vs non-minigrid)
  - Tx costs by technical justification
  - Distribution
  - Address what data is confidential; what is needed for optimization
- Estimate of avoided transmission, distribution costs with DER approaches for resiliency



# Resiliency Approach Matrix

## Illustrative

San Juan / Bayamon								Comparison Metrics and Outcomes – MiniGrid (MG) and microgrid/DER Solutions		
Essential Facility Category	Customer Type	Example: Peak Load of Essential Facility Category	Example: Energy % of normal for resiliency	Comment	Default form of service for resiliency	Total load served by solution	Cost – MiniGrid	Cost – Microgrid/DER	Cost of Resiliency (\$/MWh) MiniGrid	Cost of Resiliency (\$/MWh) DER
1 – Very Large/ Critical Loads	Airports, Large Hospitals, Major PRASA (water/sewer)	5-10 MW	Actual load factor (100% of all load)	Site specific, customized solution, highly critical infrastructure	MiniGrid connected					
2 – Large	Hospitals, nursing homes, large pumping stations, arenas, military installations, government buildings serving essential services	1-5 MW	50-100%	Site specific, customized solution, highly critical infrastructure but not optimally located for MiniGrid	Minigrid connected or Microgrid					
3 –Medium/ Large	Fire, police, water/sewer pumping, large town centers	250-1000 kW	50-100%	Opportunistic connection to Minigrid if <1 mile away	Microgrid or stand-alone					
4 – Medium/ Small	Small town centers/dense residential areas	50-250 kW	25-50%	Opportunistic connection to Minigrid/microgrid if < ½ mile away	Stand-alone					
5 – Small	Grocery store/gas stations	5-50 kW	25-50%	PV/BESS/IC units	Stand-alone PPOA/FIT/DR					
6 – Very Small	Telecommunications towers	<5 kW	100%	PV/BESS/Integrated Circuit (IC) units	Stand-alone PPOA/FIT/DR					
7 - Other	Residences, other single sites	<10 kW	25-50%	PV/BESS	NEM/DR					



# Questions & Discussion

- Resiliency Approach Matrix?
- How quickly can specific, “least regrets” transmission projects be identified to allow “fast track” for construction? [E.g., which San Juan projects?]
- How can we discern “least regrets” transmission from more marginal projects?
- How do we determine the value of avoided transmission costs?
  - Simple \$/kW? Which \$? Which kW?
- Distribution hardening is key to allow critical load service for any project associated with transmission.
  - How to align D with T projects? Wasted T if D not addressed?
- How does DER payment / control / accounting work for blue sky vs. resiliency needs?
- Who pays for battery capacity (customer or PREPA) – how much, through what mechanism? How to measure quantity? Does PREPA control via VPP/DR aggregator? How is control instituted?
- Who pays for solar PV panels – how much and through what mechanism?
- Who pays for transmission / distribution? Spread across all load? Does all load benefit?



# Load Segmentation



## Purpose of Load Segmentation

- ...”primary purpose of a determination on load segmentation approaches at the very outset of the proceeding is to appropriately define baseline criteria for which load constitutes truly “critical” or “priority” load for purpose of examining the cost-effectiveness of alternative resiliency solutions.”

Optimization Proceeding Order, page 8



# Objective of Load Segmentation

- To optimize expenditures between wires and DERs, must first identify and define the “critical” or other load service across customer classes with respect to both the size and location of that load.
- Capacity and energy needs are required, in part to test ability of PV alone to meet needs for DER solutions for some load segments.
  - Some critical service needs come with a high load factor requirement (with respect to normal peak), and energy need may drive the requirements more than peak load.
  - Other critical service needs may be minimal with respect to normal peak (e.g., household needs).
- After identifying the loads, the costs of potential solutions will be determined, as applicable.



# Approach to Load Segmentation

- Customer segmentation:
  - By essential facility classification or customer class (see Resiliency Matrix)
  - By time – Energy and peak demands by day, day-type (weekend vs. weekday), season
  - By size (kW or MW peak demand, and kWh consumption patterns)
  - By type of load (resiliency need): e.g., PREPA defines need as critical, priority, and balance
    - But other definitions considered for purpose of optimization (e.g., portion of “balance” load that is critical; and portion of “critical” load that is not critical).
  - By location – Minigrig region, substation, feeder, transmission line, other?
- Presumption of headroom on feeders for “resiliency” load needs, though “blue sky” needs may be more restrictive
  - Eventually: incorporate hosting capacity analysis results to identify “headroom” on feeders for maximizing integration of distributed generation



# Resiliency Approach Matrix

## Illustrative

San Juan / Bayamon								Comparison Metrics and Outcomes – MiniGrid (MG) and microgrid/DER Solutions			
Essential Facility Category	Customer Type	Example: Peak Load of Essential Facility Category	Example: Energy % of normal for resiliency	Comment	Default form of service for resiliency	Total load served by solution	Cost – MiniGrid	Cost – Microgrid/DER	Cost of Resiliency (\$/MWh) MiniGrid	Cost of Resiliency (\$/MWh) DER	
1 – Very Large/ Critical Loads	Airports, Large Hospitals, Major PRASA (water/sewer)	5-10 MW	Actual load factor (100% of all load)	Site specific, customized solution, highly critical infrastructure	MiniGrid connected						
2 – Large	Hospitals, nursing homes, large pumping stations, arenas, military installations, government buildings serving essential services	1-5 MW	50-100%	Site specific, customized solution, highly critical infrastructure but not optimally located for MiniGrid	Minigrid connected or Microgrid						
3 –Medium/ Large	Fire, police, water/sewer pumping, large town centers	250-1000 kW	50-100%	Opportunistic connection to Minigrid if <1 mile away	Microgrid or stand-alone						
4 – Medium/ Small	Small town centers/dense residential areas	50-250 kW	25-50%	Opportunistic connection to Minigrid/microgrid if < ½ mile away	Stand-alone						
5 – Small	Grocery store/gas stations	5-50 kW	25-50%	PV/BESS/IC units	Stand-alone PPOA/FIT/DR						
6 – Very Small	Telecommunications towers	<5 kW	100%	PV/BESS/Integrated Circuit (IC) units	Stand-alone PPOA/FIT/DR						
7 - Other	Residences, other single sites	<10 kW	25-50%	PV/BESS	NEM/DR						



## Load segmentation granularity - IRP

- Is this sufficient granularity for DER considerations? [No?]

**Exhibit 2-2: 2019 Deemed Critical/Priority/Balance Load\***

2019 Critical/Priority/Balance Night Peak Load , MW							
MiniGrid	Total Load	Critical	Priority	Balance	% Critical	% Priority	% Balance
Arecibo	234.2	117.2	60.6	56.4	50%	26%	24%
Caguas	306.7	128.2	74.4	104.1	42%	24%	34%
Carolina	310.8	132.9	33.7	144.2	43%	11%	46%
Cayey	101.1	59.7	29.9	11.5	59%	30%	11%
Mayaguez North	163.5	85.1	7.5	70.9	52%	5%	43%
Mayaguez South	161.7	110.4	9.7	41.6	68%	6%	26%
Ponce	332.3	144.2	79.2	108.9	43%	24%	33%
San Juan	1050.7	399.0	185.0	466.7	38%	18%	44%
<b>Total</b>	<b>2660.9</b>	<b>1176.7</b>	<b>480.0</b>	<b>1004.2</b>	<b>44%</b>	<b>18%</b>	<b>38%</b>

Reference: IRP\_19\_Substation\_LoadProcessing\_Final.xlsx



# Critical / Priority / Balance Load

- What is the amount of critical load requiring resiliency solution?
  - PREPA IRP: *Critical load represents the peak consumption of the total load connected to feeders that serve any critical customer*
  - PREPA noted that up to 1,177 MW of critical load could exist.
  - *Is this the right # for DER optimization that targets individual facilities, and not entire feeders? **No.***
  
- How does this impact the optimization?
  - Need to consider actual critical and other customer load served under each of the respective solutions.



# Open Discussion / Questions

- Feedback on load segmentation approach
- What load is critical?
- What are best sources for load data – PREPA only?
- How to fill in Matrix
- Is data on the loads of critical customers readily available?
- Other considerations?



# Break



# MiniGrid Transmission Elements




## Bureau Order – MiniGrid/DER Approach

- The Bureau intends at each workshop to start with an identification of the most critical, and reasonably obvious, transmission grid needs for infrastructure upgrades, dependent in significant part on identification of the location and size of the most critical larger loads, their proximity to the transmission system, and the relative density of all such critical loads in proximity to the transmission system in each region (i.e., a “top down” approach to identifying transmission resiliency solutions).
- Simultaneously, each workshop will identify those locations where a DER approach to providing resiliency is likely more reasonable than a transmission investment, by examining, for example, smaller size critical loads in lightly loaded areas furthest from the transmission grid or critical loads regardless of size or geographical location, but electrically distant from a transmission connection point (i.e., a “bottom up” approach to identifying DER resiliency solutions).



# PREPA Transmission System

Exhibit 2-7: PREPA Transmission System Map with Proposed 115 kV Investments



Source: IRP Appendix 1, Redacted Exhibit



## Transmission MiniGrid Elements

- “MiniGrid” elements are a proposed subset of infrastructure –hardened, new & existing – intended to promote resilient system operation.
- MiniGrid infrastructure includes transmission, substation, and distribution system elements.
  - PREPA MiniGrid approach included thermal and BESS capacity within regions.
  - Hardened system allows critical load service to be retained in event of severe disruption.
- IRP
  - Bureau approved \$2 billion for essentially “other” non-MiniGrid transmission
  - Remaining proposed \$5.8 billion is for review in this proceeding.
- Optimization proceeding review:
  - Focuses on determining which wires components of MG approach are optimal to provide resiliency, and where DER is a better alternative.
- Next slides: summary of MiniGrid costs and type of infrastructure



# 115 kV MiniGrid Elements

**Exhibit 2-85: 115 kV MiniGrid Transmission Investment by Project Type, \$ million**

Project Type	Arecibo	Bayamón	Caguas	Carolina	Isla	Mayaguez	Ponce	San Juan	Total
Line Hardening/Reconstruction	9.3	41.5	82.1	63.0	86.9	102.5	54.5	39.1	478.9
New Transmission Line	0.0	0.0	2.2	0.0	0.0	0.0	0.0	0.0	2.2
New Underground Construction	80.8	57.7	145.2	181.6	0.0	0.0	0.0	120.1	585.4
Switchyard Hardening/Reconstruction	205.2	208.4	251.8	181.7	0.0	208.7	364.9	320.9	1741.6
<b>Grand Total</b>	<b>295.3</b>	<b>307.5</b>	<b>481.2</b>	<b>426.3</b>	<b>86.9</b>	<b>311.2</b>	<b>419.5</b>	<b>480.1</b>	<b>2808.1</b>

**Exhibit 2-87: 115 kV MiniGrid Transmission Investment by Technical Justification, \$ million**

Technical Justification	Arecibo	Bayamón	Caguas	Carolina	Isla	Mayaguez	Ponce	San Juan	Total
Interconnection of Minigrids	0.0	0.0	17.2	0.0	56.4	0.0	0.0	0.0	73.6
Minigrid Backbone Extensions to Create High Reliability/Resiliency Zones	0.0	0.0	0.0	0.0	0.0	0.0	0.0	70.4	70.4
Minigrid Main Backbone	271.4	254.8	372.0	294.7	30.5	215.4	306.5	322.1	2067.2
Interconnection of Critical Loads	0.0	36.0	0.0	52.0	0.0	0.0	67.7	0.0	155.6
Existing Infrastructure Hardening for Reliability	0.0	4.5	65.0	58.8	0.0	66.2	0.0	50.2	244.6
Aging Infrastructure Replacement	23.9	12.3	27.1	20.9	0.0	29.7	45.3	37.4	196.6
<b>Grand Total</b>	<b>295.3</b>	<b>307.5</b>	<b>481.2</b>	<b>426.3</b>	<b>86.9</b>	<b>311.2</b>	<b>419.5</b>	<b>480.1</b>	<b>2808.1</b>

Reference: MiniGrids CapEx Summary\_wPriority\_Final.xlsx



## 38 kV MiniGrid Elements

**Exhibit 2-89: 38 kV MiniGrid Transmission Investment by Project Type, \$ million**

Project Type	Arecibo	Bayamón	Caguas	Carolina	Isla	Mayaguez	Ponce	San Juan	Total
Line Hardening/Reconstruction	57.0	13.6	188.5	46.0	17.2	203.7	2.4	108.7	637.2
New Transmission Line	0.0	0.0	23.2	0.0	0.0	25.5	0.0	0.0	48.7
New Underground Construction	64.4	121.9	153.2	115.3	0.0	215.1	412.8	145.4	1228.1
Switchyard Hardening/Reconstruction	131.3	84.7	147.8	57.0	0.0	158.2	358.2	169.8	1107.1
New Substation/Switchyard	0.0	0.0	13.6	12.2	0.0	0.0	0.0	0.0	25.8
<b>Grand Total</b>	<b>252.7</b>	<b>220.2</b>	<b>526.5</b>	<b>230.5</b>	<b>17.2</b>	<b>602.6</b>	<b>773.4</b>	<b>423.8</b>	<b>3046.9</b>

Reference: MiniGrids CapEx Summary\_wPriority\_Final.xlsx

**Exhibit 2-91: 38 kV MiniGrid Transmission Investment by Technical Justification, \$ million**

Technical Justification	Arecibo	Bayamón	Caguas	Carolina	Isla	Mayaguez	Ponce	San Juan	Total
Existing Infrastructure Hardening for Reliability	0.0	0.0	154.7	41.5	0.0	198.0	0.0	0.0	394.2
Interconnection of Critical Loads	240.5	209.3	298.7	159.4	10.4	390.9	759.8	343.8	2412.9
Interconnection of Minigrids	0.0	0.0	55.3	0.0	0.0	0.0	13.6	0.0	69.0
Minigrid Backbone Extensions to Create High Reliability/Resiliency Zones	5.3	10.9	2.6	29.6	6.8	0.0	0.0	80.0	135.2
Minigrid Main Backbone	6.9	0.0	15.1	0.0	0.0	13.6	0.0	0.0	35.6
<b>Grand Total</b>	<b>252.7</b>	<b>220.2</b>	<b>526.5</b>	<b>230.5</b>	<b>17.2</b>	<b>602.6</b>	<b>773.4</b>	<b>423.8</b>	<b>3046.9</b>

Reference: MiniGrids CapEx Summary\_wPriority\_Final.xlsx



# MiniGrid Elements Cost By Project/Infrastructure Type

<u>\$ Millions</u>	Arecibo	Bayamón	Caguas	Carolina	Isla	Mayaguez	Ponce	San Juan	Grand Total
115 kV Switchyard		17	7						24
115 kV Transmission Line	9	42	84	63	87	102	55	49	491
115 kV Underground Line	81	58	145	182				120	585
115/38 kV Transmission Center	24	8	36	36		28	44	37	213
230/115 kV Transmission Center		9	26			21	23		78
38 kV Switchyard		9		10		13	14	58	104
38 kV Transmission Line	57	11	212	46	17	229	2	44	618
38 kV Underground Line	64	125	153	115	-	215	413	212	1,297
Gas Insulated Substation	313	250	350	205		305	643	393	2,459
<b>Grand Total</b>	<b>548</b>	<b>528</b>	<b>1,013</b>	<b>657</b>	<b>104</b>	<b>914</b>	<b>1,193</b>	<b>913</b>	<b>5,870</b>

Source: IRP (Redacted Transmission Appendix)



# MiniGrid and Non-MiniGrid Cost Components by Technical Justification

<u>\$ Millions</u>	Arecibo	Bayamón	Caguas	Carolina	Isla	Mayaguez	Ponce	San Juan	Grand Total
<b>Existing Transmission / Non-MiniGrid</b>									
Aging Infrastructure Replacement								29	29
Existing Infrastructure Hardening for Reliability	327	197	83	-	701	71	276	209	1,864
Existing Infrastructure Hardening for Reliability					38				38
SubTotal Non-MiniGrid	327	197	83	-	738	71	276	238	1,930
<b>MiniGrid Transmission</b>									
Interconnection of Critical Loads	240	245	299	211	10	391	827	344	2,569
Interconnection of Minigrids			72		56		14		143
Minigrid Backbone Extensions to Create High Reliability/Resiliency Zones	5	11	3	30	7			150	206
Minigrid Main Backbone	278	255	387	295	30	229	306	322	2,103
Existing Infrastructure Hardening for Reliability - MG		5	220	100		264		60	648
Aging Infrastructure Replacement-MG	24	12	33	21		30	45	37	202
Subtotal MinGrid	548	528	1,013	657	104	914	1,193	913	5,870
<b>Grand Total</b>	<b>875</b>	<b>724</b>	<b>1,097</b>	<b>657</b>	<b>842</b>	<b>985</b>	<b>1,469</b>	<b>1,151</b>	<b>7,800</b>



## Other Transmission Costs

**Exhibit 2-97: Other Transmission Investment by Project Type, in \$ million**

Technical Justification	Arecibo	Bayamón	Caguas	Isla	Mayaguez	Ponce	San Juan	Total
Aging Infrastructure Replacement	0.0	0.0	0.0	0.0	0.0	0.0	28.8	28.8
Existing Infrastructure Hardening for Reliability	327.3	196.8	83.2	777.1	70.8	303.5	209.2	1967.8

Reference: MiniGrids CapEx Summary\_wPriority\_Final.xlsx

**Exhibit 2-98: Other Transmission Investment by Voltage, \$ million**

Voltage	Arecibo	Bayamón	Caguas	Isla	Mayaguez	Ponce	San Juan	Total
115 kV	178.8	71.8	0.0	211.3	0.0	50.7	70.5	583.2
115/38 kV	0.0	0.0	0.0	0.0	0.0	0.0	28.8	28.8
230 kV	28.1	0.0	0.0	543.7	0.0	0.0	0.0	571.8
230/115 kV	3.5	14.4	0.0	0.0	0.0	0.0	0.0	17.9
38 kV	116.9	110.6	83.2	22.1	70.8	252.8	138.6	795.0
<b>Grand Total</b>	<b>327.3</b>	<b>196.8</b>	<b>83.2</b>	<b>777.1</b>	<b>70.8</b>	<b>303.5</b>	<b>238.0</b>	<b>1996.6</b>

Reference: MiniGrids CapEx Summary\_wPriority\_Final.xlsx



# 10-Year Plan “Near Term” transmission and distribution

- 115kV / 230kV transmission Lines
  - “near-term objective is to provide hardening/resiliency and/or rebuild 12 transmission lines (237 circuit miles).” P34, 10-year plan
- Distribution
  - “...95 feeders were identified as critical with an immediate need to repair. These feeders have been included in the near-term and classified in the first tier of projects to be completed.”
- How do these proposed infrastructure projects align with MiniGrid, or non-MiniGrid, transmission?



## Questions and Discussion

- What are the categories of transmission, or specific projects, that are readily seen as reasonable for installation? Any?
- Can this be easily discerned?
- Where are the most dense urban clusters in the San Juan region? Other regions?
- Should MiniGrid hardening needs be separate from other transmission / distribution hardening needs?



# **DER Options and Distributed Resiliency Approach**



# DER Resiliency Solution Options and Approach - General

- Options: Provide capacity and energy at specific facility locations, to serve critical – and other? - load
  - Microgrids
  - Standalone DER
  - Virtual Power Plants (VPP) – aggregate of standalone DER, possibly microgrid resource
  - Demand Response – battery offerings through DR regulation
- Approach: Determine locations across Puerto Rico best suited to DER (distant from hardened grid; less densely loaded areas)
  - Identify microgrid options
  - Identify stand-alone options
  - Determine deployment methods



# DER Options and Approach - Specific

- Hi Level Costs, Attributes of DERs
  - Capacity
  - Energy
  - Ancillary Services (AS)
  - Controllability
- Considerations: Who pays? How? Capacity and energy? AS?
- Determine/estimate which loads best served by DER approach
  - How to address small-scale, kW size needs – residential, small commercial – mass market.
- Determine/estimate which load best served by MiniGrid approach
- Parameters to roughly bound solution sets:
  - Broadly: rural vs. urban / dense vs. less dense load
  - Distance from potential MiniGrid / distance from existing transmission
  - Feeder load locational analysis
  - Transmission/sub-transmission system connected load
  - Existing data from PREPA – critical load levels by feeder, other?



# PREPA Distributed Resiliency Approach

- DER approach minimal, limited to microgrids; 50 zones identified
- Identified critical, balance and balance load within each optional microgrid. No detailed analysis, cost, or deployment options assessed.
- Portion of Exhibit 2.4 (Appendix 1, IRP):

MiniGrid	Microgrid Name	Critical	Priority	Balance
	VILLALBA (Toro Negro)	7.4	1.9	1.9
	PORTUGUES	0.4	0.0	0.3
San Juan	CARRAIZO	1.8	0.0	10.7
	NARANJITO	6.6	0.2	6.1
	PINAS	4.4	0.0	11.6
	UNIBON	0.0	3.2	5.3
	VILLA BETINA	3.9	7.0	15.2
	QUEBRADA NEGRITO	0.0	0.0	4.5
	COROZAL	6.0	2.7	0.0

Reference: IRP\_19\_Substation\_LoadProcessing\_Final.xlsx



# Sandia Distributed Resiliency Approach

- Sandia identified 159 candidate microgrids, supplemented with backup generation to critical assets in locations that may not warrant a microgrid.
- System costs \$1.2B if only critical loads served by microgrids and \$2B to serve both critical and non-critical load.
- A large cluster of portfolios achieves performance benefits close to the do-everything scenario at cost on the order of \$300-\$400M.
  - Estimate total microgrid cost on the order of \$1.3-\$2M per MW of peak load required for the microgrid
  - Appendix A: Microgrid Cost Methodology pgs. 55-60
  - Latitudes and longitudes of buildings suggested under each of the 159 candidate microgrids



# Snapshot from Sandia Report

**Table 7. Microgrid Cost Estimates for each Microgrid Area**

Microgrid #	Microgrid Name	Critical Demand (kW)	Non-Critical Demand (kW)	Option A1 (\$M)	Option A2 (\$M)	Option B1 (\$M)	Option B2 (\$M)
1	San Juan City Hall	1079	4630	15.42	20.90	4.56	5.60
2	Hospital Complex	70049	9323	203.99	280.19	181.13	248.37
3	International Airport	122315	12805	346.71	476.42	314.93	432.35
4	Muelle De Viejo Ferry and Cruise Terminals	4202	4069	21.97	29.91	12.56	16.59
5	Calle Cuervillas	1201	4250	14.75	19.99	4.87	6.03
6	Doctors Hospital Center	2164	2097	11.71	15.80	7.34	9.42
7	Centro Comunal El Gandel	456	1100	4.78	6.28	2.97	3.41
8	Conservatoria de Musica de Puerto Rico	2655	886	9.86	13.26	8.60	11.15
9	Pavia Hospital Complex	2032	14882	44.10	60.34	7.00	8.95
10	Avenida Wilson	1579	10464	31.63	43.19	5.84	7.36
11	Avenida Doctor Ashford	2902	14966	46.54	63.70	9.23	12.02
12	University Sacred Heart	1332	3019	11.94	16.12	5.21	6.49
13	FRD Airport and Convention Center	7774	21268	75.15	103.03	21.70	29.16
14	Sagrado Corazon	1377	3848	14.18	19.19	5.33	6.65

Source: Sandia report, page 56.

- “There is a great range in size with the microgrids, so the costs for given microgrids vary widely. It may be possible to further reduce the size of larger microgrids like microgrid 2, the Hospital Complex, or microgrid 3, the International Airport, by splitting them into smaller microgrids or serve a smaller subset of critical loads. In any case the results presented show load and cost comparative information which can be further analyzed to determine which ones are the most important and critical for service to Puerto Rico during major events.” (Sandia report, page 55)



# RMI Distributed Resiliency Approach

- RMI urged a DER-focused solution
  - Not a detailed, comprehensive presentation of DER solution
- 20,000 critical facilities
- Solar PV and storage
- 650-700 MW PV capacity
- 900-1,000 MWH battery storage



# Microgrid Boundary Delineation

- Determine boundaries for the potential distributed microgrid solutions
  - Note: Identify independent microgrids (e.g. some resilience nodes may overlap)
    - Can eventually look at a networked microgrid approach, where practical

## Data Inputs:

- Sandia 2018 Microgrid Locations Report (159 microgrid locations)
- Electrical distribution system layout (e.g. critical loads, feeders, switches, physical equipment, etc.)
- Assess data on relative reliability and resiliency of individual feeders
- Identify existing grid resiliency solutions (e.g. batteries, generators, etc.)



# Microgrid Design Considerations

- **Responsibility**      ➤ What is PREPA's role? Customer role? Third-party role?
- **Backup Duration**      ➤ Duration of time microgrid required to be functional
  - *Minimal time needed for microgrid operation*
- **Size**      ➤ Size each microgrid system based on critical load demands
- **Generation Resources**      ➤ Types and composition of distributed generation considered
  - *Maximum allowable renewable resource coverage for microgrid*
  - *Incorporation of available existing generation resources*
  - *Need for any new small fossil generation given PV/BESS economics?*
- **Grid-Tied**      ➤ Island-mode versus grid-connected



## Microgrid Cost, Size, Design

- Use standard sources (NREL, Lazard) to estimate costs for microgrid system, in aggregate, at high level, for purposes of this proceeding?
- Estimate total cost of microgrids
  - Note: Sandia estimates total microgrid cost ~\$1.3M-\$2M per MW of peak load
- Sizing and designing microgrids:
  - Optimize resource mix to deliver least-cost microgrid solution for each location using techno-economic modeling tool (HOMER, DER-CAM, etc.)
  - Estimate other microgrid-related construction costs (e.g. overhead/underground lines, switches, points of common coupling, etc.)
  - Add safety factor to estimate other auxiliary costs (e.g. EPC, controls, etc.)



## How much resiliency can avoided transmission buy?

- \$5.9 billion – MG elements (transmission only) – distribution needs add more
- Microgrid costs (Sandia): ~\$2 million/MW
  - @\$6 billion: 3,000 MW worth of microgrid.
- So why do any MiniGrid approach at all?
  - Densely clustered load
  - Availability of existing resources on grid, blue sky / partial outage conditions – supports resiliency, especially in near/medium term – economies of scale for utility PV, BESS
  - MiniGrid – a form of a very large microgrid



# Questions and Discussion

- Stand alone DER
  - At what scale?
  - How to procure?
  - Who pays?
  - Capacity only, or capacity + energy?
  - Timeframe of deployment
- Microgrid resources
  - Fully customer/third party, or role for PREPA / Other agencies?
  - How to design, size, integrate into PREPA grid
  - Feedback on Sandia distributed resiliency approach?
  - Timeframe of deployment
  - Other considerations?



## Wrap Up – Day 1

- Open Questions / Discussion
- Return to:
  - Analytical Approach
  - Load Segmentation
  - MiniGrid Elements
  - DER Options
- Process – Submitting information, responding to questions
- Plans for Day 2



Para más información:



<http://energia.pr.gov>



@NEPRenergia



787-523-6262



268 Ave. Muñoz Rivera, Edificio World Plaza  
Nivel Plaza - Suite 202, Hato Rey, PR 00918



# Backup Slides – Day 1



# 10-Year Plan Near Term Transmission

## Transmission – Near-Term (2021-2023)

**Table 4.5 – Near-Term Transmission Projects**

Transmission Project Name	Brief Description	Est. COR3 /FEMA Submission	Est. Cost (M USD)	IRP Reference
21- Transmission Existing (38 kV)	The objective of this project is to harden existing 38kV transmission lines to consensus-based codes and standards, improve reliability and resiliency of the infrastructure to critical loads, and accelerate future restoration efforts by strengthening and/or replacing transmission structures and components. This project includes work on 21 transmission lines for an estimated total of 442 miles.	2021 Q4	\$419.65	Section III C
12- Transmission Existing (115 & 230 kV)	The objective of this project is to harden existing 115kV and 230kV transmission lines to consensus-based codes and standards, improve reliability and resiliency of the infrastructure to critical loads, and accelerate future restoration efforts by strengthening and/or replacing transmission structures and components. This project includes work on 12 transmission lines for an estimated total of 237 miles.	2021 Q4	\$262.30	Section III C
14- Transmission New Lines (38kV, 115 & 230 kV)	The objective of this project is to build new underground or overhead transmission lines across all three voltage levels (38 kV, 115 kV, and 230 kV) to consensus-based codes and standards and increase the transmission grid reliability and resiliency by providing redundancy to existing disaster damaged lines. This project includes work on 14 transmission lines for an estimated total of 53 miles.	2022 Q2	\$215.00	Section III E



# 10- Year Plan Mid-Term Transmission Projects

## Transmission – Mid-Term (2024-2027)

**Table 4.15 – Mid-Term Transmission Projects**

Transmission Project Name	Brief Description	Est. COR3 /FEMA Submission	Est. Cost (M USD)	IRP Reference
<b>37- Transmission Existing (115 &amp; 230 kV)</b>	The objective of this project is to harden existing 115kV and 230kV transmission lines to consensus-based codes and standards, improve reliability and resiliency of the infrastructure to critical loads, and accelerate future restoration efforts by strengthening and/or replacing transmission structures and components. This project includes work on 37 transmission lines for an estimated total of 496 miles.	2025	\$548.60	Section III C
<b>40- Transmission Existing (38 kV)</b>	The objective of this project is to harden existing 38kV transmission lines to consensus-based codes and standards, improve reliability and resiliency of the infrastructure to critical loads, and accelerate future restoration efforts by strengthening and/or replacing transmission structures and components. This project includes work on 40 transmission lines for an estimated total of 511 miles.	2025	\$537.70	Section III C
<b>16- Transmission New Lines (38kV, 115 &amp; 230 kV)</b>	The objective of this project is to build new underground or overhead transmission lines across all three voltage levels (38 kV, 115 kV, and 230 kV) to consensus-based codes and standards and increase the transmission grid reliability and resiliency by providing redundancy to existing disaster damaged lines. This project includes work on 16 transmission lines for an estimated total of 125 miles.	2026	\$294.00	Section III E