



Field Inspection Report

Cargo Operation: Inventory

Asset(s)

Inventory

Product(s)

#2 Fuel Oil

Client(s)

Autoridad De Energia Electrica De Puerto Rico

Reference #

JB-END OF MONTH-5-21

Location(s)

N/A | Jobos - PREPA Guayama

All measurements contained in this report were performed according to the API manual of petroleum measurement standards:


Chapter 3 Tank Gauging; Chapter 7 Temperature Determination; Chapter 8 Sampling; Chapter 12 Calculation of Petroleum Quantities; Chapter 17 Marine Measurement.

All Bureau Veritas measurement devices and methods used for quantity and quality determination meet pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule).

All Operations to be carried out in accordance with Bureau Veritas Commodities Division General Conditions of Service (2014 Edition).

An electronic version can also be viewed on our company website:

www.bureauveritas.com/terms_and_conditions/index.asp



Victor REYES
Bureau Veritas Commodities and Trade, Inc

Table of Contents

Shore Tank Measurements - #2 Fuel Oil

1

V. Payne

Job #: PRPUE-21-10081-1

Date: 17-May-2021

Location: N/A - Jobos - PREPA Guayama

Asset(s): Inventory

Product(s): #2 Fuel Oil

Client(s): Autoridad De Energia Electrica De Puerto Rico JB-END OF MONTH-5-21

Shore Tank Measurements



**BUREAU
VERITAS**

S-1 ²		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Gal	Lines Adj	VCF Table	CoE
			Open	17-May-2021	21:45	N/A	79.0	1.00031	23.81		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Gallons	FW Gauge ft	FW Gallons	API-60°F	Temp °F	GOV Gallons	VCF 60°F	GSV Gallons			
Open	21-0 5/8	76,860.00	0-0 7/8	58.00	36.1	86.1	76,825.81	0.98778	75,887.00			
Close												
Difference		76,860.00		58.00			76,825.81					
Adjustments to GSV									75,887.00			
S-2 ²		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Gal	Lines Adj	VCF Table	CoE
			Open	17-May-2021	22:00	N/A	79.0	1.00031	70.89	0.00	6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Gallons	FW Gauge ft	FW Gallons	API-60°F	Temp °F	GOV Gallons	VCF 60°F	GSV Gallons			
Open	15-8 1/16	229,795.00	0-0 7/8	1,113.00	36.1	86.2	228,752.89	0.98774	225,948.38			
Close												
Difference		229,795.00		1,113.00			228,752.89					
Adjustments to GSV									225,948.38			

² The indicated Tank(s) were found to have no Standpipe

Shore Summary						
API-60°F	Adjustments (Gallons)			Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV	To Water			
36.1						KOLOR KUT
Shore Delivered	Shore Delivered	Total Calculated	Gross Standard			Density
	CubicMeters-15C	1,146.465	1,142.034			API-60F
	CubicMeters-60F	1,147.004	1,142.571			36.1
	Liters-60F	1,147,004	1,142,571			Table 8 Lbs/Gal (In Air)
	Barrels-60F	7,214.44	7,186.56			7.029904653
	Gallons-60F	303,006.38	301,835.38			Table 11 LT/Bbl (In Air)
	Kilograms	966,200	962,466			0.1318107123
	Pounds	2,130,106	2,121,874			Table 13 MT/Bbl (In Air)
	Short Tons	1,065.053	1,060.937			0.1339258667
	Long Tons	950.940	947.266			Table 13 MT/Bbl (In Vac)
	MT (In Air)	966.200	962.466			0.1340964527
MT (In Vac)	967.431	963.692				
	Free Water	1,171.00				

Date / Time

Date / Time

V. Reyes
Victor REYES