

Job #: PRPUE-21-10081-1

Date: 17-May-2021

Location: N/A - Jobos - PREPA Guayama

Asset(s): Inventory

Product(s): #2 Fuel Oil

# Shore Tank Measurements

# DRAFT



**BUREAU  
VERITAS**

S-1 <sup>2</sup>		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Gal	Lines Adj	VCF Table	CoE
			Open	17-May-2021	21:45	N/A	79.0	1.00031	23.81		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Gallons	FW Gauge ft	FW Gallons	API-60°F	Temp °F	GOV Gallons	VCF 60°F	GSV Gallons			
Open	21-0 5/8	76,860.00	0-0 7/8	58.00	36.1	86.1	76,825.81	0.98778	75,887.00			
Close												
Difference		76,860.00		58.00			76,825.81					
Adjustments to GSV									75,887.00			

S-2 <sup>2</sup>		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Gal	Lines Adj	VCF Table	CoE
			Open	17-May-2021	22:00	N/A	79.0	1.00031	70.89	0.00	6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Gallons	FW Gauge ft	FW Gallons	API-60°F	Temp °F	GOV Gallons	VCF 60°F	GSV Gallons			
Open	15-8 1/16	229,795.00	0-0 7/8	1,113.00	36.1	86.2	228,752.89	0.98774	225,948.38			
Close												
Difference		229,795.00		1,113.00			228,752.89					
Adjustments to GSV									225,948.38			

<sup>2</sup> The indicated Tank(s) were found to have no Standpipe

Shore Summary						
API-60°F	Adjustments (Gallons)			Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV	To Water			
36.1						KOLOR KUT
Shore Delivered	Shore Delivered	Total Calculated	Gross Standard			Density
	CubicMeters-15C	1,146.465	1,142.034			API-60F
	Barrels-60F	7,214.44	7,186.56			36.1
	Gallons-60F	303,006.38	301,835.38			Table 8 Lbs/Gal (In Air)
	Pounds	2,130,106	2,121,874			7.029904653
	Long Tons	950.940	947.266			Table 11 LT/Bbl (In Air)
	MT (In Air)	966.200	962.466			0.1318107123
	Free Water	1,171.00			Table 13 MT/Bbl (In Air)	
					0.1339258667	
					Table 13 MT/Bbl (In Vac)	
					0.1340964527	

Date / Time

Date / Time