

Job #: PRPUE-21-10343-1

Date: 30-Nov-2021

Location: Yabucoa - Prepa

Asset(s): Inventory

Product(s): #2 Fuel Oil/ Diesel

Client(s): Autoridad De Energia Electrica De Puerto Rico- YB-TANK INVENTORY-11-21

Shore Tank Measurements

DRAFT



**BUREAU
VERITAS**

S-1 ²		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Gal	Lines Adj	VCF Table	CoE
			Open	30-Nov-2021	21:30	N/A	77.0	1.00027	17.23		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Gallons	FW Gauge ft	FW Gallons	API-60°F	Temp °F	GOV Gallons	VCF 60°F	GSV Gallons			
Open	8-11 1/2	64,115.00	0-0 1/2	291.00	35.5	83.1	63,841.23	0.98924	63,154.30			
Close												
Difference		64,115.00		291.00			63,841.23					
Adjustments to GSV									63,154.30			

S-2 ²		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Gal	Lines Adj	VCF Table	CoE
			Open	30-Nov-2021		N/A	77.0	1.00029	78.52		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Gallons	FW Gauge ft	FW Gallons	API-60°F	Temp °F	GOV Gallons	VCF 60°F	GSV Gallons			
Open	18-6 9/16	271,356.00	0-0 7/8	581.00	35.5	83.3	270,853.52	0.98915	267,914.76			
Close												
Difference		271,356.00		581.00			270,853.52					
Adjustments to GSV									267,914.76			

² The indicated Tank(s) were found to have no Standpipe

Shore Summary									
API-60°F	Adjustments (Gallons)			Condition of Shore Lines	Method of Verification	Water Paste Used			
	For Meters to GSV	For Lines to GSV	To Water						
35.5				Full Before & After	Per Terminal	Kolor Kut			
Shore Delivered	Shore Delivered	Total Calculated		Gross Standard		Density			
	CubicMeters-15C	1,255.955		1,252.656		API-60F			
	CubicMeters-60F	1,256.534		1,253.233		35.5			
	Liters-60F	1,256,534		1,253,233		Table 8 Lbs/Gal (In Air)			
	Barrels-60F	7,903.36		7,882.60		7.055197758			
	Gallons-60F	331,941.06		331,069.06		Table 11 LT/Bbl (In Air)			
	Kilograms	1,062,273		1,059,482		0.1322849580			
	Pounds	2,341,910		2,335,758		Table 13 MT/Bbl (In Air)			
	Short Tons	1,170.955		1,167.879		0.1344077226			
	Long Tons	1,045.496		1,042.749		Table 13 MT/Bbl (In Vac)			
	MT (In Air)	1,062.273		1,059.482		0.1345782364			
MT (In Vac)	1,063.620		1,060.826						
Free Water		872.00							

Date / Time

Date / Time

Date / Time