

Puerto Rico  
Firm Delivery Carr 127 Km 19.1

\*[Job #:]\* PRPUE-22-00059-1  
\*[Date:]\* 28-Feb-2022



BUREAU  
VERITAS

## *\*[Field Inspection Report]\**

*\*[Cargo Operation: ]\*Inventory*

*\*[Asset(s)]\**  
Inventory

*\*[Product(s)]\**  
#2 Fuel Oil/ Diesel

*\*[Client(s)]\**  
Autoridad De Energia Electrica De Puerto Rico

*\*[Reference #]\**  
JB-TANK INVENTORY-2-22

*\*[Location(s)]\**  
Guayama | Prepa - Jobs

All measurements contained in this report were performed according to the API manual of petroleum measurement standards:  
Chapter 3 Tank Gauging; Chapter 7 Temperature Determination; Chapter 8 Sampling; Chapter 12 Calculation of Petroleum Quantities; Chapter 17 Marine Measurement.

All Bureau Veritas measurement devices and methods used for quantity and quality determination meet pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule).

All Operations to be carried out in accordance with Bureau Veritas Commodities Division General Conditions of Service (2014 Edition).  
An electronic version can also be viewed on our company website: <https://commodities.bureauveritas.com/general-conditions-service>

Victor REYES

Bureau Veritas Commodities and Trade, Inc

# Table of Contents

Shore Tank Measurements - #2 Fuel Oil/ Diesel

1

V. Rey

\*[Job #:]\* PRPUE-22-00059-1

\*[Date:]\* 28-Feb-2022

\*[Location:]\* Guayama - Prepa - Jobos

\*[Asset(s):] Inventory

\*[Product #] 2 Fuel Oil/ Diesel

\*[Client(s):] Autoridad De Energia Electrica De Puerto Rico-JB-TANK INVENTORY-2-22

# Shore Tank Measurements



**BUREAU  
VERITAS**

S1 <sup>2</sup>		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Gal	Lines Adj	VCF Table	CoE
			Open	28-Feb-2022	18:30	N/A	79.0	1.00027	17.81		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Gallons	FW Gauge ft	FW Gallons	API-60°F	Temp °F	GOV Gallons	VCF 60°F	GSV Gallons			
Open	18-1 1/8	66,007.00	0-0 3/4	51.00	35.5	82.8	65,973.81	0.98938	65,273.17			
Close												
Difference		66,007.00		51.00			65,973.81					
Adjustments to GSV										65,273.17		

S2 <sup>2</sup>		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Gal	Lines Adj	VCF Table	CoE
			Open	28-Feb-2022	18:50	N/A	79.0	1.00029	84.70		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Gallons	FW Gauge ft	FW Gallons	API-60°F	Temp °F	GOV Gallons	VCF 60°F	GSV Gallons			
Open	19-11 3/4	293,083.00	0-0 3/4	1,018.00	35.5	83.4	292,149.70	0.98910	288,965.27			
Close												
Difference		293,083.00		1,018.00			292,149.70					
Adjustments to GSV										288,965.27		

<sup>2</sup> The indicated Tank(s) were found to have no Standpipe

Shore Summary						
API-60°F	Adjustments (Gallons)			Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV	To Water			
35.5				Full Before & After	Per Terminal	Kolor Kut
	Shore Delivered	Total Calculated	Gross Standard			Density
	CubicMeters-15C	1,344	1,340			
	CubicMeters-60F	1,345	1,341			
	Liters-60F	1,344,985	1,340,939			
	Barrels-60F	8,460	8,434			
	Gallons-60F	355,307	354,238			
	Kilograms	1,137,049	1,133,628			
	Pounds	2,506,764	2,499,222			
	Short Tons	1,253	1,250			
	Long Tons	1,119	1,116			
	MT (In Air)	1,137	1,134			
	MT (In Vac)	1,138	1,135			
	Free Water					

\*[Date / Time]\*

\*[Date / Time]\*

*V. Reyes*  
Victor REYES

\*[Date / Time]\*