



Field Inspection Report

Cargo Operation: Inventory

Vessel(s)

Product(s)

#2 Fuel Oil/ Diesel

Client(s)

Autoridad De Energia Electrica De Puerto Rico

Reference #

DG-TANKINVENTORY-8-22

Location(s)

Daguao | PREPA - Ceiba

All measurements contained in this report were performed according to the API manual of petroleum measurement standards:

Chapter 3 Tank Gauging; Chapter 7 Temperature Determination; Chapter 8 Sampling; Chapter 12 Calculation of Petroleum Quantities; Chapter 17 Marine Measurement.

All Bureau Veritas measurement devices and methods used for quantity and quality determination meet pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule).

All Operations to be carried out in accordance with Bureau Veritas Commodities Division General Conditions of Service (2014 Edition). An electronic version can also be viewed on our company website: www.bureauveritas.com/terms_and_conditions/index.asp

REYES

Bureau Veritas Commodities and Trade, Inc

Table of Contents

Shore Tanks Measurements - #2 Fuel Oil/ Diesel

1

V. Rey

Job #: PRPUE-22-00187-1

Date: 31-Aug-2022

Location(s): Daguaao - PREPA - Celba

Vessel(s):

Product(s): #2 Fuel Oil/ Diesel

Client(s): Autoridad De Energia Electrica De Puerto Rico-DG-TANKINVENTORY-8-22

Shore Tanks Measurements



**BUREAU
VERITAS**

S-1 ²		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Gal	Lines Adj	VCF Table	CoE
			Open	31-Aug-2022	18:30	N/A	82.0	1.00031	123.91		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Gallons	FW Gauge ft	FW Gallons	API-60°F	Temp °F	GOV Gallons	VCF 60°F	GSV Gallons			
Open	27-1 11/16	399,722.00	Nil	0.00	33.4	85.1	399,845.91	0.98850	395,247.68			
Close												
Difference		399,722.00		0.00			399,845.91					
Adjustments to GSV										395,247.68		

² The indicated Tank(s) were found to have no Standpipe

Shore Summary									
API-60°F	Adjustments (Gallons)			Condition of Shore Lines	Method of Verification	Water Paste Used			
	For Meters to GSV	For Lines to GSV	To Water						
33.4				Full Before & After	Per Terminal	Kolor Kut			
Shore Delivered	Shore Delivered	Total Calculated		Gross Standard		Density			
	Cubic Meters 15°C	1,495.487		1,495.487		API 60°F	33.4		
	Cubic Meters 60°F	1,496.175		1,496.175		Table 8 Lbs/Gal (In Air)	7.145173108		
	Liters 60°F	1,496,175		1,496,175		Table 11 LT/Bbl (In Air)	0.1339719958		
	Barrels 60°F	9,410.66		9,410.66		Table 13 MT/Bbl (In Air)	0.1361218322		
	Gallons 60°F	395,247.68		395,247.68		Table 13 MT/Bbl (In Vac)	0.1362920890		
	Kilograms	1,280,996		1,280,996					
	Pounds	2,824,113		2,824,113					
	Short Tons	1,412.057		1,412.057					
	Long Tons	1,260.765		1,260.765					
MT (In Air)	1,280.996		1,280.996						
MT (In Vac)	1,282.599		1,282.599						
Free Water		0.00							

Date/Time

Date/Time

Date/Time

31-Aug-2022