

Job #: PRPUE-22-00187-1

Date: 31-Aug-2022

Location(s): Daguao - PREPA - Ceiba

Vessel(s):

Product(s): #2 Fuel Oil/ Diesel

Shore Tanks Measurements

DRAFT



**BUREAU
VERITAS**

S-1 ²		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Gal	Lines Adj	VCF Table	CoE
			Open	31-Aug-2022	18:30	N/A	82.0	1.00031	123.91		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Gallons	FW Gauge ft	FW Gallons	API-60°F	Temp °F	GOV Gallons	VCF 60°F	GSV Gallons			
Open	27-1 11/16	399,722.00	Nil	0.00	33.4	85.1	399,845.91	0.98850	395,247.68			
Close												
Difference		399,722.00		0.00			399,845.91					
Adjustments to GSV										395,247.68		

² The indicated Tank(s) were found to have no Standpipe

Shore Summary						
API-60°F	Adjustments (Gallons)			Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV	To Water			
33.4				Full Before & After	Per Terminal	Kolor Kut
Shore Delivered	Shore Delivered	Total Calculated	Gross Standard			Density
	Cubic Meters 15°C	1,495.487	1,495.487			API 60°F
	Cubic Meters 60°F	1,496.175	1,496.175			33.4
	Liters 60°F	1,496,175	1,496,175			Table 8 Lbs/Gal (In Air)
	Barrels 60°F	9,410.66	9,410.66			7.145173108
	Gallons 60°F	395,247.68	395,247.68			Table 11 LT/Bbl (In Air)
	Kilograms	1,280,996	1,280,996			0.1339719958
	Pounds	2,824,113	2,824,113			Table 13 MT/Bbl (In Air)
	Short Tons	1,412.057	1,412.057			0.1361218322
	Long Tons	1,260.765	1,260.765			Table 13 MT/Bbl (In Vac)
	MT (In Air)	1,280.996	1,280.996			0.1362920890
	MT (In Vac)	1,282.599	1,282.599			
	Free Water	0.00				

Date/Time

Date/Time

Date/Time

31-Aug-2022

VICTOR REYES

Bureau Veritas Commodities and Trade, Inc