



Field Inspection Report

Cargo Operation: Inventory

Vessel(s)

Product(s)

ULSD

Client(s)

Autoridad De Energia Electrica De Puerto Rico

Reference #

JB-TANK INV-2-29-24

Location(s)

GeneraPR - Jobos

All measurements contained in this report were performed according to the API manual of petroleum measurement standards:

Chapter 3 Tank Gauging; Chapter 7 Temperature Determination; Chapter 8 Sampling; Chapter 12 Calculation of Petroleum Quantities; Chapter 17 Marine Measurement.

All Bureau Veritas measurement devices and methods used for quantity and quality determination meet pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule).

All Operations to be carried out in accordance with Bureau Veritas Commodities Division General Conditions of Service (2014 Edition). An electronic version can also be viewed on our company website: www.bureauveritas.com/terms_and_conditions/index.asp

Victor REYES
Bureau Veritas Commodities and Trade, Inc

Table of Contents

Shore Tanks Measurements - ULSD

1

V. Reyes

Job #: PRPUE-24-00068-1

Date: 29-Feb-2024

Location(s): GeneraPR - Jobos

Vessel(s):

Product(s): ULSD

Client(s): Autoridad De Energia Electrica De Puerto Rico-JB-TANK INV-2-29-24



**BUREAU
VERITAS**

S-1	Crit Zone	Phase	Date/Time	Roof Adj	Amb °F	CTSh Factor	CTSh Gal	Lines Adj	VCF Table	CoE
API:		Open	29-Feb-2024 18:50	N/A	78.0	1.00035	3.46		6B-60°F	
Vol:		Close		N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Gallons	FW Gauge ft	FW Gallons	API-60°F	Temp °F	GOV Gallons	VCF 60°F	GSV Gallons
Open	2-10 1/8	9897.00	0-0	0.00	35.0	89.0	9900.46	0.98654	9767.20
Close									
Difference		9897.00		0.00			9900.46		9767.20
Adjustments to GSV									9767.20

S-2	Crit Zone	Phase	Date/Time	Roof Adj	Amb °F	CTSh Factor	CTSh Gal	Lines Adj	VCF Table	CoE
API:		Open	29-Feb-2024 18:45	N/A	78.0	1.00031	80.59		6B-60°F	
Vol:		Close		N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Gallons	FW Gauge ft	FW Gallons	API-60°F	Temp °F	GOV Gallons	VCF 60°F	GSV Gallons
Open	17-9 3/8	260788.00	0-0 1/2	828.00	35.0	86.0	260040.59	0.98794	256904.50
Close									
Difference		260788.00		828.00			260040.59		256904.50
Adjustments to GSV									256904.50

Shore Summary

API-60°F	Adjustments (Gallons)			Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV	To Water			
35.0				Full Before & After	Per Terminal	Kolor Kut
Shore Delivered	Shore Delivered		Total Calculated	Gross Standard		Density
	Cubic Meters 15°C		1,012.131	1,008.999		API 60°F
	Cubic Meters 60°F		1,012.596	1,009.463		35.0
	Liters 60°F		1,012,596	1,009,463		Table 8 Lbs/Gal (In Air)
	Barrels 60°F		6,369.04	6,349.33		7.076414596
	Gallons 60°F		267,499.70	266,671.70		Table 11 LT/Bbl (In Air)
	Kilograms		858,623	855,965		0.1326827737
	Pounds		1,892,939	1,887,080		Table 13 MT/Bbl (In Air)
	Short Tons		946.470	943.540		0.1348119220
	Long Tons		845.062	842.447		Table 13 MT/Bbl (In Vac)
	MT (In Air)		858.623	855.965		0.1349823752
MT (In Vac)		859.708	857.048			
Free Water		828.00				

Date/Time

Date/Time

V. Reyes
Victor REYES

Date/Time
29-Feb-2024