



## Field Inspection Report

### Cargo Operation: Inventory

**Vessel(s)**

**Product(s)**

ULSD

**Client(s)**

Autoridad De Energia Electrica De Puerto Rico

**Reference #**

DG-TANK-INV-2-29-24

**Location(s)**

GeneraPR - Daguao

All measurements contained in this report were performed according to the API manual of petroleum measurement standards:

Chapter 3 Tank Gauging; Chapter 7 Temperature Determination; Chapter 8 Sampling; Chapter 12 Calculation of Petroleum Quantities; Chapter 17 Marine Measurement.

All Bureau Veritas measurement devices and methods used for quantity and quality determination meet pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule).

All Operations to be carried out in accordance with Bureau Veritas Commodities Division General Conditions of Service (2014 Edition). An electronic version can also be viewed on our company website: [www.bureauveritas.com/terms\\_and\\_conditions/index.asp](http://www.bureauveritas.com/terms_and_conditions/index.asp)

Victor REYES  
Bureau Veritas Commodities and Trade, Inc

# Table of Contents

Shore Tanks Measurements - ULSD

1

V. Ray

Job #: PRPUE-24-00069-1  
 Date: 29-Feb-2024

# Shore Tanks Measurements



Location(s): GeneraPR - Daguao  
 Vessel(s):  
 Product(s): ULSD  
 Client(s): Autoridad De Energia Electrica De Puerto Rico-DG-TANK-INV-2-29-24

**BUREAU  
 VERITAS**

S-1	Crit Zone	Phase	Date/Time	Roof Adj	Amb °F	CTSh Factor	CTSh Gal	Lines Adj	VCF Table	CoE
API:		Open	29-Feb-2024 20:45	N/A	73.0	1.00031	127.84		6B-60°F	
Vol:		Close	29-Feb-2024	N/A					6B-60°F	

  

Operation Phase	Gauge ft	TOV Gallons	FW Gauge ft	FW Gallons	API-60°F	Temp °F	GOV Gallons	VCF 60°F	GSV Gallons
Open	28-0	412400.00	0-0	0.00	34.0	86.6	412527.84	0.98775	407474.37
Close									
Difference		412400.00		0.00			412527.84		407474.37
Adjustments to GSV									407474.37

Shore Summary						
API-60°F	Adjustments (Gallons)			Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV	To Water			
34.0				Full Before & After	Per Terminal	Kolor Kut

  

Shore Delivered	Shore Delivered	Total Calculated	Gross Standard	Density	
	Cubic Meters 15°C		1,541.749	1,541.749	API 60°F
	Cubic Meters 60°F		1,542.458	1,542.458	34.0
	Liters 60°F		1,542,458	1,542,458	Table 8 Lbs/Gal (In Air)
	Barrels 60°F		9,701.77	9,701.77	7.119232869
	Gallons 60°F		407,474.37	407,474.37	Table 11 LT/Bbl (In Air)
	Kilograms		1,315,828	1,315,828	0.1334856163
	Pounds		2,900,905	2,900,905	Table 13 MT/Bbl (In Air)
	Short Tons		1,450.453	1,450.453	0.1356276478
	Long Tons		1,295.047	1,295.047	Table 13 MT/Bbl (In Vac)
	MT (In Air)		1,315.828	1,315.828	0.1357979787
MT (In Vac)		1,317.481	1,317.481		
	Free Water		0.00		

Date/Time \_\_\_\_\_ Date/Time \_\_\_\_\_  
 V. Reyes 29-Feb-2024  
 Victor REYES