



## Field Inspection Report

### Cargo Operation: Inventory

**Vessel(s)**

**Product(s)**

ULSD

**Client(s)**

Autoridad De Energia Electrica De Puerto Rico

**Reference #**

CAM-TANK-INV-2-29-24

**Location(s)**

GeneraPR - Cambalache

All measurements contained in this report were performed according to the API manual of petroleum measurement standards:

Chapter 3 Tank Gauging, Chapter 7 Temperature Determination, Chapter 8 Sampling, Chapter 12 Calculation of Petroleum Quantities, Chapter 17 Manne Measurement.

All Bureau Veritas measurement devices and methods used for quantity and quality determination meet pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule).

All Operations to be carried out in accordance with Bureau Veritas Commodities Division General Conditions of Service (2014 Edition). An electronic version can also be viewed on our company website: [www.bureauveritas.com/terms\\_and\\_conditions/index.asp](http://www.bureauveritas.com/terms_and_conditions/index.asp)

Reinaldo LUGO  
Bureau Veritas Commodities and Trade, Inc

# Table of Contents

Shore Tanks Measurements - ULSD

1

R. Dy

Job #: PRPUE-24-00071-1

Date: 29-Feb-2024

Location(s): GeneraPR - Cambalache

Vessel(s):

Product(s): ULSD

Client(s): Autoridad De Energia Electrica De Puerto Rico-CAM-TANK-INV-2-29-24



BUREAU VERITAS

D-1	Crit Zone	Phase	Date/Time	Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
API:		Open	29-Feb-2024 00:01	N/A	74.0	0.99989	-3.71		6B-60°F	
Vol:		Close		N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels
Open	33-9 5/8	34003.21	0-1 7/8	234.41	35.0	76.7	33765.09	0.99226	33503.75
Close									
Difference		34003.21		234.41			33765.09		33503.75
Adjustments to GSV									33503.75

D-3	Crit Zone	Phase	Date/Time	Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
API:		Open	29-Feb-2024 23:45	N/A	74.0	0.99993	-4.64		6B-60°F	
Vol:		Close		N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels
Open	18-1 3/4	66764.62	0-3 1/2	447.99	34.0	80.0	66311.99	0.99080	65701.92
Close									
Difference		66764.62		447.99			66311.99		65701.92
Adjustments to GSV									65701.92

### Shore Summary

API-60°F	Adjustments (Bbls)		To Water	Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV				
34.3						Kolor Kut

Shore Delivered	Shore Delivered	Total Calculated	Gross Standard
	Cubic Meters 15°C	15,873.632	15,765.190
	Barrels 60°F	99,888.07	99,205.67
	Gallons 60°F	4,195,298.94	4,166,638.14
	Pounds	29,813,192	29,609,519
	Long Tons	13,309.461	13,218.535
	MT (In Air)	13,523.036	13,430.652
	Free Water	682.40	

Density
API 60°F
34.3
Table 8 Lbs/Gal (In Air)
7.106333154
Table 11 LT/Bbi (In Air)
0.1332437467
Table 13 MT/Bbi (In Air)
0.1353818969
Table 13 MT/Bbi (In Vac)
0.1355522646

Date/Time

Date/Time

 Date/Time

Reinaldo LUGO