

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08080 / AGUIRRE / 08/31/2025

Digitally Generated by : Saybolt
Reason : Reporting
Location : 13101 Saybolt Puerto Rico - All Activity
Date : 2025.09.02 13:13:36 -04:00



Job No 13101/00018491.0000/01/I/25
Report date 02 Sep 2025
Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank **END OF THE MONTH INVENTORY / AGUIRRE**
Product **NO6, NO2**

Survey date: 31-Aug-2025, 31-Aug-2025

Contents page

Saybolt LP (Puerto Rico) has performed a survey and the findings of the survey are reflected in the following reports:

Title	Number of Pages
Contents page	one
Shore Tank Inventory Report	three
Shore Tank Inventory Subtotals	three
Certificate of Quantity	two

This report consists of 9 pages.

A copy of this report and all field documents and related correspondence will be retained for a period of 10 years, unless local law requires otherwise

Handled by: Rafael Rodriguez

This report reflects only the findings at the time and place of the inspection and testing. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions.



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 08080 / AGUIRRE / 08/31/2025



Job No 13101/00018491.0000/01/I/25
 Report date 02 Sep 2025
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank **END OF THE MONTH INVENTORY / AGUIRRE**
Product **NO2**

Survey date: 31-Aug-2025

Shore Tank Inventory Report - 1

Shore tank measurement		Totals	R-1 (2)	R-6	D-2	R-2
Open measurement						
Date/time of measurement		31 Aug 2025 21:00	31 Aug 2025 21:30	01 Sep 2025 00:05	31 Aug 2025 21:15	
Average Innage	FT/IN	27 08-9/16	32 00-1/4	16 07-1/2	36 05-1/4	
Average temp.	°F	86.9	89.7	92.9	86.9	
T.O.V.	Barrels	24,690.92	213,393.70	11,571.71	32,465.38	
Free Water		Traces				
Water	FT/IN	00 02-3/4		00 09-1/2	00 02-3/8	
Water	Barrels	85.18		706.50	55.49	
Ambient temp.	°F	80.00	80.00	80.00	80.00	
Tank shell temp.	°F	86.00	88.00	91.00	86.00	
CTsh		1.00032	1.00035	1.00038	1.00032	
G.O.V.	Barrels	24,613.61	213,468.39	10,869.34	32,420.26	
API 60°F		35.50	35.80	35.80	35.20	
V.C.F.	6B	0.98747	0.98613	0.98462	0.98750	
G.S.V.	barrels 60°F	24,305.20	210,507.58	10,702.17	32,015.01	
W.C.F.	MPMS 11.5.1.4.12	0.1322849580	0.1320474099	0.1320474099	0.1325233610	
W.C.F.	MPMS 11.5.1.4.15	0.1344077226	0.1341663626	0.1341663626	0.1346499513	
Long Tons		3,215.212	27,796.981	1,413.194	4,242.737	
Metric Tons Air		3,266.807	28,243.036	1,435.871	4,310.820	
Subtotals						
G.S.V.	barrels 60°F	327,168.26	24,305.20	210,507.58	10,702.17	32,015.01
Long Tons		43,212.175	3,215.212	27,796.981	1,413.194	4,242.737

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 08080 / AGUIRRE / 08/31/2025



Job No 13101/00018491.0000/01/I/25
 Report date 02 Sep 2025
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank **END OF THE MONTH INVENTORY / AGUIRRE**
Product **NO2**

Survey date: 31-Aug-2025

Shore Tank Inventory Report - 2

Shore tank measurement		D-4 CC	TG-1	TG-2	D-1
Open measurement					
Date/time of measurement		31 Aug 2025 23:20	31 Aug 2025 22:05	31 Aug 2025 21:50	31 Aug 2025 23:15
Average Innage	FT/IN	17 06-1/4	29 05-3/8	33 00-1/2	33 03-3/8
Average temp.	°F	89.0	87.0	88.0	91.6
T.O.V.	Barrels	12,007.38	10,345.36	5,669.93	22,803.26
Free Water					
Water	FT/IN	00 00-3/8	00 00-1/2	00 07-1/2	00 06-3/4
Water	Barrels	21.40	38.48	99.94	345.76
Ambient temp.	°F	80.00	80.00	80.00	80.00
Tank shell temp.	°F	88.00	86.00	87.00	90.00
CTsh		1.00035	1.00032	1.00033	1.00037
G.O.V.	Barrels	11,990.18	10,310.18	5,571.83	22,465.81
API 60°F		33.30	38.30	39.20	35.80
V.C.F.	6B	0.98672	0.98708	0.98646	0.98523
G.S.V.	barrels 60°F	11,830.95	10,176.97	5,496.39	22,133.99
W.C.F.	MPMS 11.5.1.4.12	0.1340534034	0.1301004858	0.1294135534	0.1320474099
W.C.F.	MPMS 11.5.1.4.15	0.1362045461	0.1321881963	0.1314902409	0.1341663626
Long Tons		1,585.979	1,324.029	711.307	2,922.736
Metric Tons Air		1,611.429	1,345.275	722.722	2,969.637
Subtotals					
G.S.V.	barrels 60°F	11,830.95	10,176.97	5,496.39	22,133.99
Long Tons		1,585.979	1,324.029	711.307	2,922.736

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 08080 / AGUIRRE / 08/31/2025



Job No 13101/00018491.0000/01/I/25
 Report date 02 Sep 2025
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY / AGUIRRE
Product NO6

Shore Tank Inventory Report

Survey date: 31-Aug-2025

Shore tank measurement		Totals	R-1	R-3	S-1	S-2
Open measurement						
Date/time of measurement		31 Aug 2025 22:40	31 Aug 2025 23:00	31 Aug 2025 22:20	01 Sep 2025 00:00	
Average Innage	FT/IN	42 11-7/8	09 08-3/8	05 04-3/4	07 07-0/0	
Average temp.	°F	99.9	93.5	84.1	94.9	
T.O.V.	Barrels	286,949.42	63,934.94	31,566.28	29,572.31	
Free Water		NIL	NIL	NIL	NIL	
Ambient temp.	°F	80.00	80.00	80.00	80.00	
Tank shell temp.	°F	97.00	92.00	84.00	93.00	
CTsh		1.00046	1.00040	1.00030	1.00041	
G.O.V.	Barrels	287,081.42	63,960.51	31,575.75	29,584.43	
API 60°F		17.30	18.70	18.00	17.30	
V.C.F.	6B	0.98399	0.98640	0.99029	0.98600	
G.S.V.	barrels 60°F	282,485.25	63,090.65	31,269.15	29,170.25	
W.C.F.	MPMS 11.5.1.4.12	0.1484879284	0.1471021371	0.1477917884	0.1484879284	
W.C.F.	MPMS 11.5.1.4.15	0.1508707005	0.1494626716	0.1501633897	0.1508707005	
Long Tons		41,945.650	9,280.769	4,621.324	4,331.430	
Metric Tons Air		42,618.748	9,429.697	4,695.482	4,400.936	
Subtotals						
G.S.V.	barrels 60°F	406,015.30	282,485.25	63,090.65	31,269.15	29,170.25
Long Tons		60,179.173	41,945.650	9,280.769	4,621.324	4,331.430

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 08080 / AGUIRRE / 08/31/2025



Job No 13101/00018491.0000/01/I/25
 Report date 02 Sep 2025
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY / AGUIRRE
Product NO2

Survey date: 31-Aug-2025

Shore Tank Inventory Subtotals - 1

Shore tank Subtotals	Totals	R-1 (2)	R-6	D-2	R-2
Gross Standard Volume					
Cu m 60°F	52,015.599	3,864.218	33,468.033	1,701.509	5,089.980
Barrels 60°F	327,168.26	24,305.20	210,507.58	10,702.17	32,015.01
US Gallons 60°F	13,741,066.92	1,020,818.40	8,841,318.36	449,491.14	1,344,630.42
Metric Tons Vac	43,961.364	3,270.949	28,278.919	1,437.695	4,316.275
Metric Tons Air	43,905.597	3,266.807	28,243.036	1,435.871	4,310.820
Long Tons Air	43,212.175	3,215.212	27,796.981	1,413.194	4,242.737
Short Tons Air	48,397.634	3,601.037	31,132.619	1,582.777	4,751.865
Pounds Air	96,795,268.00	7,202,074.00	62,265,238.00	3,165,554.00	9,503,730.00
Density 15°C		0.8469	0.8454	0.8454	0.8484
API 60°F		35.50	35.80	35.80	35.20
RD 60/60°		0.8473	0.8458	0.8458	0.8488
Total Calculated Volume					
Barrels 60°F	328,521.01	24,390.38	210,507.58	11,408.67	32,070.50
US Gallons 60°F	13,797,882.42	1,024,395.96	8,841,318.36	479,164.14	1,346,961.00



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 08080 / AGUIRRE / 08/31/2025



Job No 13101/00018491.0000/01/I/25
 Report date 02 Sep 2025
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY / AGUIRRE
Product NO2

Survey date: 31-Aug-2025

Shore Tank Inventory Subtotals - 2

Shore tank Subtotals	D-4 CC	TG-1	TG-2	D-1
Gross Standard Volume				
Cu m 60°F	1,880.971	1,618.009	873.856	3,519.023
Barrels 60°F	11,830.95	10,176.97	5,496.39	22,133.99
US Gallons 60°F	496,899.90	427,432.74	230,848.38	929,627.58
Metric Tons Vac	1,613.442	1,347.013	723.661	2,973.410
Metric Tons Air	1,611.429	1,345.275	722.722	2,969.637
Long Tons Air	1,585.979	1,324.029	711.307	2,922.736
Short Tons Air	1,776.296	1,482.912	796.664	3,273.464
Pounds Air	3,552,592.00	2,965,824.00	1,593,328.00	6,546,928.00
Density 15°C	0.8582	0.8329	0.8285	0.8454
API 60°F	33.30	38.30	39.20	35.80
RD 60/60°	0.8586	0.8333	0.8289	0.8458
Total Calculated Volume				
Barrels 60°F	11,852.35	10,215.45	5,596.33	22,479.75
US Gallons 60°F	497,798.70	429,048.90	235,045.86	944,149.50



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 08080 / AGUIRRE / 08/31/2025



Job No 13101/00018491.0000/01/I/25
 Report date 02 Sep 2025
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY / AGUIRRE
Product NO6

Survey date: 31-Aug-2025

Shore Tank Inventory Subtotals

Shore tank Subtotals	Totals	R-1	R-3	S-1	S-2
Gross Standard Volume					
Cu m 60°F	64,551.277	44,911.568	10,030.612	4,971.398	4,637.699
Barrels 60°F	406,015.30	282,485.25	63,090.65	31,269.15	29,170.25
US Gallons 60°F	17,052,642.60	11,864,380.50	2,649,807.30	1,313,304.30	1,225,150.50
Metric Tons Vac	61,213.079	42,666.197	9,440.308	4,700.738	4,405.836
Metric Tons Air	61,144.863	42,618.748	9,429.697	4,695.482	4,400.936
Long Tons Air	60,179.173	41,945.650	9,280.769	4,621.324	4,331.430
Short Tons Air	67,400.674	46,979.128	10,394.461	5,175.883	4,851.202
Pounds Air	134,801,348.00	93,958,256.00	20,788,922.00	10,351,766.00	9,702,404.00
Density 15°C		0.9504	0.9415	0.9459	0.9504
API 60°F		17.30	18.70	18.00	17.30
RD 60/60°		0.9509	0.9421	0.9465	0.9509
Total Calculated Volume					
Barrels 60°F	406,015.30	282,485.25	63,090.65	31,269.15	29,170.25
US Gallons 60°F	17,052,642.60	11,864,380.50	2,649,807.30	1,313,304.30	1,225,150.50



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08080 / AGUIRRE / 08/31/2025



Job No 13101/00018491.0000/01/I/25
Report date 02 Sep 2025
Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY / AGUIRRE
Product NO6

Survey date: 31 Aug 2025

Certificate of Quantity

The undersigned Independent Saybolt Surveyor herewith declares that the quantity of product measured amounts to:

	Gross	Net
Cubic meters 60°F	64,551.277	64,551.277
Barrels 60°F	406,015.30	406,015.30
US Gallons 60°F	17,052,642.60	17,052,642.60
Metric Tons vac	61,213.079	61,213.079
Metric Tons air	61,144.863	61,144.863
Long Tons	60,179.173	60,179.173
Short Tons	67,400.674	67,400.674
Pounds	134,801,348.00	134,801,348.00

These quantities have been determined by measurement of shore tanks.

B/L API 60°F	17.57
B/L Density 15°C	0.9487
B/L Density 20°C	0.9453
B/L RD 60/60°F	0.9492

Criteria used

US Barrels 60°F to Cu m 60°F	MPMS 11.5 - Annex D	0.158987304
US Barrels 60°F to US Gallons 60°F	MPMS 11.5 - Annex D	42
Metric Tons Air to Metric Tons Vac	MPMS 11.5.3 - 4.5	1.001115582
Barrels 60°F to Metric Tons Air	MPMS 11.5.1 - 4.15	0.1505970937
Barrels 60°F to Long Tons	MPMS 11.5.1 - 4.12	0.1482186427
Long Tons to Short Tons	MPMS 11.5 - Annex D	1.12

Remark

Net via S&W Volume %

Signed by: Saybolt representative
Name:
Rank: Saybolt Inspector



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08080 / AGUIRRE / 08/31/2025



Job No 13101/00018491.0000/01/1/25
Report date 02 Sep 2025
Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY / AGUIRRE
Product NO2

Survey date: 31 Aug 2025

Certificate of Quantity

The undersigned Independent Saybolt Surveyor herewith declares that the quantity of product measured amounts to:

	Gross	Net
Cubic meters 60°F	52,015.599	52,015.599
Barrels 60°F	327,168.26	327,168.26
US Gallons 60°F	13,741,066.92	13,741,066.92
Metric Tons vac	43,961.364	43,961.364
Metric Tons air	43,905.597	43,905.597
Long Tons	43,212.175	43,212.175
Short Tons	48,397.634	48,397.634
Pounds	96,795,268.00	96,795,268.00

These quantities have been determined by measurement of shore tanks.

B/L API 60°F	35.76
B/L Density 15°C	0.8456
B/L Density 20°C	0.8421
B/L RD 60/60°F	0.8460

Criteria used

US Barrels 60°F to Cu m 60°F	MPMS 11.5 - Annex D	0.158987304
US Barrels 60°F to US Gallons 60°F	MPMS 11.5 - Annex D	42
Metric Tons Air to Metric Tons Vac	MPMS 11.5.3 - 4.5	1.001270095
Barrels 60°F to Metric Tons Air	MPMS 11.5.1 - 4.15	0.1341984939
Barrels 60°F to Long Tons	MPMS 11.5.1 - 4.12	0.1320790338
Long Tons to Short Tons	MPMS 11.5 - Annex D	1.12

Remark

Net via S&W Volume %

Signed by: Saybolt representative
Name:
Rank: Saybolt Inspector

