



Field Inspection Report

Cargo Operation: Inventory

Vessel(s)

Inventory

Product(s)

No. 2 Fuel Oil

Client(s)

Autoridad De Energia Electrica De Puerto Rico

Reference #

CAM-TANKINVENTORY-8-25

Location(s)

Arecibo | GeneraPR - Cambalache

All measurements contained in this report were performed according to the API manual of petroleum measurement standards:

Chapter 3 Tank Gauging; Chapter 7 Temperature Determination; Chapter 8 Sampling; Chapter 12 Calculation of Petroleum Quantities; Chapter 17 Marine Measurement.

All Bureau Veritas measurement devices and methods used for quantity and quality determination meet pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule).

All Operations to be carried out in accordance with Bureau Veritas Commodities Division General Conditions of Service (2014 Edition). An electronic version can also be viewed on our company website: www.bureauveritas.com/Terms_and_conditions/index.asp

Reinaldo LUGO
Bureau Veritas Commodities and Trade, Inc

Table of Contents

Shore Tanks Measurements - No. 2 Fuel Oil

1

R. B.

Job #: PRPUE-25-00314-1

Date: 31-Aug-2025

Location(s): Arecibo - GeneraPR - Cambalache

Vessel(s): Inventory

Product(s): No. 2 Fuel Oil

Client(s): Autoridad De Energia Electrica De Puerto Rico-CAM-TANKINVENTORY-8-25

Shore Tanks Measurements

BUREAU
VERITAS

D-1	Crit Zone	Phase	Date/Time	Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
		Open	01-Sep-2025 00:00	N/A	76.0	0.99996	-3.27		6B-60°F	
		Close		N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels
Open	10-8 11/16	82,052.14	0-1 5/8	199.26	35.9	82.6	81,849.61	0.98944	80,985.28
Close									
Difference		82,052.14		199.26			81,849.61		80,985.28
Adjustments to GSV									80,985.28

D-3	Crit Zone	Phase	Date/Time	Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
		Open	31-Aug-2025 23:35	N/A	76.0	1.00002	1.77		6B-60°F	
		Close		N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels
Open	7-6 7/8	88,812.76	0-2 1/2	290.31	34.5	88.4	88,524.22	0.98687	87,361.90
Close									
Difference		88,812.76		290.31			88,524.22		87,361.90
Adjustments to GSV									87,361.90

Shore Summary

API-60°F	Adjustments (Bbls)			Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV	To Water			

35.2

Kolor Kut

Shore Delivered	Shore Delivered	Total Calculated	Gross Standard
	Cubic Meters 15°C	26,830.556	26,752.757
	Barrels 60°F	168,836.75	168,347.18
	Gallons 60°F	7,091,143.50	7,070,581.56
	Pounds	50,119,582	49,974,252
	Long Tons	22,374.814	22,309.934
	MT (In Air)	22,733.860	22,667.940
	Free Water	489.57	

Density
API 60°F
35.2
Table 8 Lbs/Gal (In Air)
7.067912588
Table 11 LT/Bbl (In Air)
0.1325233610
Table 13 MT/Bbl (In Air)
0.1346499513
Table 13 MT/Bbl (In Vac)
0.1348204288

Date/Time

Date/Time

Date/Time

Reinaldo LUGO

Bureau Veritas Commodities and Trade, Inc