

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08081 / JOBOS 08/31/2025

Digitally Generated by : Saybolt
Reason : Reporting
Location : 13101 Saybolt Puerto Rico - All Activity
Date : 2025.09.03 13:45:18 -04:00



Job No 13101/00018492.0000/01/I/25
Report date 03 Sep 2025
Installation Arroyo, Puerto Rico, PREPA Jobos Turbine Power Block

Shore tank **END OF THE MONTH INVENTORY / JOBOS**
Product **NO2**

Survey date: 31-Aug-2025

Contents page

Saybolt LP (Puerto Rico) has performed a survey and the findings of the survey are reflected in the following reports:

Title	Number of Pages
Contents page	one
Shore Tank Inventory Report	one
Shore Tank Inventory Subtotals	one
Certificate of Quantity	one

This report consists of 4 pages.

A copy of this report and all field documents and related correspondence will be retained for a period of 10 years, unless local law requires otherwise

Handled by: Rafael Rodriguez

This report reflects only the findings at the time and place of the inspection and testing. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions.



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 08081 / JOBOS 08/31/2025



Job No 13101/00018492.0000/01/I/25
 Report date 03 Sep 2025
 Installation Arroyo, Puerto Rico, PREPA Jobos Turbine Power Block

Shore tank **END OF THE MONTH INVENTORY / JOBOS**
Product **NO2**

Shore Tank Inventory Report

Survey date: 31-Aug-2025

Shore tank measurement		Totals	S-1	S-2
Open measurement				
Date/time of measurement		31 Aug 2025 23:40	31 Aug 2025 23:30	
Average Innage	FT/IN	02 09-3/16	18 05-9/16	
Average temp.	°F	85.6	85.6	90.1
T.O.V.	Barrels	228.79	228.79	6,447.93
Free Water				
Water	FT/IN	00 00-1/2	00 00-1/2	
Water	Barrels	0.88	0.88	19.71
Ambient temp.	°F	80.00	80.00	80.00
Tank shell temp.	°F	85.00	85.00	89.00
CTsh		1.00031	1.00031	1.00036
G.O.V.	Barrels	227.98	227.98	6,430.53
API 60°F		34.50	34.50	34.50
V.C.F.	6B	0.98817	0.98817	0.98608
G.S.V.	barrels 60°F	225.28	225.28	6,341.02
W.C.F.	MPMS 11.5.1.4.12	0.1330829859	0.1330829859	0.1330829859
W.C.F.	MPMS 11.5.1.4.15	0.1352185564	0.1352185564	0.1352185564
Long Tons		29.981	29.981	843.882
Metric Tons Air		30.462	30.462	857.424
Subtotals				
G.S.V.	barrels 60°F	6,566.30	225.28	6,341.02
Long Tons		873.863	29.981	843.882

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 08081 / JOBOS 08/31/2025



Job No 13101/00018492.0000/01/I/25
 Report date 03 Sep 2025
 Installation Arroyo, Puerto Rico, PREPA Jobos Turbine Power Block

Shore tank **END OF THE MONTH INVENTORY / JOBOS**
Product **NO2**

Survey date: 31-Aug-2025

Shore Tank Inventory Subtotals

Shore tank Subtotals	Totals	S-1	S-2
Gross Standard Volume			
Cu m 60°F	1,043.959	35.817	1,008.142
Barrels 60°F	6,566.30	225.28	6,341.02
US Gallons 60°F	275,784.60	9,461.76	266,322.84
Metric Tons Vac	889.004	30.500	858.504
Metric Tons Air	887.886	30.462	857.424
Long Tons Air	873.863	29.981	843.882
Short Tons Air	978.727	33.579	945.148
Pounds Air	1,957,454.00	67,158.00	1,890,296.00
Density 15°C		0.8520	0.8520
API 60°F		34.50	34.50
RD 60/60°		0.8524	0.8524
Total Calculated Volume			
Barrels 60°F	6,586.89	226.16	6,360.73
US Gallons 60°F	276,649.38	9,498.72	267,150.66



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08081 / JOBOS 08/31/2025



Job No 13101/00018492.0000/01/I/25
Report date 03 Sep 2025
Installation Arroyo, Puerto Rico, PREPA Jobos Turbine Power Block

Shore tank END OF THE MONTH INVENTORY / JOBOS
Product NO2

Survey date: 31 Aug 2025

Certificate of Quantity

The undersigned Independent Saybolt Surveyor herewith declares that the quantity of product measured amounts to:

	Gross	Net
Cubic meters 60°F	1,043.959	1,043.959
Barrels 60°F	6,566.30	6,566.30
US Gallons 60°F	275,784.60	275,784.60
Metric Tons vac	889.004	889.004
Metric Tons air	887.886	887.886
Long Tons	873.863	873.863
Short Tons	978.727	978.727
Pounds	1,957,454.00	1,957,454.00

These quantities have been determined by measurement of shore tanks.

B/L API 60°F	34.50
B/L Density 15°C	0.8520
B/L Density 20°C	0.8485
B/L RD 60/60°F	0.8524

Criteria used

US Barrels 60°F to Cu m 60°F	MPMS 11.5 - Annex D	0.158987304
US Barrels 60°F to US Gallons 60°F	MPMS 11.5 - Annex D	42
Metric Tons Air to Metric Tons Vac	MPMS 11.5.3 - 4.5	1.001259414
Barrels 60°F to Metric Tons Air	MPMS 11.5.1 - 4.15	0.1352185564
Barrels 60°F to Long Tons	MPMS 11.5.1 - 4.12	0.1330829859
Long Tons to Short Tons	MPMS 11.5 - Annex D	1.12

Remark

Net via S&W Volume %

Signed by: Saybolt representative
Name:
Rank: Saybolt Inspector

