



PREPA MAYAGUEZ INVENTORY
AS PER API CHAP: 3,7,8,12,17

DATE: AUGUST 31, 2025
RECORD NO.: GA025414

Page 1

PREPA SHIPMENT NO. MY-TANKINVENTORY-8-25

TANK	DATE	TIME	GAUGE	GROSS VOLUME	WATER GAUGE	VOLUME	LIQ. TEMP.	API	AMB. TEMP.
NO 2 DESTILLATE FUEL OIL									
D-1	08/31/25	2135	09' 06 7/8"	2,725,406.00	00' 03 3/4"	18,824.50	87.6	35.7	79.0
D-4	08/31/25	2335	13' 00 7/8"	409,113.00	00' 00"	0.00	83.6	34.1	79.0
NO 2 DESTILLATE FUEL OIL									
D-2 **	08/31/25	2205	27' 07"	198,600.00	00' 00 1/2"	300.00	88.3	35.4	79.0
D-3 **	0831/25	2355	35' 00 1/8"	281,133.65	00' 00"	0.00	88.5	35.6	79.0

09/04/25 @02:51pm Shore Figures confirmed with William Vega of PREPA Mayaguez Power Plant


ALTOL PETROLEUM PRODUCTS SERV. INC.
BRENDA REYES-MARTINEZ
INSPECTION SERVICES SUPERVISOR

228 Parque Industrial Sabanetas
Ponce, PR 00716-4401
Tel. 787-835-4242, Fax 787-835-2004



Calle Gregorio Ledesma, HN 55, Levittown
Toa Baja, P. R. 00949
Tel. 787-784-1112, Fax 787-784-1115

REPORT OF SHORE QUANTITY AS PER API CHAP: 3,7,8,12,17

PREPA SHIPMENT NO. MY-TANKINVENTORY-8-25

EVENT: MAYAGUEZ END OF MONTH INVENTORY GAUGE					RECORD NO.: GA025414					DATE: AUGUST 31, 2025				
PRODUCT: NO. 2 FUEL OIL					CONSIGNOR: PUERTO RICO ELECTRIC POWER AUTHORITY					PORT/TERMINAL: MAYAGUEZ, P.R.				
					CONSIGNEE: PUERTO RICO ELECTRIC POWER AUTHORITY					DESTINATION: MAYAGUEZ POWER PLANT				
TANK NO.			ULLAGE (FT/M)	TOTAL OBSERVED VOLUME (TOV GALLONS)	FREE WATER = (FW)		TEMP. CORR. CTSh	ROOF CORR. (+/-) (FRA)	GROSS OBSERVED VOLUME (GOV GALLONS)	API @ 60°F	AMB. TEMP. (°F/°C)	OBS. TEMP. (°F/°C)	V.C.F. TABLE (CTL)	GROSS STANDARD VOLUME (GSV GALLONS)
	DATE	TIME			INNAGE (FT/M)	VOLUME GALLONS								
D-1	08/31/25	2135	09' 06 7/8"	2,725,406.00	00' 03 3/4"	18,824.50	1.00033	0.00	2,707,474.67	35.7	79.0	87.6	0.98712	2,672,602.40
			27' 07"											
TOTAL DELIVERED THIS TANK														
D-4	08/31/25	2335	13' 00 7/8"	409,113.00	00' 00"	0.00	1.00029	0.00	409,231.64	34.1	79.0	83.6	0.98913	404,783.29
TOTAL DELIVERED THIS TANK														
TOTAL DELIVERED THIS TANK														
TOTAL DELIVERED THIS TANK														

TANKS NO.	D-1		D-4						TOTAL CARGO
NET BARRELS AT 60F	63,633.39		9,637.70						73,271.09
NET GALLONS AT 60F	2,672,602.40		404,783.29						3,077,385.69
POUNDS/GALS									
POUNDS	18,832,217.60		2,879,900.80						21,712,118.40
LONG TONS	8,407.24		1,285.67						9,692.91
METRIC TONS	8,542.15		1,306.29						9,848.44
CUBIC METERS	0.13212	0.13424	0.13340	0.13554					11,649.174
SHORE PIPELINES : COMMENCED: FINISHED :									
VESSEL TANKS :									

FORM AL04-08/95

09/04/25 @02:51pm Shore Figures confirmed with William Vega of PREPA Mayaguez Power Plant


ALTOL PETROLEUM PRODUCTS SERV. INC.
BRENDA REYES-MARTINEZ
INSPECTION SERVICES SUPERVISOR

228 Parque Industrial Sabanetas
Ponce, PR 00716-4401
Tel. 787-835-4242, Fax 787-835-2004



Calle Gregorio Ledesma, HN 55, Levittown
Toa Baja, P. R. 00949
Tel. 787-784-1112, Fax 787-784-1115

REPORT OF SHORE QUANTITY

AS PER API CHAP: 3,7,8,12,17

PREPA SHIPMENT NO. MY-TANKINVENTORY-8-25

EVENT: MAYAGUEZ END OF MONTH INVENTORY GAUGE					RECORD NO. GA025414					DATE: AUGUST 31, 2025				
PRODUCT : NO. 2 FUEL OIL					CONSIGNOR : PUERTO RICO ELECTRIC POWER AUTHORITY					PORT/TERMINAL : MAYAGUEZ, P.R.				
					CONSIGNEE : PUERTO RICO ELECTRIC POWER AUTHORITY					DESTINATION : MAYAGUEZ POWER PLANT				
TANK NO.	DATE	TIME	INNAGE ULLAGE (FT/M)	TOTAL OBSERVED VOLUME (TOV)	FREE WATER = (FW)		TEMP. CORR. SHELL CTSh	ROOF CORR. (+/-) (FRA)	GROSS OBSERVED VOLUME (GOV)	API @ 60°F	AMB. TEMP. (°F/°C)	OBS. TEMP. (°F/°C)	V.C.F. TABLE (CTL)	GROSS STANDARD VOLUME (GSV)
D-2 **	08/31/25	2205	27' 07"	198,600.00	00' 00 1/2"	300.00	1.00033	0.00	198,365.44	35.4	79.0	88.3	0.98682	195,750.98
TOTAL DELIVERED THIS TANK														
D-3 **	0831/25	2355	35' 00 1/8"	281,133.65	00' 00"	0.00	1.00033	0.00	281,226.42	35.6	79.0	88.5	0.98671	277,488.92
TOTAL DELIVERED THIS TANK														
TOTAL DELIVERED THIS TANK														
TOTAL DELIVERED THIS TANK														
** Tanks D-2 & D-3 do not have official strapping table. Quantities used by Prepa approximation														
TOTAL DELIVERED THIS TANK														

TANKS NO.	D-2 **	D-3 **				TOTAL CARGO
NET BARRELS AT 60F	4,660.74	6,606.88				11,267.62
NET GALLONS AT 60F	195,750.98	277,488.92				473,239.90
POUNDS/GALS						
POUNDS	1,381,856.00	2,470,025.60				3,851,881.60
LONG TONS	616.90	1,102.69				1,719.59
METRIC TONS	626.78	1,120.39				1,747.17
CUBIC METERS	0.13236 0.13448	0.16690 0.16958				1,791.409
SHORE PIPELINES :						

FORM AL04-08/95

09/04/25 @02:51pm Shore Figures confirmed with William Vega of PREPA Mayaguez Power Plant


ALTOL PETROLEUM PRODUCTS SERV. INC.
BRENDA REYES-MARTINEZ
INSPECTION SERVICES SUPERVISOR