

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08075 / PALO SECO / 08/31/2025

Digitally Generated by : Saybolt
Reason : Reporting
Location : 13101 Saybolt Puerto Rico - All Activity
Date : 2025.09.03 20:03:07 -04:00



Job No 13101/00018490.0000/01/I/25
Report date 02 Sep 2025
Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank **END OF THE MONTH INVENTORY / PALO SECO**
Product **NO6, NO2**

Survey date: 31-Aug-2025, 31-Aug-2025

Contents page

Saybolt LP (Puerto Rico) has performed a survey and the findings of the survey are reflected in the following reports:

Title	Number of Pages
Contents page	one
Shore Tank Inventory Report	three
Shore Tank Inventory Subtotals	three
Certificate of Quantity	two
Shore Tank Measurement Details	nine

This report consists of 18 pages.

A copy of this report and all field documents and related correspondence will be retained for a period of 10 years, unless local law requires otherwise

Handled by: Rafael Rodriguez

This report reflects only the findings at the time and place of the inspection and testing. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions.

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 08075 / PALO SECO / 08/31/2025



Job No 13101/00018490.0000/01/I/25
 Report date 02 Sep 2025
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO2

Shore Tank Inventory Report

Survey date: 31-Aug-2025

Shore tank measurement		Totals	D-2	D-1	D-3
Open measurement					
Date/time of measurement		31 Aug 2025 21:30	31 Aug 2025 23:21	31 Aug 2025 21:15	
Average Innage	FT/IN	06 01-5/8	12 10-0/0	08 09-1/2	
Average temp.	°F	88.6	87.0	86.6	
T.O.V.	Barrels	14,406.13	10,859.70	15,154.39	
Free Water		NIL	NIL		
Water	FT/IN				00 01-0/0
Water	Barrels				44.42
Ambient temp.	°F	82.00	80.00	82.00	
Tank shell temp.	°F	88.00	86.00	86.00	
CTsh		1.00035	1.00032	1.00032	
G.O.V.	Barrels	14,411.17	10,863.18	15,114.81	
API 60°F		36.30	36.40	35.60	
V.C.F.	6B	0.98659	0.98733	0.98760	
G.S.V.	barrels 60°F	14,217.92	10,725.54	14,927.39	
W.C.F.	MPMS 11.5.1.4.12	0.1316533840	0.1315748605	0.1322056805	
W.C.F.	MPMS 11.5.1.4.15	0.1337660138	0.1336862302	0.1343271730	
Long Tons		1,871.837	1,411.211	1,973.486	
Metric Tons Air		1,901.874	1,433.857	2,005.154	
Subtotals					
G.S.V.	barrels 60°F	39,870.85	14,217.92	10,725.54	14,927.39
Long Tons		5,256.534	1,871.837	1,411.211	1,973.486

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 08075 / PALO SECO / 08/31/2025



Job No 13101/00018490.0000/01/I/25
 Report date 02 Sep 2025
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Survey date: 31-Aug-2025

Shore Tank Inventory Report - 1

Shore tank measurement	Totals	R-1	R-4	R-2	S-1
Open measurement					
Date/time of measurement	31 Aug 2025 21:30	31 Aug 2025 22:00	31 Aug 2025 21:50	31 Aug 2025 23:34	
Average Innage FT/IN	04 03-5/8	07 07-0/0	03 11-0/0	08 03-1/8	
Average temp. °F	112.4	93.2	100.0	92.2	
T.O.V. Barrels	90,194.99	125,432.91	90,499.46	4,129.80	
Free Water	NIL	NIL	NIL	NIL	
Ambient temp. °F	82.00	82.00	82.00	80.00	
Tank shell temp. °F	109.00	92.00	98.00	91.00	
CTsh	1.00061	1.00040	1.00047	1.00038	
G.O.V. Barrels	90,250.01	125,483.08	90,541.99	4,131.37	
API 60°F	21.20	18.50	18.40	18.50	
V.C.F. 6B	0.97822	0.98655	0.98379	0.98695	
G.S.V. barrels 60°F	88,284.36	123,795.33	89,074.30	4,077.46	
W.C.F. MPMS 11.5.1.4.12	0.1446907124	0.1472985235	0.1473969132	0.1472985235	
W.C.F. MPMS 11.5.1.4.15	0.1470125511	0.1496622094	0.1497621780	0.1496622094	
Long Tons	12,773.927	18,234.869	13,129.277	600.604	
Metric Tons Air	12,978.909	18,527.483	13,339.961	610.242	
Subtotals					
G.S.V. barrels 60°F	321,326.51	88,284.36	123,795.33	89,074.30	4,077.46
Long Tons	47,109.456	12,773.927	18,234.869	13,129.277	600.604

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 08075 / PALO SECO / 08/31/2025



Job No 13101/00018490.0000/01/1/25
 Report date 02 Sep 2025
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Survey date: 31-Aug-2025

Shore Tank Inventory Report - 2

Shore tank measurement		S-3	S-4
Open measurement			
Date/time of measurement		31 Aug 2025 23:45	31 Aug 2025 23:55
Average Innage	FT/IN	09 00-11/16	08 09-1/16
Average temp.	°F	91.7	90.0
T.O.V.	Barrels	8,182.53	8,110.26
Free Water		NIL	NIL
Ambient temp.	°F	80.00	80.00
Tank shell temp.	°F	90.00	89.00
CTsh		1.00037	1.00036
G.O.V.	Barrels	8,185.56	8,113.18
API 60°F		18.50	18.50
V.C.F.	6B	0.98716	0.98785
G.S.V.	barrels 60°F	8,080.46	8,014.60
W.C.F.	MPMS 11.5.1.4.12	0.1472985235	0.1472985235
W.C.F.	MPMS 11.5.1.4.15	0.1496622094	0.1496622094
Long Tons		1,190.240	1,180.539
Metric Tons Air		1,209.339	1,199.483
Subtotals			
G.S.V.	barrels 60°F	8,080.46	8,014.60
Long Tons		1,190.240	1,180.539

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 08075 / PALO SECO / 08/31/2025



Job No 13101/00018490.0000/01/1/25
 Report date 02 Sep 2025
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO2

Survey date: 31-Aug-2025

Shore Tank Inventory Subtotals

Shore tank Subtotals	Totals	D-2	D-1	D-3
Gross Standard Volume				
Cu m 60°F	6,338.959	2,260.469	1,705.225	2,373.265
Barrels 60°F	39,870.85	14,217.92	10,725.54	14,927.39
US Gallons 60°F	1,674,575.70	597,152.64	450,472.68	626,950.38
Metric Tons Vac	5,347.682	1,904.298	1,435.686	2,007.698
Metric Tons Air	5,340.885	1,901.874	1,433.857	2,005.154
Long Tons Air	5,256.534	1,871.837	1,411.211	1,973.486
Short Tons Air	5,887.317	2,096.457	1,580.556	2,210.304
Pounds Air	11,774,634.00	4,192,914.00	3,161,112.00	4,420,608.00
Density 15°C		0.8428	0.8423	0.8464
API 60°F		36.30	36.40	35.60
RD 60/60°		0.8433	0.8428	0.8468
Total Calculated Volume				
Barrels 60°F	39,915.27	14,217.92	10,725.54	14,971.81
US Gallons 60°F	1,676,441.34	597,152.64	450,472.68	628,816.02



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08075 / PALO SECO / 08/31/2025



Job No 13101/00018490.0000/01/I/25
Report date 02 Sep 2025
Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Survey date: 31-Aug-2025

Shore Tank Inventory Subtotals - 1

Shore tank Subtotals	Totals	R-1	R-4	R-2	S-1
Gross Standard Volume					
Cu m 60°F	51,086.836	14,036.092	19,681.886	14,161.683	648.264
Barrels 60°F	321,326.51	88,284.36	123,795.33	89,074.30	4,077.46
US Gallons 60°F	13,495,713.42	3,707,943.12	5,199,403.86	3,741,120.60	171,253.32
Metric Tons Vac	47,919.483	12,993.789	18,548.299	13,354.938	610.928
Metric Tons Air	47,865.417	12,978.909	18,527.483	13,339.961	610.242
Long Tons Air	47,109.456	12,773.927	18,234.869	13,129.277	600.604
Short Tons Air	52,762.590	14,306.798	20,423.053	14,704.790	672.676
Pounds Air	105,525,180.00	28,613,596.00	40,846,106.00	29,409,580.00	1,345,352.00
Density 15°C		0.9261	0.9428	0.9434	0.9428
API 60°F		21.20	18.50	18.40	18.50
RD 60/60°		0.9267	0.9433	0.9440	0.9433
Total Calculated Volume					
Barrels 60°F	321,326.51	88,284.36	123,795.33	89,074.30	4,077.46
US Gallons 60°F	13,495,713.42	3,707,943.12	5,199,403.86	3,741,120.60	171,253.32



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 08075 / PALO SECO / 08/31/2025



Job No 13101/00018490.0000/01/I/25
 Report date 02 Sep 2025
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Survey date: 31-Aug-2025

Shore Tank Inventory Subtotals - 2

Shore tank Subtotals	S-3	S-4
----------------------	-----	-----

Gross Standard Volume

Cu m 60°F	1,284.691	1,274.220
Barrels 60°F	8,080.46	8,014.60
US Gallons 60°F	339,379.32	336,613.20
Metric Tons Vac	1,210.698	1,200.831
Metric Tons Air	1,209.339	1,199.483
Long Tons Air	1,190.240	1,180.539
Short Tons Air	1,333.069	1,322.204
Pounds Air	2,666,138.00	2,644,408.00
Density 15°C	0.9428	0.9428
API 60°F	18.50	18.50
RD 60/60°	0.9433	0.9433

Total Calculated Volume

Barrels 60°F	8,080.46	8,014.60
US Gallons 60°F	339,379.32	336,613.20



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08075 / PALO SECO / 08/31/2025



Job No 13101/00018490.0000/01/1/25
Report date 02 Sep 2025
Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO2

Survey date: 31 Aug 2025

Certificate of Quantity

The undersigned Independent Saybolt Surveyor herewith declares that the quantity of product measured amounts to:

	Gross	Net
Cubic meters 60°F	6,338.959	6,338.959
Barrels 60°F	39,870.85	39,870.85
US Gallons 60°F	1,674,575.70	1,674,575.70
Metric Tons vac	5,347.682	5,347.682
Metric Tons air	5,340.885	5,340.885
Long Tons	5,256.534	5,256.534
Short Tons	5,887.317	5,887.317
Pounds	11,774,634.00	11,774,634.00

These quantities have been determined by measurement of shore tanks.

B/L API 60°F	36.06
B/L Density 15°C	0.8440
B/L Density 20°C	0.8405
B/L RD 60/60°F	0.8445

Criteria used

US Barrels 60°F to Cu m 60°F	MPMS 11.5 - Annex D	0.158987304
US Barrels 60°F to US Gallons 60°F	MPMS 11.5 - Annex D	42
Metric Tons Air to Metric Tons Vac	MPMS 11.5.3 - 4.5	1.001272791
Barrels 60°F to Metric Tons Air	MPMS 11.5.1 - 4.15	0.1339578831
Barrels 60°F to Long Tons	MPMS 11.5.1 - 4.12	0.131842223
Long Tons to Short Tons	MPMS 11.5 - Annex D	1.12

Remark

Net via S&W Volume %

Signed by: Saybolt representative
Name:
Rank: Saybolt Inspector



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08075 / PALO SECO / 08/31/2025



Job No 13101/00018490.0000/01/1/25
Report date 02 Sep 2025
Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Survey date: 31 Aug 2025

Certificate of Quantity

The undersigned Independent Saybolt Surveyor herewith declares that the quantity of product measured amounts to:

	Gross	Net
Cubic meters 60°F	51,086.836	51,086.836
Barrels 60°F	321,326.51	321,326.51
US Gallons 60°F	13,495,713.42	13,495,713.42
Metric Tons vac	47,919.483	47,919.483
Metric Tons air	47,865.417	47,865.417
Long Tons	47,109.456	47,109.456
Short Tons	52,762.590	52,762.590
Pounds	105,525,180.00	105,525,180.00

These quantities have been determined by measurement of shore tanks.

B/L API 60°F	19.20
B/L Density 15°C	0.9384
B/L Density 20°C	0.9350
B/L RD 60/60°F	0.9390

Criteria used

US Barrels 60°F to Cu m 60°F	MPMS 11.5 - Annex D	0.158987304
US Barrels 60°F to US Gallons 60°F	MPMS 11.5 - Annex D	42
Metric Tons Air to Metric Tons Vac	MPMS 11.5.3 - 4.5	1.00112949
Barrels 60°F to Metric Tons Air	MPMS 11.5.1 - 4.15	0.1489661442
Barrels 60°F to Long Tons	MPMS 11.5.1 - 4.12	0.1466134515
Long Tons to Short Tons	MPMS 11.5 - Annex D	1.12

Remark

Net via S&W Volume %

Signed by: Saybolt representative
Name:
Rank: Saybolt Inspector



PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08075 / PALO SECO / 08/31/2025



Job No 13101/00018490.0000/01/I/25
Report date 02 Sep 2025
Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO2

Survey date: 31-Aug-2025

Shore Tank Measurement Details

Shore tank D-1

Measurement data (Innage)		Open	Close
Average	FT/IN	12 10-0/0	
Temperature			
Average temp.	°F	87.0	
Measurement Equipment Data			
		Open	
Water measurement used		Paste	
Water paste used		k/k	
Gauging equipment type		Saybolt Equipment	
Gauging Equipment used		Manual Tape	
Gauging equipment number		52758	
Temperature equipment type		Saybolt Equipment	
Temperature Equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-03838	
Inspector Equipment used for verification?		Yes	
Inspector name		J. Flores	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08075 / PALO SECO / 08/31/2025



Job No 13101/00018490.0000/01/I/25
Report date 02 Sep 2025
Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO2

Survey date: 31-Aug-2025

Shore Tank Measurement Details

Shore tank D-2

Measurement data (Innage)		Open	Close
Average	FT/IN	06 01-5/8	
Temperature			
Average temp.	°F	88.6	
Measurement Equipment Data			
		Open	
Water measurement used		Paste	
Water paste used		k/k	
Gauging equipment type		Saybolt Equipment	
Gauging Equipment used		Manual Tape	
Gauging equipment number		52758	
Temperature equipment type		Saybolt Equipment	
Temperature Equipment used		Glass Thermometer	
Temperature equipment number		TP9-03838	
Inspector Equipment used for verification?		Yes	
Inspector name		J. Flores	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08075 / PALO SECO / 08/31/2025



Job No 13101/00018490.0000/01/I/25
Report date 02 Sep 2025
Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO2

Survey date: 31-Aug-2025

Shore Tank Measurement Details

Shore tank D-3

Measurement data (Innage)		Open	Close
Average	FT/IN	08 09-1/2	
Temperature			
Average temp.	°F	86.6	
Measurement Equipment Data			
		Open	
Water measurement used		Paste	
Water paste used		k/k	
Gauging equipment type		Saybolt Equipment	
Gauging Equipment used		Manual Tape	
Gauging equipment number		52584	
Temperature equipment type		Saybolt Equipment	
Temperature Equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-02532	
Inspector Equipment used for verification?		Yes	
Inspector name		H. Lopez	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08075 / PALO SECO / 08/31/2025



Job No 13101/00018490.0000/01/I/25
Report date 02 Sep 2025
Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Survey date: 31-Aug-2025

Shore Tank Measurement Details

Shore tank R-1

Measurement data (Innage)		Open	Close
Average	FT/IN	04 03-5/8	
Temperature			
Average temp.	°F	112.4	
Measurement Equipment Data			
		Open	
Water measurement used		Paste	
Water paste used		k/k	
Gauging equipment type		Saybolt Equipment	
Gauging Equipment used		Manual Tape	
Gauging equipment number		52758	
Temperature equipment type		Saybolt Equipment	
Temperature Equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-03838	
Inspector Equipment used for verification?		Yes	
Inspector name		J. Flores	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08075 / PALO SECO / 08/31/2025



Job No 13101/00018490.0000/01/I/25
Report date 02 Sep 2025
Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Survey date: 31-Aug-2025

Shore Tank Measurement Details

Shore tank R-2

Measurement data (Innage)		Open	Close
Average	FT/IN	03 11-0/0	
Temperature			
Average temp.	°F	100.0	
Measurement Equipment Data			
		Open	
Water measurement used		Paste	
Water paste used		k/k	
Gauging equipment type		Saybolt Equipment	
Gauging Equipment used		Manual Tape	
Gauging equipment number		52758	
Temperature equipment type		Saybolt Equipment	
Temperature Equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-03838	
Inspector Equipment used for verification?		Yes	
Inspector name		J. Flores	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08075 / PALO SECO / 08/31/2025



Job No 13101/00018490.0000/01/I/25
Report date 02 Sep 2025
Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Survey date: 31-Aug-2025

Shore Tank Measurement Details

Shore tank R-4

Measurement data (Innage)		Open	Close
Average	FT/IN	07 07-0/0	
Temperature			
Average temp.	°F	93.2	
Measurement Equipment Data			
		Open	
Water measurement used		Paste	
Water paste used		k/k	
Gauging equipment type		Saybolt Equipment	
Gauging Equipment used		Manual Tape	
Gauging equipment number		52584	
Temperature equipment type		Saybolt Equipment	
Temperature Equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-02532	
Inspector Equipment used for verification?		Yes	
Inspector name		H. Lopez	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08075 / PALO SECO / 08/31/2025



Job No 13101/00018490.0000/01/I/25
Report date 02 Sep 2025
Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Survey date: 31-Aug-2025

Shore Tank Measurement Details

Shore tank S-1

Measurement data (Innage)		Open	Close
Average	FT/IN	08 03-1/8	
Temperature			
Average temp.	°F	92.2	
Measurement Equipment Data			
		Open	
Water measurement used		Paste	
Water paste used		k/k	
Gauging equipment type		Saybolt Equipment	
Gauging Equipment used		Manual Tape	
Gauging equipment number		52758	
Temperature equipment type		Saybolt Equipment	
Temperature Equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-03838	
Inspector Equipment used for verification?		Yes	
Inspector name		J. Flores	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08075 / PALO SECO / 08/31/2025



Job No 13101/00018490.0000/01/I/25
Report date 02 Sep 2025
Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Survey date: 31-Aug-2025

Shore Tank Measurement Details

Shore tank S-3

Measurement data (Innage)		Open	Close
Average	FT/IN	09 00-11/16	
Temperature			
Average temp.	°F	91.7	
Measurement Equipment Data			
		Open	
Water measurement used		Paste	
Water paste used		k/k	
Gauging equipment type		Saybolt Equipment	
Gauging Equipment used		Manual Tape	
Gauging equipment number		52758	
Temperature equipment type		Saybolt Equipment	
Temperature Equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-03838	
Inspector Equipment used for verification?		Yes	
Inspector name		J. Flores	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
08075 / PALO SECO / 08/31/2025



Job No 13101/00018490.0000/01/I/25
Report date 02 Sep 2025
Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Survey date: 31-Aug-2025

Shore Tank Measurement Details

Shore tank S-4

Measurement data (Innage)		Open	Close
Average	FT/IN	08 09-1/16	
Temperature			
Average temp.	°F	90.0	
Measurement Equipment Data			
		Open	
Water measurement used		Paste	
Water paste used		k/k	
Gauging equipment type		Saybolt Equipment	
Gauging Equipment used		Manual Tape	
Gauging equipment number		52758	
Temperature equipment type		Saybolt Equipment	
Temperature Equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-03838	
Inspector Equipment used for verification?		Yes	
Inspector name		J. Flores	