



Field Inspection Report

Cargo Operation: Inventory

Vessel(s)

Inventory

Product(s)

Diesel Fuel (ULSD)

Client(s)

Autoridad De Energia Electrica De Puerto Rico

Reference #

YB-TANKINVENTORY-11-25

Location(s)

Yabucoa | GeneraPR - Yabucoa

All measurements contained in this report were performed according to the API manual of petroleum measurement standards.

Chapter 3 Tank Gauging; Chapter 7 Temperature Determination; Chapter 8 Sampling; Chapter 12 Calculation of Petroleum Quantities; Chapter 17 Marine Measurement

All Bureau Veritas measurement devices and methods used for quantity and quality determination meet pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule).

All Operations to be carried out in accordance with Bureau Veritas Commodities Division General Conditions of Service. An electronic version can also be viewed on our company website: <https://commodities.bureauveritas.com/general-conditions-of-service>

Victor Reyes

Bureau Veritas Commodities and Trade, Inc

Table of Contents

Shore Tanks Measurements - Diesel Fuel (ULSD)

1

V. Ruy

Job #: PRPUE-25-00471-1

Date: 30-Nov-2025

Location(s): Yabucoa - GeneraPR - Yabucoa

Vessel(s): Inventory

Product(s): Diesel Fuel (ULSD)

Client(s): Autoridad De Energia Electrica De Puerto Rico-YB-TANKINVENTORY-11-25


**BUREAU
VERITAS**

S-1		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
			Open	30-Nov-2025	19:50	N/A	76.0	1.00027	1.67		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels			
Open	36-3 1/8	6,194.24	0-0	0.00	34.5	83.3	6,195.91	0.98924	6,129.24			
Close												
Difference		6,194.24		0.00			6,195.91		6,129.24			
Adjustments to GSV										6,129.24		
S-2		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
			Open	30-Nov-2025	20:20	N/A	76.0	1.00029	2.46		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels			
Open	24-4 7/8	8,511.19	0-0 7/8	13.83	34.5	83.7	8,499.82	0.98905	8,406.75			
Close												
Difference		8,511.19		13.83			8,499.82		8,406.75			
Adjustments to GSV										8,406.75		

Shore Summary						
API-60°F	Adjustments (Bbls)			Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV	To Water			
34.5						Kolor Kut
Shore Delivered	Shore Delivered	Total Calculated	Gross Standard			
	Cubic Meters 15°C	2,312.173	2,309.976	Density		
	Cubic Meters 60°F	2,313.237	2,311.038	API 60°F		
	Liters 60°F	2,313.237	2,311.038	34.5		
	Barrels 60°F	14,549.82	14,535.99	Table 8 Lbs/Gal (In Air)		
	Gallons 60°F	611,092.44	610,511.58	7.097759247		
	Kilograms	1,967.406	1,965.536	Table 11 LT/Bbl (In Air)		
	Pounds	4,337.387	4,333.264	0.1330829859		
	Short Tons	2,168.694	2,166.632	Table 13 MT/Bbl (In Air)		
	Long Tons	1,936.333	1,934.493	0.1352185564		
	MT (In Air)	1,967.406	1,965.536	Table 13 MT/Bbl (In Vac)		
	MT (In Vac)	1,969.885	1,968.012	0.1353889486		
	Free Water	13.83				

Date/Time

Date/Time

Date/Time

30-Nov-2025