

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
AG-TANKINV-2-28-26

Digitally Generated by : Saybolt
Reason : Reporting
Location : 13101 Saybolt Puerto Rico - All Activity
Date : 2026.03.02 14:11:19 -04:00



Job No 13101/00018702.0000/01/1/26
Report date 02 Mar 2026
Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO6, NO2

Survey date: 28-Feb-2026, 28-Feb-2026

Contents page

Saybolt LP (Puerto Rico) has performed a survey and the findings of the survey are reflected in the following reports:

Title	Number of Pages
Contents page	one
Shore Tank Inventory Report	four
Shore Tank Measurement Details	thirteen
Shore Tank Inventory Subtotals	four
Certificate of Quantity	two

This report consists of 24 pages.

A copy of this report and all field documents and related correspondence will be retained for a period of 10 years, unless local law requires otherwise

Handled by: Rafael Rodriguez

This report reflects only the findings at the time and place of the inspection and testing. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions.

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

Handled by: Rafael Rodriguez
SAYBOLT LLC, STREET 127 KM 11.7 MAGAS ARRIBA, 00656 GUAYANILLA, PUERTO RICO
Tel. 787-835-4784 FAX 787-835-4788
Website: WWW.CORELAB.COM E-mail: EDWIN.HERNANDEZ@CORELAB.COM
All our activities are carried out under Saybolt's terms and conditions, available at www.corelab.com/saybolt/terms-conditions
SAIL4 CNT V4.3.0.0 2026/01/27

Date: 02 Mar 2026 14:09
Page 1 of 24

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO2

Survey date: 28-Feb-2026

Shore Tank Inventory Report - 1

Shore tank measurement		Totals	R-6	CYCLO 2	CYCLO 3	CYCLO 4
Open measurement						
Date/time of measurement		28 Feb 2026 20:50	28 Feb 2026 22:00	28 Feb 2026 22:15	28 Feb 2026 22:30	
Average Innage	FT/IN	40 02-1/8	33 0-3/4	00 0-0/0	17 06-1/4	
Average temp.	°F	83.5	85.4	60.0	89.4	
T.O.V.	Barrels	268,317.45	22,846.83		12,007.38	
Free Water		NIL		NIL		
Water	FT/IN		00 08-1/2	00 0-3/8		
Water	Barrels		649.31	21.43		
Ambient temp.	°F	75.00	75.00	75.00	75.00	
Tank shell temp.	°F	82.00	84.00		88.00	
CTsh		1.00027	1.00030		1.00035	
G.O.V.	Barrels	268,389.90	22,204.18		11,990.15	
API 60°F		36.60	36.60	32.00	33.30	
V.C.F.	6B	0.98896	0.98807		0.98654	
G.S.V.	barrels 60°F	265,426.88	21,939.28		11,828.76	
W.C.F.	MPMS 11.5.1.4.12	0.1314180936	0.1314180936		0.1340534034	
W.C.F.	MPMS 11.5.1.4.15	0.1335269477	0.1335269477		0.1362045461	
Long Tons		34,881.895	2,883.218		1,585.686	
Metric Tons Air		35,441.641	2,929.485		1,611.131	
Subtotals						
G.S.V.	barrels 60°F	383,128.86	265,426.88	21,939.28	11,828.76	
Long Tons		50,409.127	34,881.895	2,883.218	1,585.686	

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO2

Survey date: 28-Feb-2026

Shore Tank Inventory Report - 2

Shore tank measurement		CYCLO 1	R-2	R-1 (2)	T-1
Open measurement					
Date/time of measurement		28 Mar 2026 23:55	28 Mar 2026 21:10	28 Mar 2026 20:50	28 Mar 2026 20:10
Average Innage	FT/IN	23 01-3/8	32 08-0/0	27 06-1/2	29 04-1/4
Average temp.	°F	84.9	80.2	79.9	82.7
T.O.V.	Barrels	15,820.19	29,087.92	24,536.89	10,312.45
Free Water					NIL
Water	FT/IN	00 07-0/0	00 02-5/8	00 02-7/8	
Water	Barrels	360.05	66.44	91.42	
Ambient temp.	°F	75.00	75.00	75.00	75.00
Tank shell temp.	°F	84.00	80.00	79.00	82.00
CTsh		1.00030	1.00025	1.00024	1.00027
G.O.V.	Barrels	15,464.78	29,028.74	24,451.34	10,277.56
API 60°F		36.60	35.20	35.50	38.36
V.C.F.	6B	0.98830	0.99062	0.99074	0.98914
G.S.V.	barrels 60°F	15,283.84	28,756.45	24,224.92	10,165.95
W.C.F.	MPMS 11.5.1.4.12	0.1314180936	0.1325233610	0.1322849580	0.1300544638
W.C.F.	MPMS 11.5.1.4.15	0.1335269477	0.1346499513	0.1344077226	0.1321414359
Long Tons		2,008.573	3,810.901	3,204.593	1,322.127
Metric Tons Air		2,040.805	3,872.055	3,256.016	1,343.343
Subtotals					
G.S.V.	barrels 60°F	15,283.84	28,756.45	24,224.92	10,165.95
Long Tons		2,008.573	3,810.901	3,204.593	1,322.127

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO2

Shore Tank Inventory Report - 3

Survey date: 28-Feb-2026

Shore tank measurement T-2

Open measurement

Date/time of measurement		28 Mar 2026 20:25
Average Innage	FT/IN	32 11-3/8
Average temp.	°F	82.2
T.O.V.	Barrels	5,653.81
Free Water		
Water	FT/IN	00 07-0/0
Water	Barrels	92.79
Ambient temp.	°F	75.00
Tank shell temp.	°F	81.00
CTsh		1.00026
G.O.V.	Barrels	5,562.47
API 60°F		39.20
V.C.F.	6B	0.98927
G.S.V.	barrels 60°F	5,502.78
W.C.F.	MPMS 11.5.1.4.12	0.1294135534
W.C.F.	MPMS 11.5.1.4.15	0.1314902409
Long Tons		712.134
Metric Tons Air		723.562

Subtotals

G.S.V.	barrels 60°F	5,502.78
Long Tons		712.134

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO6

Shore Tank Inventory Report

Survey date: 28-Feb-2026

Shore tank measurement		Totals	R-1	R-3	S-1	S-2
Open measurement						
Date/time of measurement		28 Feb 2026 21:30	28 Feb 2026 21:15	28 Mar 2026 19:40	28 Mar 2026 18:45	
Average Innage	FT/IN	30 07-5/16	41 02-3/4	09 10-3/4	09 11-0/0	
Average temp.	°F	90.6	97.8	84.4	86.4	
T.O.V.	Barrels	203,742.30	275,428.35	27,529.15	27,479.85	
Free Water		NIL	NIL	NIL	NIL	
Ambient temp.	°F	75.00	75.00	75.00	75.00	
Tank shell temp.	°F	89.00	95.00	83.00	85.00	
CTsh		1.00035	1.00043	1.00029	1.00031	
G.O.V.	Barrels	203,813.61	275,546.78	27,537.13	27,488.37	
API 60°F		18.70	17.80	18.70	18.70	
V.C.F.	6B	0.98758	0.98477	0.99010	0.98929	
G.S.V.	barrels 60°F	201,282.24	271,350.20	27,264.51	27,193.97	
W.C.F.	MPMS 11.5.1.4.12	0.1471021371	0.1479900194	0.1471021371	0.1471021371	
W.C.F.	MPMS 11.5.1.4.15	0.1494626716	0.1503648017	0.1494626716	0.1494626716	
Long Tons		29,609.048	40,157.121	4,010.668	4,000.291	
Metric Tons Air		30,084.181	40,801.519	4,075.027	4,064.483	
Subtotals						
G.S.V.	barrels 60°F	527,090.92	201,282.24	271,350.20	27,264.51	27,193.97
Long Tons		77,777.128	29,609.048	40,157.121	4,010.668	4,000.291

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO2

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank CYCLO 1

Measurement data (Innage)		Open	Close
Average	FT/IN	23 01-3/8	
Temperature			
Average temp.	°F	84.9	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53408	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		9-01699	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO2

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank CYCLO 2

Measurement data (Innage)		Open	Close
Average	FT/IN	33 0-3/4	
Temperature			
Average temp.	°F	85.4	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53408	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		9-01699	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO2

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank CYCLO 3

Measurement data (Innage)		Open	Close
Average	FT/IN	00 0-0/0	
Temperature			
Average temp.	°F	60.0	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53408	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		9-01699	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO2

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank CYCLO 4

Measurement data (Innage)		Open	Close
Average	FT/IN	17 06-1/4	
Temperature			
Average temp.	°F	89.4	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53408	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		9-01699	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO2

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank R-1 (2)

Measurement data (Innage)		Open	Close
Average	FT/IN	27 06-1/2	
Temperature			
Average temp.	°F	79.9	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53408	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		9-01699	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO2

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank R-2

Measurement data (Innage)		Open	Close
Average	FT/IN	32 08-0/0	
Temperature			
Average temp.	°F	80.2	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53408	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		9-01699	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO2

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank R-6

Measurement data (Innage)		Open	Close
Average	FT/IN	40 02-1/8	
Temperature			
Average temp.	°F	83.5	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53408	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		9-01699	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO2

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank T-1

Measurement data (Innage)		Open	Close
Average	FT/IN	29 04-1/4	
Temperature			
Average temp.	°F	82.7	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53408	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		9-01699	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO2

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank T-2

Measurement data (Innage)		Open	Close
Average	FT/IN	32 11-3/8	
Temperature			
Average temp.	°F	82.2	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53408	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		9-01699	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO6

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank R-1

Measurement data (Innage)		Open	Close
Average	FT/IN	30 07-5/16	
Temperature			
Average temp.	°F	90.6	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53408	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		9-01699	
Inspector equipment used for verification?		Yes	
Inspector name		DWIN HERNANDEZ	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO6

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank R-3

Measurement data (Innage)		Open	Close
Average	FT/IN	41 02-3/4	
Temperature			
Average temp.	°F	97.8	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53408	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		9-01699	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO6

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank S-1

Measurement data (Innage)		Open	Close
Average	FT/IN	09 10-3/4	
Temperature			
Average temp.	°F	84.4	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53408	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		9-01699	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO6

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank S-2

Measurement data (Innage)		Open	Close
Average	FT/IN	09 11-0/0	
Temperature			
Average temp.	°F	86.4	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53408	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		9-01699	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO2

Survey date: 28-Feb-2026

Shore Tank Inventory Subtotals - 1

Shore tank Subtotals	Totals	R-6	CYCLO 2	CYCLO 3	CYCLO 4
Gross Standard Volume					
Cu m 60°F	60,912.625	42,199.504	3,488.067		1,880.623
Barrels 60°F	383,128.86	265,426.88	21,939.28		11,828.76
US Gallons 60°F	16,091,412.12	11,147,928.96	921,449.76		496,807.92
Metric Tons Vac	51,283.375	35,486.911	2,933.227		1,613.144
Metric Tons Air	51,218.038	35,441.641	2,929.485		1,611.131
Long Tons Air	50,409.127	34,881.895	2,883.218		1,585.686
Short Tons Air	56,458.221	39,067.722	3,229.204		1,775.968
Pounds Air	112,916,442.00	78,135,444.00	6,458,408.00		3,551,936.00
Density 15°C		0.8413	0.8413		0.8582
API 60°F		36.60	36.60		33.30
RD 60/60°F		0.8418	0.8418		0.8586
Total Calculated Volume					
Barrels 60°F	384,410.30	265,426.88	22,588.59		11,850.19
US Gallons 60°F	16,145,232.60	11,147,928.96	948,720.78		497,707.98

All manual gauges, temp, and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp, based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO2

Survey date: 28-Feb-2026

Shore Tank Inventory Subtotals - 2

Shore tank Subtotals	CYCLO 1	R-2	R-1 (2)	T-1
Gross Standard Volume				
Cu m 60°F	2,429.937	4,571.910	3,851.455	1,616.257
Barrels 60°F	15,283.84	28,756.45	24,224.92	10,165.95
US Gallons 60°F	641,921.28	1,207,770.90	1,017,446.64	426,969.90
Metric Tons Vac	2,043.412	3,876.955	3,260.145	1,345.079
Metric Tons Air	2,040.805	3,872.055	3,256.016	1,343.343
Long Tons Air	2,008.573	3,810.901	3,204.593	1,322.127
Short Tons Air	2,249.602	4,268.209	3,589.144	1,480.782
Pounds Air	4,499,204.00	8,536,418.00	7,178,288.00	2,961,564.00
Density 15°C	0.8413	0.8484	0.8469	0.8326
API 60°F	36.60	35.20	35.50	38.36
RD 60/60°F	0.8418	0.8488	0.8473	0.8330
Total Calculated Volume				
Barrels 60°F	15,643.89	28,822.89	24,316.34	10,165.95
US Gallons 60°F	657,043.38	1,210,561.38	1,021,286.28	426,969.90

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO2

Survey date: 28-Feb-2026

Shore Tank Inventory Subtotals - 3

Shore tank Subtotals T-2

Gross Standard Volume

Cu m 60°F	874.872
Barrels 60°F	5,502.78
US Gallons 60°F	231,116.76
Metric Tons Vac	724.502
Metric Tons Air	723.562
Long Tons Air	712.134
Short Tons Air	797.590
Pounds Air	1,595,180.00
Density 15°C	0.8285
API 60°F	39.20
RD 60/60°F	0.8289

Total Calculated Volume

Barrels 60°F	5,595.57
US Gallons 60°F	235,013.94

All manual gauges, temp, and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol corr. for temp, based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO6

Survey date: 28-Feb-2026

Shore Tank Inventory Subtotals

Shore tank Subtotals	Totals	R-1	R-3	S-1	S-2
Gross Standard Volume					
Cu m 60°F	83,800.765	32,001.321	43,141.237	4,334.711	4,323.496
Barrels 60°F	527,090.92	201,282.24	271,350.20	27,264.51	27,193.97
US Gallons 60°F	22,137,818.64	8,453,854.08	11,396,708.40	1,145,109.42	1,142,146.74
Metric Tons Vac	79,113.819	30,118.033	40,847.118	4,079.612	4,069.056
Metric Tons Air	79,025.210	30,084.181	40,801.519	4,075.027	4,064.483
Long Tons Air	77,777.128	29,609.048	40,157.121	4,010.668	4,000.291
Short Tons Air	87,110.384	33,162.134	44,975.976	4,491.948	4,480.326
Pounds Air	174,220,768.00	66,324,268.00	89,951,952.00	8,983,896.00	8,960,652.00
Density 15°C		0.9415	0.9472	0.9415	0.9415
API 60°F		18.70	17.80	18.70	18.70
RD 60/60°F		0.9421	0.9478	0.9421	0.9421
Total Calculated Volume					
Barrels 60°F	527,090.92	201,282.24	271,350.20	27,264.51	27,193.97
US Gallons 60°F	22,137,818.64	8,453,854.08	11,396,708.40	1,145,109.42	1,142,146.74

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO6

Survey date: 28 Feb 2026

Certificate of Quantity

The undersigned Independent Saybolt Surveyor herewith declares that the quantity of product measured amounts to:

	Gross	Net
Cubic meters 60°F	83,800.765	83,800.765
Barrels 60°F	527,090.92	527,090.92
US Gallons 60°F	22,137,818.64	22,137,818.64
Metric Tons vac	79,113.819	79,113.819
Metric Tons air	79,025.210	79,025.210
Long Tons	77,777.128	77,777.128
Short Tons	87,110.384	87,110.384
Pounds	174,220,768.00	174,220,768.00

These quantities have been determined by Shore tank measurements taken by Manual measurements.

B/L API 60°F	18.24
B/L Density 15°C	0.9444
B/L Density 20°C	0.9410
B/L RD 60/60°F	0.9450

Criteria used

US Barrels 60°F to Cu m 60°F	MPMS 11.5 - Annex D	0.158987304
US Barrels 60°F to US Gallons 60°F	MPMS 11.5 - Annex D	42
Metric Tons Air to Metric Tons Vac	MPMS 11.5.3 - 4.5	1.001121351
Barrels 60°F to Metric Tons Air	MPMS 11.5.1 - 4.15	0.1499224054
Barrels 60°F to Long Tons	MPMS 11.5.1 - 4.12	0.1475546101
Long Tons to Short Tons	MPMS 11.5 - Annex D	1.12

Remark

Net via S&W Volume %

Signed by: Saybolt representative
 Name:
 Rank: Saybolt Inspector

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

Handled by: Rafael Rodriguez
 SAYBOLT LLC, STREET 127 KM 11.7 MAGAS ARRIBA, 00656 GUAYANILLA, PUERTO RICO
 Tel. 787-835-4784 FAX 787-835-4788
 Website: WWW.CORELAB.COM E-mail: EDWIN.HERNANDEZ@CORELAB.COM
 All our activities are carried out under Saybolt's terms and conditions, available at www.corelab.com/saybolt/terms-conditions
 SAIL4 COO V4.1.9.14 20240227

Date: 02 Mar 2026 14:09
 Page 23 of 24

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 AG-TANKINV-2-28-26



Job No 13101/00018702.0000/01/1/26
 Report date 02 Mar 2026
 Installation Salinas, Puerto Rico, Central Aguirre Power Station

Shore tank END OF THE MONTH INVENTORY AGUIRRE 02-28-2026
Product NO2

Survey date: 28 Feb 2026

Certificate of Quantity

The undersigned Independent Saybolt Surveyor herewith declares that the quantity of product measured amounts to:

	Gross	Net
Cubic meters 60°F	60,912.625	60,912.625
Barrels 60°F	383,128.86	383,128.86
US Gallons 60°F	16,091,412.12	16,091,412.12
Metric Tons vac	51,283.375	51,283.375
Metric Tons air	51,218.038	51,218.038
Long Tons	50,409.127	50,409.127
Short Tons	56,458.221	56,458.221
Pounds	112,916,442.00	112,916,442.00

These quantities have been determined by Shore tank measurements taken by Manual measurements.

B/L API 60°F	36.40
B/L Density 15°C	0.8423
B/L Density 20°C	0.8388
B/L RD 60/60°F	0.8428

Criteria used

US Barrels 60°F to Cu m 60°F	MPMS 11.5 - Annex D	0.158987304
US Barrels 60°F to US Gallons 60°F	MPMS 11.5 - Annex D	42
Metric Tons Air to Metric Tons Vac	MPMS 11.5.3 - 4.5	1.001275667
Barrels 60°F to Metric Tons Air	MPMS 11.5.1 - 4.15	0.1336862302
Barrels 60°F to Long Tons	MPMS 11.5.1 - 4.12	0.1315748605
Long Tons to Short Tons	MPMS 11.5 - Annex D	1.12

Remark

Net via S&W Volume %

Signed by: Saybolt representative
 Name:
 Rank: Saybolt Inspector

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

Handled by: Rafael Rodriguez
 SAYBOLT LLC, STREET 127 KM 11.7 MAGAS ARRIBA, 00656 GUAYANILLA, PUERTO RICO
 Tel. 787-835-4784 FAX 787-835-4788
 Website: WWW.CORELAB.COM E-mail: EDWIN.HERNANDEZ@CORELAB.COM
 All our activities are carried out under Saybolt's terms and conditions, available at www.corelab.com/saybolt/terms-conditions
 SAIL4 COO V4.1.9.14 20240227

Date: 02 Mar 2026 14:09
 Page 24 of 24