



Field Inspection Report

Cargo Operation: Inventory

Vessel(s)

Inventory

Product(s)

6 Fuel Oil
ULSD

Client(s)

Autoridad De Energia Electrica De Puerto Rico

Reference #

CS-TANKINV-2-28-26

Location(s)

Guayanilla | Genera PR - Costa Sur

All measurements contained in this report were performed according to the API manual of petroleum measurement standards:

Chapter 3 Tank Gauging; Chapter 7 Temperature Determination; Chapter 8 Sampling; Chapter 12 Calculation of Petroleum Quantities; Chapter 17 Marine Measurement.

All Bureau Veritas measurement devices and methods used for quantity and quality determination meet pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule).

All Operations to be carried out in accordance with Bureau Veritas Commodities Division General Conditions of Service (2014 Edition). An electronic version can also be viewed on our company website:
www.bureauveritas.com/terms_and_conditions/index.asp

Reinaldo LUGO
Bureau Veritas Commodities and Trade, Inc

Table of Contents

Shore Tanks Measurements - # 6 Fuel Oil	1
Shore Tanks Measurements - ULSD	2

R.B.

Job #: PRPUE-26-00061-1

Date: 28-Feb-2026

Location(s): Guayanilla - Genera PR - Costa Sur

Vessel(s): Inventory

Product(s): # 6 Fuel Oil

Client(s): Autoridad De Energia Electrica De Puerto Rico-CS-TANKINV-2-28-26

Shore Tanks Measurements



BUREAU
VERITAS

R-2	Crit Zone	Phase	Date/Time	Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
		Open	28-Feb-2026 23:32	N/A	75.0	1.00036	75.99		6B-60°F	
		Close		N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels
Open	17-1 1/2	211,074.64	N/A		19.1	91.2	211,150.63	0.98729	208,466.91
Close									
Difference		211,074.64					211,150.63		208,466.91

Adjustments to GSV

R-3	Crit Zone	Phase	Date/Time	Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
		Open	01-Mar-2026 00:00	N/A	75.0	1.00032	68.79		6B-60°F	
		Close		N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels
Open	16-9 3/8	214,972.32	N/A		17.6	87.0	215,041.11	0.98915	212,707.91
Close									
Difference		214,972.32					215,041.11		212,707.91

Adjustments to GSV

Shore Summary						
API-60°F	Adjustments (Bbls)			Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV	To Water			
18.4						N/A

Shore Delivered	Shore Delivered	Total Calculated	Gross Standard
	Cubic Meters 15°C	66,934.672	66,934.672
	Barrels 60°F	421,174.82	421,174.82
	Gallons 60°F	17,689,342.44	17,689,342.44
	Pounds	139,058,905	139,058,905
	Long Tons	62,079.868	62,079.868
	MT (In Air)	63,076.058	63,076.058
	Free Water		

Density
API 60°F
18.4
Table 8 Lbs/Gal (In Air)
7.861168704
Table 11 LT/Bbl (In Air)
0.1473969132
Table 13 MT/Bbl (In Air)
0.1497621780
Table 13 MT/Bbl (In Vac)
0.1499303901

Comments

Preliminary

Date/Time

Date/Time

Reinaldo LUGO

Job #: PRPUE-26-00061-1

Date: 28-Feb-2026

Location(s): Guayanilla - Genera PR - Costa Sur

Vessel(s): Inventory

Product(s): ULSD

Client(s): Autoridad De Energia Electrica De Puerto Rico-CS-TANKINV-2-28-26

Shore Tanks Measurements



BUREAU
VERITAS

TG - 1		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
			Open	28-Feb-2026	23:20	N/A	80.0	1.00029	0.88		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels			
Open	17-10 15/16	3,067.10	0-2 1/2	35.64	34.6	83.0	3,032.34	0.98937	3,000.11			
Close												
Difference		3,067.10		35.64			3,032.34		3,000.11			
Adjustments to GSV									3,000.11			

Shore Summary						
API-60°F	Adjustments (Bbls)			Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV	To Water			
34.6						N/A
Shore Delivered	Shore Delivered	Total Calculated	Gross Standard		Density	
	Cubic Meters 15°C	482.423	476.760		API 60°F	
	Barrels 60°F	3,035.75	3,000.11		34.6	
	Gallons 60°F	127,501.50	126,004.62		Table 8 Lbs/Gal (In Air)	
	Pounds	904,429	893,811		7.093480037	
	Long Tons	403.763	399.023		Table 11 LT/Bbl (In Air)	
	MT (In Air)	410.242	405.426		0.1330027507	
	Free Water	35.64			Table 13 MT/Bbl (In Air)	
					0.1351370337	
					Table 13 MT/Bbl (In Vac)	
					0.1353074381	

Comments

Preliminary

Date/Time

Date/Time

Reinaldo LUG