



Field Inspection Report

Cargo Operation: Inventory

Vessel(s)

Inventory

Product(s)

Diesel Fuel (ULSD)

Client(s)

Autoridad De Energia Electrica De Puerto Rico

Reference #

DG-TANKINV-2-28-26

Location(s)

GeneraPR - Daguao

All measurements contained in this report were performed according to the API manual of petroleum measurement standards.

Chapter 3 Tank Gauging, Chapter 7 Temperature Determination, Chapter 8 Sampling, Chapter 12 Calculation of Petroleum Quantities, Chapter 17 Marine Measurement.

All Bureau Veritas measurement devices and methods used for quantity and quality determination meet pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule).

All Operations to be carried out in accordance with Bureau Veritas Commodities Division General Conditions of Service. An electronic version can also be viewed on our company website: <https://commodities.bureauveritas.com/general-conditions-of-service>

Victor Reyes
Bureau Veritas Commodities and Trade, Inc

Table of Contents

Shore Tanks Measurements - Diesel Fuel (ULSD)

1

V. Reyes

Job #: PRPUE-26-00063-1

Date: 28-Feb-2026

Location(s): GeneraPR - Daguao

Vessel(s): Inventory

Product(s): Diesel Fuel (ULSD)

Client(s): Autoridad De Energia Electrica De Puerto Rico-DG-TANKINV-2-28-26

Shore Tanks Measurements



**BUREAU
VERITAS**

S-1		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
			Open	28-Feb-2026	21:15	N/A	78.0	1.00025	2.46		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels			
Open	28-1 3/8	9,859.29	0-0	0.00	36.0	80.2	9,861.75	0.99056	9,768.66			
Close												
Difference		9,859.29		0.00			9,861.75		9,768.66			
Adjustments to GSV									9,768.66			

Shore Summary						
API-60°F	Adjustments (Bbls)			Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV	To Water			
36.0						Kolor Kut
Shore Delivered	Shore Delivered	Total Calculated	Gross Standard			Density
	Cubic Meters 15°C	1,552.363	1,552.363	1,552.363		API 60°F
	Cubic Meters 60°F	1,553.093	1,553.093	1,553.093		36.0
	Liters 60°F	1,553,093	1,553,093	1,553,093		Table 8 Lbs/Gal (In Air)
	Barrels 60°F	9,768.66	9,768.66	9,768.66		7.034107587
	Gallons 60°F	410,283.72	410,283.72	410,283.72		Table 11 LT/Bbl (In Air)
	Kilograms	1,309,058	1,309,058	1,309,058		0.1318895173
	Pounds	2,885,980	2,885,980	2,885,980		Table 13 MT/Bbl (In Air)
	Short Tons	1,442.990	1,442.990	1,442.990		0.1340059363
	Long Tons	1,288.384	1,288.384	1,288.384		Table 13 MT/Bbl (In Vac)
	MT (In Air)	1,309.058	1,309.058	1,309.058		0.1341765103
MT (In Vac)	1,310.725	1,310.725	1,310.725			
	Free Water	0.00				

Date/Time

Date/Time

Date/Time

28-Feb-2026