

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
PS-TANKINV-2-28-26

Digitally Generated by : Saybolt
Reason : Reporting
Location : 13101 Saybolt Puerto Rico - All Activity
Date : 2026.03.03 15:15:02 -04:00



Job No 13101/00018703.0000/01/1/26
Report date 02 Mar 2026
Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6, NO2

Survey date: 28-Feb-2026, 28-Feb-2026

Contents page

Saybolt LP (Puerto Rico) has performed a survey and the findings of the survey are reflected in the following reports:

Title	Number of Pages
Contents page	one
Shore Tank Inventory Report	two
Shore Tank Measurement Details	seven
Shore Tank Inventory Subtotals	two
Certificate of Quantity	two

This report consists of 14 pages.

A copy of this report and all field documents and related correspondence will be retained for a period of 10 years, unless local law requires otherwise

Handled by: Rafael Rodriguez

This report reflects only the findings at the time and place of the inspection and testing. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions.

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

Handled by: Rafael Rodriguez
Saybolt LP, 127 Km 11.7 magas Arriba, 00656 Guayanilla, Puerto Rico
Tel. 787-835-4784 FAX
Website: www.corelab.com E-mail:rafael.rodriguez@corelab.com
All our activities are carried out under Saybolt's terms and conditions, available at www.corelab.com/saybolt/terms-conditions
SAIL4 CNT V4.3.0.0 2026/01/27

Date: 03 Mar 2026 15:14
Page 1 of 14

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 PS-TANKINV-2-28-26



Job No 13101/00018703.0000/01/1/26
 Report date 02 Mar 2026
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO2

Shore Tank Inventory Report

Survey date: 28-Feb-2026

Shore tank measurement		Totals	D-2	D-1	D-3
Open measurement					
Date/time of measurement		28 Feb 2026 22:30	28 Feb 2026 23:55	28 Feb 2026 22:15	
Average Innage	FT/IN	07 10-3/8	14 01-1/2	07 04-1/16	
Average temp.	°F	81.6	81.2	82.6	
T.O.V.	Barrels	13,534.23	10,208.02	15,884.96	
Free Water					
Water	FT/IN				00 03-1/2
Water	Barrels				147.80
Ambient temp.	°F	76.00	76.00	76.00	
Tank shell temp.	°F	81.00	81.00	82.00	
CTsh		1.00026	1.00026	1.00027	
G.O.V.	Barrels	13,537.75	10,210.67	15,741.41	
API 60°F		36.60	37.20	37.60	
V.C.F.	6B	0.98986	0.99000	0.98928	
G.S.V.	barrels 60°F	13,400.48	10,108.56	15,572.66	
W.C.F.	MPMS 11.5.1.4.12	0.1314180936	0.1309500233	0.1306398217	
W.C.F.	MPMS 11.5.1.4.15	0.1335269477	0.1330513663	0.1327361870	
Long Tons		1,761.066	1,323.716	2,034.410	
Metric Tons Air		1,789.325	1,344.958	2,067.056	
Subtotals					
G.S.V.	barrels 60°F	39,081.70	13,400.48	10,108.56	15,572.66
Long Tons		5,119.192	1,761.066	1,323.716	2,034.410

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 PS-TANKINV-2-28-26



Job No 13101/00018703.0000/01/1/26
 Report date 02 Mar 2026
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Shore Tank Inventory Report

Survey date: 28-Feb-2026

Shore tank measurement		Totals	R-1	R-4	R-2	S-4
Open measurement						
Date/time of measurement		28 Feb 2026 22:45	28 Feb 2026 22:45	28 Feb 2026 22:15	28 Feb 2026 23:55	
Average Innage	FT/IN	22 11-1/4	30 06-0/0	26 09-15/16	06 09-7/8	
Average temp.	°F	79.4	88.9	86.9	85.4	
T.O.V.	Barrels	31,536.67	47,351.15	18,422.69	8,734.12	
Free Water						
Ambient temp.	°F	76.00	76.00	76.00	76.00	
Tank shell temp.	°F	79.00	87.00	86.00	84.00	
CTsh		1.00024	1.00033	1.00032	1.00030	
G.O.V.	Barrels	31,544.24	47,366.78	18,428.59	8,736.74	
API 60°F		18.10	18.00	18.70	18.00	
V.C.F.	6B	0.99218	0.98834	0.98909	0.98976	
G.S.V.	barrels 60°F	31,297.56	46,814.48	18,227.53	8,647.28	
W.C.F.	MPMS 11.5.1.4.12	0.1476928716	0.1477917884	0.1471021371	0.1477917884	
W.C.F.	MPMS 11.5.1.4.15	0.1500628856	0.1501633897	0.1494626716	0.1501633897	
Long Tons		4,622.427	6,918.796	2,681.309	1,277.997	
Metric Tons Air		4,696.602	7,029.821	2,724.335	1,298.505	
Subtotals						
G.S.V.	barrels 60°F	104,986.85	31,297.56	46,814.48	18,227.53	8,647.28
Long Tons		15,500.529	4,622.427	6,918.796	2,681.309	1,277.997

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 PS-TANKINV-2-28-26



Job No 13101/00018703.0000/01/1/26
 Report date 02 Mar 2026
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO2

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank D-1

Measurement data (Innage)		Open	Close
Average	FT/IN	14 01-1/2	
Temperature			
Average temp.	°F	81.2	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53314	
Temperature equipment type		Shore Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-05649	
Tank calibration table		valid from 28 Jul 2024	
Tank Calibration table nr.		D-1	
Inspector equipment used for verification?		Yes	
Inspector name		J.FLORES	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 PS-TANKINV-2-28-26



Job No 13101/00018703.0000/01/1/26
 Report date 02 Mar 2026
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO2

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank D-2

Measurement data (Innage)		Open	Close
Average	FT/IN	07 10-3/8	
Temperature			
Average temp.	°F	81.6	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53314	
Temperature equipment type		Shore Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-05649	
Tank calibration table		valid from 28 Jul 2024	
Tank Calibration table nr.		D-2	
Inspector equipment used for verification?		Yes	
Inspector name		J.FLORES	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 PS-TANKINV-2-28-26



Job No 13101/00018703.0000/01/1/26
 Report date 02 Mar 2026
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO2

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank D-3

Measurement data (Innage)		Open	Close
Average	FT/IN	07 04-1/16	
Temperature			
Average temp.	°F	82.6	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53314	
Temperature equipment type		Shore Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-05649	
Tank calibration table		valid from 28 Jul 2024	
Tank Calibration table nr.		D-3	
Inspector equipment used for verification?		Yes	
Inspector name		J.FLORES	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 PS-TANKINV-2-28-26



Job No 13101/00018703.0000/01/1/26
 Report date 02 Mar 2026
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank R-1

Measurement data (Innage)		Open	Close
Average	FT/IN	22 11-1/4	
Temperature			
Average temp.	°F	79.4	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53314	
Temperature equipment type		Shore Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-05649	
Tank Calibration table nr.		R-1	
Inspector equipment used for verification?		Yes	
Inspector name		J.FLORES	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 PS-TANKINV-2-28-26



Job No 13101/00018703.0000/01/1/26
 Report date 02 Mar 2026
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank R-2

Measurement data (Innage)		Open	Close
Average	FT/IN	26 09-15/16	
Temperature			
Average temp.	°F	86.9	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53315	
Temperature equipment type		Shore Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9A-9773	
Tank Calibration table nr.		R-2	
Inspector equipment used for verification?		Yes	
Inspector name		H.LOPEZ	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 PS-TANKINV-2-28-26



Job No 13101/00018703.0000/01/1/26
 Report date 02 Mar 2026
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank R-4

Measurement data (Innage)		Open	Close
Average	FT/IN	30 06-0/0	
Temperature			
Average temp.	°F	88.9	
Measurement equipment Data		Open	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53314	
Temperature equipment type		Shore Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-05649	
Tank calibration table		valid from 16 May 2001	
Tank Calibration table nr.		R-4	
Inspector name		H.LOPEZ	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 PS-TANKINV-2-28-26



Job No 13101/00018703.0000/01/1/26
 Report date 02 Mar 2026
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Survey date: 28-Feb-2026

Shore Tank Measurement Details

Shore tank S-4

Measurement data (Innage)		Open	Close
Average	FT/IN	06 09-7/8	
Temperature			
Average temp.	°F	85.4	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53315	
Temperature equipment type		Shore Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9A-9773	
Tank Calibration table nr.		S-4	
Inspector equipment used for verification?		Yes	
Inspector name		H.LOPEZ	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 PS-TANKINV-2-28-26



Job No 13101/00018703.0000/01/1/26
 Report date 02 Mar 2026
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO2

Survey date: 28-Feb-2026

Shore Tank Inventory Subtotals

Shore tank Subtotals	Totals	D-2	D-1	D-3
Gross Standard Volume				
Cu m 60°F	6,213.494	2,130.506	1,607.133	2,475.855
Barrels 60°F	39,081.70	13,400.48	10,108.56	15,572.66
US Gallons 60°F	1,641,431.40	562,820.16	424,559.52	654,051.72
Metric Tons Vac	5,208.008	1,791.611	1,346.683	2,069.714
Metric Tons Air	5,201.339	1,789.325	1,344.958	2,067.056
Long Tons Air	5,119.192	1,761.066	1,323.716	2,034.410
Short Tons Air	5,733.495	1,972.394	1,482.562	2,278.539
Pounds Air	11,466,990.00	3,944,788.00	2,965,124.00	4,557,078.00
Density 15°C		0.8413	0.8383	0.8364
API 60°F		36.60	37.20	37.60
RD 60/60°F		0.8418	0.8388	0.8368
Total Calculated Volume				
Barrels 60°F	39,229.50	13,400.48	10,108.56	15,720.46
US Gallons 60°F	1,647,639.00	562,820.16	424,559.52	660,259.32

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 PS-TANKINV-2-28-26



Job No 13101/00018703.0000/01/1/26
 Report date 02 Mar 2026
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Survey date: 28-Feb-2026

Shore Tank Inventory Subtotals

Shore tank Subtotals	Totals	R-1	R-4	R-2	S-4
Gross Standard Volume					
Cu m 60°F	16,691.577	4,975.915	7,442.908	2,897.946	1,374.808
Barrels 60°F	104,986.85	31,297.56	46,814.48	18,227.53	8,647.28
US Gallons 60°F	4,409,447.70	1,314,497.52	1,966,208.16	765,556.26	363,185.76
Metric Tons Vac	15,766.911	4,701.863	7,037.689	2,727.401	1,299.958
Metric Tons Air	15,749.263	4,696.602	7,029.821	2,724.335	1,298.505
Long Tons Air	15,500.529	4,622.427	6,918.796	2,681.309	1,277.997
Short Tons Air	17,360.593	5,177.118	7,749.052	3,003.066	1,431.357
Pounds Air	34,721,186.00	10,354,236.00	15,498,104.00	6,006,132.00	2,862,714.00
Density 15°C		0.9453	0.9459	0.9415	0.9459
API 60°F		18.10	18.00	18.70	18.00
RD 60/60°F		0.9459	0.9465	0.9421	0.9465
Total Calculated Volume					
Barrels 60°F	104,986.85	31,297.56	46,814.48	18,227.53	8,647.28
US Gallons 60°F	4,409,447.70	1,314,497.52	1,966,208.16	765,556.26	363,185.76

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 PS-TANKINV-2-28-26



Job No 13101/00018703.0000/01/1/26
 Report date 02 Mar 2026
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO6

Survey date: 28 Feb 2026

Certificate of Quantity

The undersigned Independent Saybolt Surveyor herewith declares that the quantity of product measured amounts to:

	Gross	Net
Cubic meters 60°F	16,691.577	16,691.577
Barrels 60°F	104,986.85	104,986.85
US Gallons 60°F	4,409,447.70	4,409,447.70
Metric Tons vac	15,766.911	15,766.911
Metric Tons air	15,749.263	15,749.263
Long Tons	15,500.529	15,500.529
Short Tons	17,360.593	17,360.593
Pounds	34,721,186.00	34,721,186.00

These quantities have been determined by measurement of shore tanks.

B/L API 60°F	18.15
B/L Density 15°C	0.9450
B/L Density 20°C	0.9416
B/L RD 60/60°F	0.9455

Criteria used

US Barrels 60°F to Cu m 60°F	MPMS 11.5 - Annex D	0.158987304
US Barrels 60°F to US Gallons 60°F	MPMS 11.5 - Annex D	42
Metric Tons Air to Metric Tons Vac	MPMS 11.5.3 - 4.5	1.001120543
Barrels 60°F to Metric Tons Air	MPMS 11.5.1 - 4.15	0.150012684
Barrels 60°F to Long Tons	MPMS 11.5.1 - 4.12	0.1476434628
Long Tons to Short Tons	MPMS 11.5 - Annex D	1.12

Remark

Net via S&W Volume %

Signed by: Saybolt representative
 Name:
 Rank: Saybolt Inspector

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

Handled by: Rafael Rodriguez
 Saybolt LP, 127 Km 11.7 magas Arriba, 00656 Guayanilla, Puerto Rico
 Tel. 787-835-4784 FAX
 Website: www.corelab.com E-mail:rafael.rodriguez@corelab.com
 All our activities are carried out under Saybolt's terms and conditions, available at www.corelab.com/saybolt/terms-conditions
 SAIL4 COQ V4.1.9.14 20240227

Date: 03 Mar 2026 15:14
 Page 13 of 14

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 PS-TANKINV-2-28-26



Job No 13101/00018703.0000/01/1/26
 Report date 02 Mar 2026
 Installation Toa Baja, Puerto Rico, Central Palo Seco Terminal

Shore tank END OF THE MONTH INVENTORY / PALO SECO
Product NO2

Survey date: 28 Feb 2026

Certificate of Quantity

The undersigned Independent Saybolt Surveyor herewith declares that the quantity of product measured amounts to:

	Gross	Net
Cubic meters 60°F	6,213.494	6,213.494
Barrels 60°F	39,081.70	39,081.70
US Gallons 60°F	1,641,431.40	1,641,431.40
Metric Tons vac	5,208.008	5,208.008
Metric Tons air	5,201.339	5,201.339
Long Tons	5,119.192	5,119.192
Short Tons	5,733.495	5,733.495
Pounds	11,466,990.00	11,466,990.00

These quantities have been determined by measurement of shore tanks.

B/L API 60°F	37.15
B/L Density 15°C	0.8386
B/L Density 20°C	0.8350
B/L RD 60/60°F	0.8390

Criteria used

US Barrels 60°F to Cu m 60°F	MPMS 11.5 - Annex D	0.158987304
US Barrels 60°F to US Gallons 60°F	MPMS 11.5 - Annex D	42
Metric Tons Air to Metric Tons Vac	MPMS 11.5.3 - 4.5	1.001281966
Barrels 60°F to Metric Tons Air	MPMS 11.5.1 - 4.15	0.1330908689
Barrels 60°F to Long Tons	MPMS 11.5.1 - 4.12	0.1309889019
Long Tons to Short Tons	MPMS 11.5 - Annex D	1.12

Remark

Net via S&W Volume %

Signed by: Saybolt representative
 Name:
 Rank: Saybolt Inspector

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

Handled by: Rafael Rodriguez
 Saybolt LP, 127 Km 11.7 magas Arriba, 00656 Guayanilla, Puerto Rico
 Tel. 787-835-4784 FAX
 Website: www.corelab.com E-mail:rafael.rodriguez@corelab.com
 All our activities are carried out under Saybolt's terms and conditions, available at www.corelab.com/saybolt/terms-conditions
 SAIL4 COQ V4.1.9.14 20240227

Date: 03 Mar 2026 15:14
 Page 14 of 14