



Field Inspection Report

Cargo Operation: Inventory

Vessel(s)

Inventory

Product(s)

6 Fuel Oil

ULSD

Client(s)

Autoridad De Energia Electrica De Puerto Rico

Reference #

AG-TANKINV-5-31-26

Location(s)

Aguirre - Genera PR

All measurements contained in this report were performed according to the API manual of petroleum measurement standards:

Chapter 3 Tank Gauging; Chapter 7 Temperature Determination; Chapter 8 Sampling; Chapter 12 Calculation of Petroleum Quantities; Chapter 17 Marine Measurement.

All Bureau Veritas measurement devices and methods used for quantity and quality determination meet pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule).

All Operations to be carried out in accordance with Bureau Veritas Commodities Division General Conditions of Service (2014 Edition). An electronic version can also be viewed on our company website: www.bureauveritas.com/terms_and_conditions/index.asp

Reinaldo LOGO

Bureau Veritas Commodities and Trade, Inc

Table of Contents

Shore Tanks Measurements - # 6 Fuel Oil	1
Shore Tanks Measurements - ULSD	2

R.A.

Job #: PRPUE-26-00201-1

Date: 31-May-2026

Location(s): Aguirre - Genera PR

Vessel(s): Inventory

Product(s): # 6 Fuel Oil

Client(s): Autoridad De Energia Electrica De Puerto Rico-AG-TANKINV-5-31-26

Shore Tanks Measurements



**BUREAU
VERITAS**

R-1	Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
		Open	31-May-2026	19:45	N/A	80.0	1.00037	91.57		6B-60°F	
		Close			N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels
Open	37-1 1/2	247,490.77	N/A		17.1	91.3	247,582.34	0.98747	244,480.13
Close									
Difference		247,490.77					247,582.34		244,480.13

Adjustments to GSV

R-3	Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
		Open	31-May-2026	19:30	N/A	80.0	1.00040	97.72		6B-60°F	
		Close			N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels
Open	36-7 1/8	244,297.27	N/A		16.6	93.4	244,394.99	0.98669	241,142.09
Close									
Difference		244,297.27					244,394.99		241,142.09

Adjustments to GSV

S-1	Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
		Open	01-Jun-2026	00:01	N/A	80.0	1.00027	6.49		6B-60°F	
		Close			N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels
Open	13-9 5/8	24,025.63	N/A		18.7	82.7	24,032.12	0.99080	23,811.02
Close									
Difference		24,025.63					24,032.12		23,811.02

Adjustments to GSV

S-2	Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
		Open	01-Jun-2026	00:05	N/A	80.0	1.00030	7.73		6B-60°F	
		Close			N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels
Open	11-9 7/8	25,770.69	N/A		18.7	84.6	25,778.42	0.99002	25,521.15
Close									
Difference		25,770.69					25,778.42		25,521.15

Adjustments to GSV

Shore Summary						
API-60°F	Adjustments (Bbls)			Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV	To Water			
17.0						N/A

Shore Delivered	Shore Delivered	Total Calculated	Gross Standard	Density
	Cubic Meters 15°C	85,016.944	85,016.944	API 60°F
	Barrels 60°F	534,954.39	534,954.39	17.0
	Gallons 60°F	22,468,084.38	22,468,084.38	Table 8 Lbs/Gal (In Air)
	Pounds	178,292,677	178,292,677	7.935375098
	Long Tons	79,594.945	79,594.945	Table 11 LT/Bbl (In Air)
	MT (In Air)	80,872.198	80,872.198	0.1487882831
	Free Water			Table 13 MT/Bbl (In Air)
				0.1511758751
				Table 13 MT/Bbl (In Vac)
				0.1513438752

Date/Time

Date/Time

R. LUGO
Remaldo LUGO

Date/Time

Job #: PRPUE-26-00201-1
 Date: 31-May-2026

Shore Tanks Measurements



**BUREAU
VERITAS**

Location(s): Aguirre - Genera PR
 Vessel(s): Inventory
 Product(s): ULSD
 Client(s): Autoridad De Energia Electrica De Puerto Rico-AG-TANKINV-5-31-26

R-1		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
			Open	31-May-2026	22:20	N/A	80.0	1.00030	3.18		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels			
Open	12-1 1/8	10,690.83	0-3	97.66	35.5	84.1	10,596.35	0.98878	10,477.46			
Close												
Difference		10,690.83		97.66			10,596.35		10,477.46			
Adjustments to GSV												10,477.46
R-2		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
			Open	31-May-2026	22:40	N/A	80.0	1.00030	10.40		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels			
Open	38-11 11/16	34,737.24	0-2 3/4	71.92	35.2	84.3	34,675.72	0.98871	34,284.23			
Close												
Difference		34,737.24		71.92			34,675.72		34,284.23			
Adjustments to GSV												34,284.23
R-6		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
			Open	31-May-2026	19:15	N/A	80.0	1.00031	81.33		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels			
Open	39-3 1/2	262,352.62	0-0	0.00	36.6	86.2	262,433.95	0.98769	259,203.39			
Close												
Difference		262,352.62		0.00			262,433.95		259,203.39			
Adjustments to GSV												259,203.39
D-1		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
			Open	01-Jun-2026	00:15	N/A	80.0	1.00033	3.68		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels			
Open	16-8 7/8	11,442.07	0-6	302.90	36.6	88.5	11,142.85	0.98660	10,993.54			
Close												
Difference		11,442.07		302.90			11,142.85		10,993.54			
Adjustments to GSV												10,993.54
D-2		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
			Open	31-May-2026		N/A	80.0	1.00033	7.11		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels			
Open	32-2	22,232.43	0-9	677.90	36.6	88.3	21,561.64	0.98670	21,274.87			
Close												
Difference		22,232.43		677.90			21,561.64		21,274.87			
Adjustments to GSV												21,274.87
D-4		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
			Open	31-May-2026	21:15	N/A	80.0	1.00035	4.20		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels			
Open	17-6 1/4	12,007.38	0-0 3/8	21.40	33.3	89.0	11,990.18	0.98672	11,830.95			
Close												
Difference		12,007.38		21.40			11,990.18		11,830.95			
Adjustments to GSV												11,830.95
TG-1		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
			Open	31-May-2026	18:45	N/A	80.0	1.00032	3.31		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels			
Open	29-4 7/8	10,330.71	0-0	0.00	38.4	86.5	10,334.02	0.98731	10,202.88			
Close												
Difference		10,330.71		0.00			10,334.02		10,202.88			
Adjustments to GSV												10,202.88

Job #: PRPUE-26-00201-1

Date: 31-May-2026

Location(s): Aguirre - Genera PR

Vessel(s): Inventory

Product(s): ULSD

Client(s): Autoridad De Energia Electrica De Puerto Rico-AG-TANKINV-5-31-26

Shore Tanks Measurements



**BUREAU
VERITAS**

TG-2		Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
			Open	31-May-2026	18:30	N/A	80.0	1.00032	1.78		6B-60°F	
			Close			N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels			
Open	32-11 15/16	5,661.86	0-7	92.79	39.2	86.9	5,570.85	0.98699	5,498.37			
Close												
Difference		5,661.86		92.79			5,570.85		5,498.37			
Adjustments to GSV										5,498.37		

Shore Summary						
API-60°F	Adjustments (Bbls)			Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV	To Water			
36.0						Kolor kut
Shore Delivered	Shore Delivered	Total Calculated	Gross Standard			
	Cubic Meters 15°C	58,007.910	57,806.954		Density	
	Barrels 60°F	365,030.26	363,765.69		API 60°F	
	Gallons 60°F	15,331,270.92	15,278,158.98		36.0	
	Pounds	107,841,809	107,468,214		Table 8 Lbs/Gal (In Air)	
	Long Tons	48,143.665	47,976.881		7.034107587	
	MT (In Air)	48,916.222	48,746.762		Table 11 LT/Bbl (In Air)	
					0.1318895173	
					Table 13 MT/Bbl (In Air)	
					0.1340059363	
					Table 13 MT/Bbl (In Vac)	
					0.1341765103	
	Free Water	1,264.57				

Date/Time

Date/Time

Date/Time

Reinaldo LUGO