




PREPA COSTA SUR INVENTORY
AS PER API CHAP: 3,7,8,12,17

DATE: MAY 31, 2026
RECORD NO.: GA026225

PREPA SHIPMENT NO. CS-TANKINV-5-31-26

TANK	DATE	TIME	GAUGE	GROSS VOLUME	WATER GAUGE	VOLUME	LIQ. TEMP.	API	AMB. TEMP.
NO 6 FUEL OIL									
R-2	05/31/26	2359	09' 08 7/8"	260,676.06	00' 00"	0.00	89.7	19.0	77.0
R-3	05/31/26	2310	07' 10 11/16"	274,733.65	00' 00"	0.00	89.2	17.0	77.0
NO 2 DESTILLATE FUEL OIL									
LDS	05/31/26	2325	17' 11"	128,856.00	00' 02 1/2"	1,497.00	87.0	34.6	77.0

06/02/26 @10:28am Shore Figures confirmed with Eng. Hector Lopez of PREPA Costa Sur Power Plant


 ALTOL PETROLEUM PRODUCTS SERV. INC.
 BRENDA REYES-MARTINEZ
 INSPECTION SERVICES SUPERVISOR

228 Parque Industrial Sabanetas
 Ponce, PR 00716-4401
 Tel. 787-835-4242, Fax 787-835-2004



Calle Gregorio Ledesma, HN 55, Levittown
 Toa Baja, P. R. 00949
 Tel. 787-784-1112, Fax 787-784-1115

REPORT OF SHORE QUANTITY
 AS PER API CHAP: 3,7,8,12,17

PREPA SHIPMENT NO. CS-TANKINV-5-31-26

EVENT: COSTA SUR TANK INVENTORY GAUGE					RECORD NO.: GA026225					DATE: MAY 31, 2026				
PRODUCT: NO. 6 FUEL OIL					CONSIGNOR: PUERTO RICO ELECTRIC POWER AUTHORITY					PORT/TERMINAL: GUAYANILLA, PR				
					CONSIGNEE: GENERA PR					DESTINATION: PREPA COSTA SUR POWER PLANT				
TANK NO.	DATE	TIME	ULLAGE (FT/M)	TOTAL OBSERVED VOLUME (TOV)	FREE WATER = (FW)		TEMP. CORR. SHELL CTSh	ROOF CORR. (+/-) (FRA)	GROSS OBSERVED VOLUME (GOV)	API @ 60°F	AMB. TEMP. (°F/°C)	OBS. TEMP. (°F/°C)	V.C.F. TABLE (CTL)	GROSS STANDARD VOLUME (GSV)
					INNAGE (FT/M)	VOLUME (BBLS/M3)								
R-2	05/31/26	2359	09' 08 7/8"	260,676.06	00' 00"	0.00	1.00035	0.00	260,767.30	19.0	77.0	89.7	0.98792	257,617.23
TOTAL DELIVERED THIS TANK														
R-3	05/31/26	2310	07' 10 11/16"	274,733.65	00' 00"	0.00	1.00035	0.00	274,829.81	17.0	77.0	89.2	0.98832	271,619.79
TOTAL DELIVERED THIS TANK														
TOTAL DELIVERED THIS TANK														
TOTAL DELIVERED THIS TANK														
TOTAL DELIVERED THIS TANK														

TANKS NO.	R-2	R-3	TOTAL CARGO	
NET BARRELS AT 60F	257,617.23	271,619.79	529,237.02	
NET GALLONS AT 60F	10,819,923.66	11,408,031.18	22,227,954.84	
POUNDS/GALS				
POUNDS	84,712,790.40	90,521,961.60	175,234,752.00	
LONG TONS	37,818.21	40,411.59	78,229.80	
METRIC TONS	38,426.19	41,060.76	79,486.95	
CUBIC METERS	0.14680	0.14916	0.14878	0.15117

SHORE PIPELINES : COMMENCED: FINISHED :
 VESSEL TANKS :

FORM AL05-08/95; REV. 01/24
 06/02/26 @10:28am Shore Figures confirmed with Eng. Hector Lopez of PREPA Costa Sur Power Plant

[Signature]
 ALTOL PETROLEUM PRODUCTS SERV. INC.
 BRENDA REYES-MARTINEZ
 INSPECTION SERVICES SUPERVISOR

228 Parque Industrial Sabanetas
 Ponce, PR 00716-4401
 Tel. 787-835-4242, Fax 787-835-2004



Calle Gregorio Ledesma, HN 55, Levittown
 Toa Baja, P. R. 00949
 Tel. 787-784-1112, Fax 787-784-1115

REPORT OF SHORE QUANTITY
 AS PER API CHAP: 3,7,8,12,17

PREPA SHIPMENT NO. CS-TANKINV-5-31-26

EVENT: COSTA SUR TANK INVENTORY GAUGE					RECORD NO.: GA026225					DATE: MAY 31, 2026					
PRODUCT: NO. 2 DESTILATE FUEL OIL					CONSIGNOR: PUERTO RICO ELECTRIC POWER AUTHORITY					PORT/TERMINAL: GUAYANILLA, PR					
CONSIGNEE: GENERA PR					DESTINATION: PREPA COSTA SUR POWER PLANT										
TANK NO.	DATE		TIME	INNAGE (FT/M)	TOTAL OBSERVED VOLUME GALLONS	FREE WATER = (FW)		TEMP. CORR. SHELL CTS	ROOF CORR. (+/-) (FRA)	GROSS OBSERVED VOLUME (GOV)	API @ 60°F	AMB. TEMP. (°F/°C)	OBS. TEMP. (°F/°C)	V.C.F. TABLE (CTL)	GROSS STANDARD VOLUME (GSV)
	DATE	TIME				INNAGE (FT/M)	VOLUME (BBL/M3)								
LDS	05/31/26	2325	17' 11"	128,856.00	00' 02 1/2"	1,497.00	1.00032	0.00	127,399.75	34.6	77.0	87.0	0.98751	125,808.53	
TOTAL DELIVERED THIS TANK															
TOTAL DELIVERED THIS TANK															
TOTAL DELIVERED THIS TANK															
TOTAL DELIVERED THIS TANK															

TANKS NO.	LDS														TOTAL CARGO
NET BARRELS AT 60F	2,995.44														2,995.44
NET GALLONS AT 60F	125,808.53														125,808.53
POUNDS/GALS															
POUNDS	892,393.60														892,393.60
LONG TONS	398.39														398.39
METRIC TONS	404.77														404.77
CUBIC METERS	0.13300	0.13513													476.237
SHORE PIPELINES :		COMMENCED: FULL				FINISHED : FULL									
VESSEL TANKS :															

FORM AL05-08/95; REV. 01/24
 06/02/26 @10:28am Shore Figures confirmed with Eng. Hector Lopez of PREPA Costa Sur Power Plant

ALTOL PETROLEUM PRODUCTS SERV. INC.
 BRENDA REYES-MARTINEZ
 INSPECTION SERVICES SUPERVISOR