



## Field Inspection Report

### Cargo Operation: Inventory

**Vessel(s)**

Inventory

**Product(s)**

Diesel Fuel (ULSD)

**Client(s)**

Autoridad De Energia Electrica De Puerto Rico

**Reference #**

JB-TANKINV-5-31-26

**Location(s)**

GeneraPR - Jobos

All measurements contained in this report were performed according to the API manual of petroleum measurement standards:

Chapter 3 Tank Gauging; Chapter 7 Temperature Determination; Chapter 8 Sampling; Chapter 12 Calculation of Petroleum Quantities; Chapter 17 Manne Measurement

All Bureau Veritas measurement devices and methods used for quantity and quality determination meet pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

All Operations to be carried out in accordance with Bureau Veritas Commodities Division General Conditions of Service (2014 Edition). An electronic version can also be viewed on our company website [www.bureauveritas.com/terms\\_and\\_conditions/index.asp](http://www.bureauveritas.com/terms_and_conditions/index.asp)

Victor Reyes

Bureau Veritas Commodities and Trade, Inc

# Table of Contents

Shore Tanks Measurements - Diesel Fuel (ULSD)

1

V. Ray

Job #: PRPUE-26-00202-1

Date: 31-May-2026

Location(s): GeneraPR - Jobos

Vessel(s): Inventory

Product(s): Diesel Fuel (ULSD)

Client(s): Autoridad De Energia Electrica De Puerto Rico-JB-TANKINV-5-31-26

# Shore Tanks Measurements



**BUREAU  
VERITAS**

S-1	Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Gal	Lines Adj	VCF Table	CoE
		Open	31-May-2026	20:30	N/A	80.0	1.00029	2.76		6B-60°F	
		Close			N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Gallons	FW Gauge ft	FW Gallons	API-60°F	Temp °F	GOV Gallons	VCF 60°F	GSV Gallons
Open	2-8 7/8	9,513.00	0-0	0.00	33.0	83.1	9,515.76	0.98945	9,415.37
Close									
Difference		9,513.00		0.00			9,515.76		9,415.37

Adjustments to GSV

S-2	Crit Zone	Phase	Date/Time		Roof Adj	Amb °F	CTSh Factor	CTSh Gal	Lines Adj	VCF Table	CoE
		Open	31-May-2026	20:40	N/A	80.0	1.00032	87.69		6B-60°F	
		Close			N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Gallons	FW Gauge ft	FW Gallons	API-60°F	Temp °F	GOV Gallons	VCF 60°F	GSV Gallons
Open	18-8 3/16	274,027.00	0-0	0.00	32.0	86.8	274,114.69	0.98786	270,786.94
Close									
Difference		274,027.00		0.00			274,114.69		270,786.94

Adjustments to GSV

## Shore Summary

API-60°F	Adjustments (Gallons)			Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV	To Water			
32.0						Kolor Kut

Shore Delivered	Shore Delivered	Total Calculated	Gross Standard	Density
	Cubic Meters 15°C	1,060.204	1,060.204	API 60°F
	Cubic Meters 60°F	1,060.681	1,060.681	32.0
	Liters 60°F	1,060,681	1,060,681	Table 8 Lbs/Gal (In Air)
	Barrels 60°F	6,671.48	6,671.48	7.206440727
	Gallons 60°F	280,202.31	280,202.31	Table 11 LT/Bbl (In Air)
	Kilograms	915,921	915,921	0.1351207637
	Pounds	2,019,261	2,019,261	Table 13 MT/Bbl (In Air)
	Short Tons	1,009.631	1,009.631	0.1372890342
	Long Tons	901.455	901.455	Table 13 MT/Bbl (In Vac)
	MT (In Air)	915.921	915.921	0.1374591160
	MT (In Vac)	917.056	917.056	
Cubic Meters Other°C				
	Free Water	0.00		

Date/Time

Date/Time

*V. Reyes*  
Victor Reyes

Date/Time

31-May-2026