

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
MAY-TANKINV-5-31-26

Digitally Generated by : Saybolt
Reason : Reporting
Location : 13101 Saybolt Puerto Rico - All Activity
Date : 2026.06.02 16:14:31 -04:00



Job No 13101/00018805.0000/01/1/26
Report date 02 Jun 2026
Installation Mayagüez, Puerto Rico, PREPA Mayagüez Turbine Power Block

Shore tank End of Month Inventory Mayaguez for 5-31-26
Product NO2

Survey date: 31-May-2026

Contents page

Saybolt LP (Puerto Rico) has performed a survey and the findings of the survey are reflected in the following reports:

Title	Number of Pages
Contents page	one
Time Log	one
Shore Tank Inventory Report	one
Shore Tank Inventory Subtotals	one
Certificate of Quantity	one
Shore Tank Measurement Details	four

This report consists of 9 pages.

A copy of this report and all field documents and related correspondence will be retained for a period of 10 years, unless local law requires otherwise

Handled by: Rafael Rodriguez

This report reflects only the findings at the time and place of the inspection and testing. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions.

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

Handled by: Rafael Rodriguez
Saybolt LP, Route 127 Km 11.7 Magas Arriba, 00656 Guayanilla, Puerto Rico
Tel. 1-787-835-4784 FAX
Website: www.saybolt.com E-mail: abizayd.arzola@corelab.com
All our activities are carried out under Saybolt's terms and conditions, available at www.corelab.com/saybolt/terms-conditions
SAIL4 CNT V4.3.0.0 2026/01/27

Date: 02 Jun 2026 16:13
Page 1 of 9

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
MAY-TANKINV-5-31-26



Job No 13101/00018805.0000/01/1/26
Report date 02 Jun 2026
Installation Mayagüez, Puerto Rico, PREPA Mayagüez Turbine Power Block

Shore tank End of Month Inventory Mayaguez for 5-31-26
Product NO2

Survey date: 31-May-2026

Time Log

31 May 2026 (Sunday)	
22:45	Saybolt arrived at Installation/Destination
23:00	COMMENCED STOCK MEASUREMENT
01 Jun 2026 (Monday)	
00:10	COMPLETED STOCK MEASUREMENT
00:40	Documents Signed

All manual gauges, temp, and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp, based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

Handled by: Rafael Rodriguez
Saybolt LP, Route 127 Km 11.7 Magas Arriba, 00656 Guayanilla, Puerto Rico
Tel. 1-787-835-4784 FAX
Website: www.saybolt.com E-mail: abizayd.arzola@corelab.com
All our activities are carried out under Saybolt's terms and conditions, available at www.corelab.com/saybolt/terms-conditions
SAIL4 TML2 V4.3.0.0 20260127

Date: 02 Jun 2026 16:13
Page 2 of 9

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 MAY-TANKINV-5-31-26



Job No 13101/00018805.0000/01/1/26
 Report date 02 Jun 2026
 Installation Mayagüez, Puerto Rico, PREPA Mayagüez Turbine Power Block

Shore tank End of Month Inventory Mayaguez for 5-31-26
Product NO2

Shore Tank Inventory Report

Survey date: 31-May-2026

Shore tank measurement	Totals	D-3	D-1	D-2	D-4
Open measurement					
Date/time of measurement	01 Jun 2026 00:10	31 May 2026 23:45	31 May 2026 23:10	31 May 2026 23:25	
Average Innage FT/IN	30 05-5/16	16 00-1/4	25 10-3/4	12 06-7/8	
Average temp. °F	88.6	85.7	88.7	82.9	
T.O.V. us gallons	244,454.90	2,267,249.00	186,449.80	415,603.00	
Free Water					
Water FT/IN	00 00-1/4	00 04-3/8	00 00-1/2		
Water us gallons	167.00	22,394.82	300.00		
Ambient temp. °F	78.00	78.00	78.00	78.00	
Tank shell temp. °F	87.00	85.00	87.00	82.00	
CTsh	1.00033	1.00031	1.00033	1.00027	
G.O.V. us gallons	244,368.52	2,245,550.08	186,211.23	415,715.21	
API 60°F	35.90	35.90	35.90	34.10	
V.C.F. 6B	0.98663	0.98799	0.98658	0.98945	
G.S.V. us gallons 60°F	241,101.31	2,218,581.02	183,712.28	411,329.41	
Table 8 MPMS 11.5.1.4.4	7.038315542	7.038315542	7.038315542	7.114927771	
Pounds	1,696,947.10	15,615,073.27	1,293,025.00	2,926,579.04	
Subtotals					
G.S.V. us gallons 60°F	3,054,724.02	241,101.31	2,218,581.02	183,712.28	411,329.41
Pounds	21,531,624.41	1,696,947.10	15,615,073.27	1,293,025.00	2,926,579.04

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.4.

Net calculation via S&W% (API MPMS 12.1)

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 MAY-TANKINV-5-31-26



Job No 13101/00018805.0000/01/1/26
 Report date 02 Jun 2026
 Installation Mayagüez, Puerto Rico, PREPA Mayagüez Turbine Power Block

Shore tank End of Month Inventory Mayaguez for 5-31-26
Product NO2

Shore Tank Inventory Subtotals

Survey date: 31-May-2026

Shore tank Subtotals	Totals	D-3	D-1	D-2	D-4
Gross Standard Volume					
Cu m 60°F	11,563.390	912.668	8,398.244	695.426	1,557.052
Barrels 60°F	72,731.53	5,740.51	52,823.36	4,374.10	9,793.56
US Gallons 60°F	3,054,724.02	241,101.31	2,218,581.02	183,712.28	411,329.41
Metric Tons Vac	9,778.976	770.701	7,091.882	587.252	1,329.141
Metric Tons Air	9,766.579	769.722	7,082.877	586.506	1,327.474
Long Tons Air	9,612.333	757.566	6,971.015	577.243	1,306.509
Short Tons Air	10,765.814	848.474	7,807.537	646.513	1,463.290
Pounds Air	21,531,624.41	1,696,947.10	15,615,073.27	1,293,025.00	2,926,579.04
Density 15°C		0.8449	0.8449	0.8449	0.8540
API 60°F		35.90	35.90	35.90	34.10
RD 60/60°F		0.8453	0.8453	0.8453	0.8545
Total Calculated Volume					
Barrels 60°F	73,275.86	5,744.49	53,356.57	4,381.24	9,793.56
US Gallons 60°F	3,077,585.84	241,268.31	2,240,975.84	184,012.28	411,329.41

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 MAY-TANKINV-5-31-26



Job No 13101/00018805.0000/01/1/26
 Report date 02 Jun 2026
 Installation Mayagüez, Puerto Rico, PREPA Mayagüez Turbine Power Block

Shore tank End of Month Inventory Mayaguez for 5-31-26
Product NO2

Survey date: 31 May 2026

Certificate of Quantity

The undersigned Independent Saybolt Surveyor herewith declares that the quantity of product measured amounts to:

	Gross	Net
Cubic meters 60°F	11,563.390	11,563.390
Barrels 60°F	72,731.53	72,731.53
US Gallons 60°F	3,054,724.02	3,054,724.02
Metric Tons vac	9,778.976	9,778.976
Metric Tons air	9,766.579	9,766.579
Long Tons	9,612.333	9,612.333
Short Tons	10,765.814	10,765.814
Pounds	21,531,624.41	21,531,624.41

These quantities have been determined by Shore tank measurements taken by Manual measurements.

B/L API 60°F	35.66
B/L Density 15°C	0.8461
B/L Density 20°C	0.8426
B/L RD 60/60°F	0.8465

Criteria used

US Barrels 60°F to Cu m 60°F	MPMS 11.5 - Annex D	0.158987304
US Barrels 60°F to US Gallons 60°F	MPMS 11.5 - Annex D	42
Metric Tons Air to Metric Tons Vac	MPMS 11.5.3 - 4.5	1.001269255
Pounds to Metric Tons Air	MPMS 11.5 - Annex D	453.59237
Pounds to Long Tons	MPMS 11.5 - Annex D	2,240
Pounds to Short Tons	MPMS 11.5 - Annex D	2,000

Remark

Net via S&W Volume %

Signed by: Saybolt representative
 Name:
 Rank: Saybolt Inspector

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

Handled by: Rafael Rodriguez
 Saybolt LP, Route 127 Km 11.7 Magas Arriba, 00656 Guayanilla, Puerto Rico
 Tel. 1-787-835-4784 FAX
 Website: www.saybolt.com E-mail: abizayd.arzola@corelab.com

Date: 02 Jun 2026 16:13
 Page 5 of 9

All our activities are carried out under Saybolt's terms and conditions, available at www.corelab.com/saybolt/terms-conditions

SAIL4 COQ V4.1.9.14 20240227

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 MAY-TANKINV-5-31-26



Job No 13101/00018805.0000/01/1/26
 Report date 02 Jun 2026
 Installation Mayagüez, Puerto Rico, PREPA Mayagüez Turbine Power Block

Shore tank End of Month Inventory Mayaguez for 5-31-26
Product NO2

Survey date: 31-May-2026

Shore Tank Measurement Details

Shore tank D-1

Measurement data (Innage)		Open	Close
Average	FT/IN	16 00-1/4	
Temperature			
Average temp.	°F	85.7	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53409	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-03838	
Tank calibration table		valid from 08 Apr 2006	
Tank Calibration table nr.		D-1	
Inspector equipment used for verification?		Yes	
Inspector name		A Arzola	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

Handled by: Rafael Rodriguez
 Saybolt LP, Route 127 Km 11.7 Magas Arriba, 00656 Guayanilla, Puerto Rico
 Tel. 1-787-835-4784 FAX
 Website: www.saybolt.com E-mail: abizayd.arzola@corelab.com
 All our activities are carried out under Saybolt's terms and conditions, available at www.corelab.com/saybolt/terms-conditions
SAIL4 STD V4.3.0.0 2026/01/27

Date: 02 Jun 2026 16:13
 Page 6 of 9

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 MAY-TANKINV-5-31-26



Job No 13101/00018805.0000/01/1/26
 Report date 02 Jun 2026
 Installation Mayagüez, Puerto Rico, PREPA Mayagüez Turbine Power Block

Shore tank End of Month Inventory Mayaguez for 5-31-26
Product NO2

Survey date: 31-May-2026

Shore Tank Measurement Details

Shore tank D-2

Measurement data (Innage)		Open	Close
Average	FT/IN	25 10-3/4	
Temperature			
Average temp.	°F	88.7	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment number		53409	
Temperature equipment number		TP9-03838	
Tank Calibration table nr.		D-2	
Inspector equipment used for verification?		Yes	
Inspector name		A Arzola	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 MAY-TANKINV-5-31-26



Job No 13101/00018805.0000/01/1/26
 Report date 02 Jun 2026
 Installation Mayagüez, Puerto Rico, PREPA Mayagüez Turbine Power Block

Shore tank End of Month Inventory Mayaguez for 5-31-26
Product NO2

Survey date: 31-May-2026

Shore Tank Measurement Details

Shore tank D-3

Measurement data (Innage)		Open	Close
Average	FT/IN	30 05-5/16	
Temperature			
Average temp.	°F	88.6	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53409	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-03838	
Tank Calibration table nr.		D-3	
Inspector equipment used for verification?		Yes	
Inspector name		A Arzola	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol.com. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 MAY-TANKINV-5-31-26



Job No 13101/00018805.0000/01/1/26
 Report date 02 Jun 2026
 Installation Mayagüez, Puerto Rico, PREPA Mayagüez Turbine Power Block

Shore tank End of Month Inventory Mayaguez for 5-31-26
Product NO2

Survey date: 31-May-2026

Shore Tank Measurement Details

Shore tank D-4

Measurement data (Innage)		Open	Close
Average	FT/IN	12 06-7/8	
Temperature			
Average temp.	°F	82.9	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment number		53409	
Temperature equipment number		TP9-03838	
Tank Calibration table nr.		D-4	
Inspector equipment used for verification?		Yes	
Inspector name		A Arzola	

All manual gauges, temp. and samples in accordance with API MPMS Ch. 3 for Manual Gauging, Ch. 7 for Temperature Measurement, Ch. 8 for Sampling, Ch. 12 for Calculations and Ch. 17 for Marine Measurement. Vol corr. for temp. based on ASTM D 1250 or terminal/customer supplied tables, for which Saybolt can assume no responsibility. All Saybolt measurement devices and methods used for quantity and quality determination meet the pertinent requirements of 40 CFR 99.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule)