

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
YB-TANKINV-5-31-26

Digitally Generated by : Saybolt
Reason : Reporting
Location : 13101 Saybolt Puerto Rico - All Activity
Date : 2026.06.02 14:41:22 -04:00



Job No 13101/00018806.0000/01/1/26
Report date 02 Jun 2026
Installation Yabucoa, Puerto Rico, PREPA Yabucoa Turbine Power Block

Shore tank End of Month Inventory Yabucoa for 5-31-26
Product NO2

Survey date: 31-May-2026

Contents page

Saybolt LP (Puerto Rico) has performed a survey and the findings of the survey are reflected in the following reports:

Title	Number of Pages
Contents page	one
Time Log	one
Shore Tank Inventory Report	one
Shore Tank Measurement Details	two
Shore Tank Inventory Subtotals	one
Certificate of Quantity	one

This report consists of 7 pages.

A copy of this report and all field documents and related correspondence will be retained for a period of 10 years, unless local law requires otherwise

Handled by: Rafael Rodriguez

This report reflects only the findings at the time and place of the inspection and testing. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions.

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
YB-TANKINV-5-31-26



Job No 13101/00018806.0000/01/1/26
Report date 02 Jun 2026
Installation Yabucoa, Puerto Rico, PREPA Yabucoa Turbine Power Block

Shore tank End of Month Inventory Yabucoa for 5-31-26
Product NO2

Survey date: 31-May-2026

Time Log

31 May 2026 (Sunday)	
14:00	Saybolt arrived at Installation/Destination
14:10	COMMENCED STOCK MEASUREMENT
16:20	COMPLETED STOCK MEASUREMENT
01 Jun 2026 (Monday)	
16:40	Documents Signed

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 YB-TANKINV-5-31-26



Job No 13101/00018806.0000/01/1/26
 Report date 02 Jun 2026
 Installation Yabucoa, Puerto Rico, PREPA Yabucoa Turbine Power Block

Shore tank End of Month Inventory Yabucoa for 5-31-26
Product NO2

Shore Tank Inventory Report

Survey date: 31-May-2026

Shore tank measurement		Totals	D-3	D-1
Open measurement				
Date/time of measurement		31 May 2026 16:10	31 May 2026 16:20	
Average Innage	FT/IN	25 10-3/8	36 3-11/16	
Average temp.	°F	85.5	85.4	
T.O.V.	Barrels	9,021.07	6,202.24	
Free Water				Traces
Water	FT/IN	00 00-3/4		
Water	Barrels	12.26		
Ambient temp.	°F	87.00	87.00	
Tank shell temp.	°F	86.00	86.00	
CTsh		1.00032	1.00032	
G.O.V.	Barrels	9,011.69	6,204.22	
API 60°F		32.00	32.00	
V.C.F.	6B	0.98845	0.98849	
G.S.V.	barrels 60°F	8,907.60	6,132.81	
W.C.F.	MPMS 11.5.1.4.12	0.1351207637	0.1351207637	
W.C.F.	MPMS 11.5.1.4.15	0.1372890342	0.1372890342	
Long Tons		1,203.602	828.670	
Metric Tons Air		1,222.916	841.968	
Subtotals				
G.S.V.	barrels 60°F	15,040.41	8,907.60	6,132.81
Long Tons		2,032.272	1,203.602	828.670

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via sediments and water vol% and dens. (ISO 9403:2000(E))

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 YB-TANKINV-5-31-26



Job No 13101/00018806.0000/01/1/26
 Report date 02 Jun 2026
 Installation Yabucoa, Puerto Rico, PREPA Yabucoa Turbine Power Block

Shore tank End of Month Inventory Yabucoa for 5-31-26
Product NO2

Survey date: 31-May-2026

Shore Tank Measurement Details

Shore tank D-1

Measurement data (Innage)		Open	Close
Average	FT/IN	36 3-11/16	
Temperature			
Average temp.	°F	85.4	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53408	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		9-01699	
Tank calibration table		valid from 10 Mar 2005	
Tank Calibration table nr.		D-1	
Inspector equipment used for verification?		Yes	
Inspector name		EDWINHERNANDEZ	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 YB-TANKINV-5-31-26



Job No 13101/00018806.0000/01//26
 Report date 02 Jun 2026
 Installation Yabucoa, Puerto Rico, PREPA Yabucoa Turbine Power Block

Shore tank End of Month Inventory Yabucoa for 5-31-26
Product NO2

Survey date: 31-May-2026

Shore Tank Measurement Details

Shore tank D-3

Measurement data (Innage)		Open	Close
Average	FT/IN	25 10-3/8	
Temperature			
Average temp.	°F	85.5	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53408	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		9-01699	
Tank calibration table		valid from 02 Sep 2005	
Tank Calibration table nr.		D-3	
Inspector equipment used for verification?		Yes	
Inspector name		EDWIN HERNANDEZ	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 YB-TANKINV-5-31-26



Job No 13101/00018806.0000/01/1/26
 Report date 02 Jun 2026
 Installation Yabucoa, Puerto Rico, PREPA Yabucoa Turbine Power Block

Shore tank End of Month Inventory Yabucoa for 5-31-26
Product NO2

Survey date: 31-May-2026

Shore Tank Inventory Subtotals

Shore tank Subtotals	Totals	D-3	D-1
Gross Standard Volume			
Cu m 60°F	2,391.234	1,416.195	975.039
Barrels 60°F	15,040.41	8,907.60	6,132.81
US Gallons 60°F	631,697.22	374,119.20	257,578.02
Metric Tons Vac	2,067.441	1,224.430	843.011
Metric Tons Air	2,064.884	1,222.916	841.968
Long Tons Air	2,032.272	1,203.602	828.670
Short Tons Air	2,276.144	1,348.034	928.110
Pounds Air	4,552,288.00	2,696,068.00	1,856,220.00
Density 15°C		0.8650	0.8650
API 60°F		32.00	32.00
RD 60/60°F		0.8654	0.8654
Total Calculated Volume			
Barrels 60°F	15,052.67	8,919.86	6,132.81
US Gallons 60°F	632,212.14	374,634.12	257,578.02

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 YB-TANKINV-5-31-26



Job No 13101/00018806.0000/01/1/26
 Report date 02 Jun 2026
 Installation Yabucoa, Puerto Rico, PREPA Yabucoa Turbine Power Block

Shore tank End of Month Inventory Yabucoa for 5-31-26
Product NO2

Survey date: 31 May 2026

Certificate of Quantity

The undersigned Independent Saybolt Surveyor herewith declares that the quantity of product measured amounts to:

	Gross	Net
Cubic meters 60°F	2,391.234	2,391.234
Barrels 60°F	15,040.41	15,040.41
US Gallons 60°F	631,697.22	631,697.22
Metric Tons vac	2,067.441	2,067.441
Metric Tons air	2,064.884	2,064.884
Long Tons	2,032.272	2,032.272
Short Tons	2,276.144	2,276.144
Pounds	4,552,288.00	4,552,288.00

These quantities have been determined by Shore tank measurements taken by Manual measurements.

B/L API 60°F	32.00
B/L Density 15°C	0.8650
B/L Density 20°C	0.8615
B/L RD 60/60°F	0.8654

Criteria used

US Barrels 60°F to Cu m 60°F	MPMS 11.5 - Annex D	0.158987304
US Barrels 60°F to US Gallons 60°F	MPMS 11.5 - Annex D	42
Metric Tons Air to Metric Tons Vac	MPMS 11.5.3 - 4.5	1.001238204
Barrels 60°F to Metric Tons Air	MPMS 11.5.1 - 4.15	0.1372890342
Barrels 60°F to Long Tons	MPMS 11.5.1 - 4.12	0.1351207637
Long Tons to Short Tons	MPMS 11.5 - Annex D	1.12

Remark

Net via sediment density and water density

Signed by: Saybolt representative
 Name:
 Rank: Saybolt Inspector