

**GOVERNMENT OF PUERTO RICO
PUERTO RICO PUBLIC SERVICE REGULATORY BOARD
PUERTO RICO ENERGY BUREAU**

IN RE: REVIEW OF GENERA PR, LLC
REQUEST TO OPERATE PALO SECO MP
AND MAYAGÜEZ CT WITH NATURAL GAS
AS PRIMARY FUEL

CASE NO.: NEPR-MI-2024-0004

SUBJECT: Resolution and Order for the four
(4) Pratt & Whitney FT8 Swift Pac units
located at the Mayagüez Power Plant .

RESOLUTION AND ORDER

The Puerto Rico Electric Power Authority (“PREPA”) owns four (4) Pratt & Whitney FT8 Swift Pac, dual-fuel capable combustion units installed at the Mayagüez Power Plant in Mayagüez (“Mayagüez CT”) with a nameplate capacity of 55MW each for a total nameplate capacity of 220 MW. These units are used as part of the peakers fleet whenever there is a sudden increase in power demand that cannot be satisfied by the power generation of the base generation fleet. Genera PR, LLC (“Genera”) operates these units in accordance with the Generation OMA¹.

On January 31, 2025, following a comprehensive evaluation of Genera’s natural gas conversion proposal, the Energy Bureau of the Puerto Rico Public Service Regulatory Board (“Energy Bureau”) issued a Resolution and Order (“January 31 Resolution”) conditionally approving the conversion Mayagüez CTs to dual-fuel operation, allowing them to run on ultra-low sulfur diesel (“ULSD”) and natural gas (“NG”).² The approval was subject to several conditions intended to preserve competition in the natural gas market, safeguard eligibility for federal funding, establish appropriate ownership arrangements for the conversion and regasification infrastructure, and ensure that the project would ultimately benefit PREPA and its ratepayers.³

LUMA’s Monthly Generation Performance Report shows the available capacity and plant availability rate of the base load units and peaker units. The plant availability rate indicates the percent of available capacity out of the total nameplate capacity. The latest report published on September 15, 2026, indicates that the Mayagüez Power Plant has been having an availability rate of less than 40% on average.

The purpose of this Resolution and Order is to obtain information regarding the maintenance, repairs, reliability, condition and contractual arrangements, of the four (4) Pratt & Whitney FT8 Swift Pac. The requested information is intended to provide a complete understanding of the actions taken by Genera to repair the units and to identify the causes of outages, recurring problems, maintenance requirements, and any outstanding warranty or contractual issues.

Genera **SHALL** file, within **five (5) business days** from the notification of this Resolution and Order, a status report that shall identify, describe, and explain, as applicable:

- (i) the actions undertaken by Genera to repair the units at the Mayaguez CTs, including any procurement, including quotations obtained by supplier representatives, manufacturer or third-party vendors to repair the Pratt & Whitney FT8 Swift Pac units;

¹ *The Puerto Rico Thermal Generation Facilities Operation and Maintenance Agreement* (the “Generation OMA”), January 24, 2023

² See *Request for Leave to Operate Palo Seco MP and Mayagüez CT with Natural Gas as the Primary Fuel* filed by Genera on February 21, 2024 (“February 21 Motion”).


³ See January 31 Resolution, pp. 15-16.




- (ii) any evaluation of the procurement process undertaken by Genera, the conclusions reached in regards to any quotations recieved, and, if no such evaluation has been undertaken, the reasons therefor;
- (iii) any and all communications between Genera and supplier representatives, and/or the manufacturer of the Pratt & Whitney FT8 Swift Pac units;
- (iv) any agreement of exclusive representation in Puerto Rico by the manufacturer if such supplier representative is being used.

The Energy Bureau **WARNS** Genera that, in accordance with Art. 6.36 of Act 57-2014, non-compliance with this Resolution and Order may carry the imposition of fines.

Be it notified and published.



Edison Aviles Deliz
Chairman



Antonio Torres Miranda
Associate Commissioner



Omar M. Rodriguez González
Associate Commissioner

CERTIFICATION

I certify that the majority of the members of the Puerto Rico Energy Bureau agreed on September 30, 2026. Associate Commissioners Ferdinand A. Ramos Soegaard and Sylvia B. Ugarte Araujo did not intervene. Also certify that on September 30, 2026. I have proceeded with the filing of this Resolution and was notified by email to: alexis.rivera@prepa.pr.gov; rcruzfranqui@gmlex.net; mvalle@gmlex.net; nzayas@gmlex.net; jfernandez@ecija.com; jdiaz@ecija.com; eramos@ecija.com; legal@genera-pr.com; regulatory@genera-pr.com.

I sign this in San Juan, Puerto Rico, today September 30, 2026.



Sonia Seda Gaztambide
Clerk

