



Field Inspection Report

Cargo Operation: Inventory

Vessel(s)

Product(s)

ULSD

Client(s)

Autoridad De Energia Electrica De Puerto Rico

Reference #

CAM-TANKINV-8-31-26

Location(s)

Arecibo | Genera PR

All measurements contained in this report were performed according to the API manual of petroleum measurement standards:

Chapter 3 Tank Gauging; Chapter 7 Temperature Determination; Chapter 8 Sampling; Chapter 12 Calculation of Petroleum Quantities; Chapter 17 Marine Measurement.

All Bureau Veritas measurement devices and methods used for quantity and quality determination meet pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule).

All Operations to be carried out in accordance with Bureau Veritas Commodities Division General Conditions of Service (2014 Edition). An electronic version can also be viewed on our company website:
www.bureauveritas.com/terms_and_conditions/index.asp

Reinaldo LUGO
Bureau Veritas Commodities and Trade, Inc

Table of Contents

Shore Tanks Measurements - ULSD

1

Q. B.

Job #: PRPUE-26-00326-1

Date: 31-Aug-2026

Location(s): Arecibo - Genera PR

Vessel(s): Inventory

Product(s): ULSD

Client(s): Autoridad De Energia Electrica De Puerto Rico-CAM-TANKINV-8-31-26

Shore Tanks Measurements

BUREAU
VERITAS

D-1	Crit Zone	Phase	Date/Time	Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
		Open	01-Sep-2026 00:00	N/A	78.0	1.00002	1.03		6B-60°F	
		Close		N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels
Open	25-3	51,802.60	0-1 5/8	199.26	36.9	88.0	51,604.37	0.98681	50,923.71
Close									
Difference		51,802.60		199.26			51,604.37		50,923.71
Adjustments to GSV									50,923.71

D-3	Crit Zone	Phase	Date/Time	Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
		Open	31-Aug-2026 23:45	N/A	78.0	1.00000	0.00		6B-60°F	
		Close		N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels
Open	15-7 1/8	72,085.74	0-2 7/8	348.82	36.2	86.2	71,736.92	0.98773	70,856.71
Close									
Difference		72,085.74		348.82			71,736.92		70,856.71
Adjustments to GSV									70,856.71

Shore Summary						
API-60°F	Adjustments (Bbls)			Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV	To Water			
36.5						Kolor Kut

Shore Delivered	Shore Delivered	Total Calculated	Gross Standard
	Cubic Meters 15°C	19,439.540	19,352.444
	Barrels 60°F	122,328.50	121,780.42
	Gallons 60°F	5,137,797.00	5,114,777.64
	Pounds	36,032,105	35,870,667
	Long Tons	16,085.761	16,013.691
	MT (In Air)	16,343.888	16,270.661
	Free Water	548.08	

Density
API 60°F
36.5
Table 8 Lbs/Gal (In Air)
7.013142952
Table 11 LT/Bbl (In Air)
0.1314964304
Table 13 MT/Bbl (In Air)
0.1336065416
Table 13 MT/Bbl (In Vac)
0.1337771754

Date/Time

Date/Time

Reinaldo LUGO