

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
CS-TANKINV-8-31-2026

Digitally Generated by : Saybolt
Reason : Reporting
Location : 13101 Saybolt Puerto Rico - All Activity
Date : 2026.09.01 13:18:49 -04:00



Job No 13101/00018949.0000/01/I/26
Report date 01 Sep 2026
Installation Penuelas, Puerto Rico, Central Costa Sur

Shore tank End of Month Inventory 8-31-2026 / COSTA SUR
Product Fuel Oil NO 6, NO2 Fuel Oil

Survey date: 31-Aug-2026, 31-Aug-2026

Contents page

Saybolt LP (Puerto Rico) has performed a survey and the findings of the survey are reflected in the following reports:

Title	Number of Pages
Contents page	one
Time Log	one
Shore Tank Measurement Details	three
Shore Tank Inventory Report	two
Shore Tank Inventory Subtotals	two
Certificate of Quantity	two

This report consists of 11 pages.

A copy of this report and all field documents and related correspondence will be retained for a period of 10 years, unless local law requires otherwise

Handled by: Rafael Rodriguez

This report reflects only the findings at the time and place of the inspection and testing. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions.

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
CS-TANKINV-8-31-2026



Job No 13101/00018949.0000/01/I/26
Report date 01 Sep 2026
Installation Penuelas, Puerto Rico, Central Costa Sur

Shore tank End of Month Inventory 8-31-2026 / COSTA SUR
Product Fuel Oil NO 6, NO2 Fuel Oil

Survey date: 31-Aug-2026, 31-Aug-2026

Time Log

31 Aug 2026 (Monday)		
22:45		COMMENCED STOCK MEASUREMENT (Fuel Oil NO 6)
23:00		COMMENCED STOCK MEASUREMENT (NO2 Fuel Oil)
23:15		COMPLETED STOCK MEASUREMENT (Fuel Oil NO 6)
23:35		COMPLETED STOCK MEASUREMENT (NO2 Fuel Oil)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
CS-TANKINV-8-31-2026



Job No 13101/00018949.0000/01/I/26
Report date 01 Sep 2026
Installation Penuelas, Puerto Rico, Central Costa Sur

Shore tank End of Month Inventory 8-31-2026 / COSTA SUR
Product Fuel Oil NO 6

Survey date: 31-Aug-2026

Shore Tank Measurement Details

Shore tank R-2

Measurement data (Innage)		Open	Close
Average	FT/IN	05 07-1/8	
Temperature			
Average temp.	°F	99.4	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53313	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-05649	
Tank calibration table		valid from 19 Apr 2006	
Tank Calibration table nr.		R-2	
Inspector equipment used for verification?		Yes	
Inspector name		J.VELASQUEZ	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
CS-TANKINV-8-31-2026



Job No 13101/00018949.0000/01/I/26
Report date 01 Sep 2026
Installation Penuelas, Puerto Rico, Central Costa Sur

Shore tank End of Month Inventory 8-31-2026 / COSTA SUR
Product Fuel Oil NO 6

Survey date: 31-Aug-2026

Shore Tank Measurement Details

Shore tank R-3

Measurement data (Innage)		Open	Close
Average	FT/IN	07 02-5/8	
Temperature			
Average temp.	°F	95.8	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53313	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-05649	
Tank calibration table		valid from 11 Jun 2007	
Tank Calibration table nr.		R-3	
Inspector equipment used for verification?		Yes	
Inspector name		J.VELASQUEZ	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
CS-TANKINV-8-31-2026



Job No 13101/00018949.0000/01/I/26
Report date 01 Sep 2026
Installation Penuelas, Puerto Rico, Central Costa Sur

Shore tank End of Month Inventory 8-31-2026 / COSTA SUR
Product NO2 Fuel Oil

Survey date: 31-Aug-2026

Shore Tank Measurement Details

Shore tank TG-1

Measurement data (Innage)		Open	Close
Average	FT/IN	17 10-5/8	
Temperature			
Average temp.	°F	87.7	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53313	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9-05649	
Tank calibration table		valid from 06 May 1973	
Tank Calibration table nr.		TG-1	
Inspector equipment used for verification?		Yes	
Inspector name		J.VELASQUEZ	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 CS-TANKINV-8-31-2026



Job No 13101/00018949.0000/01/I/26
 Report date 01 Sep 2026
 Installation Penuelas, Puerto Rico, Central Costa Sur

Shore tank End of Month Inventory 8-31-2026 / COSTA SUR
Product Fuel Oil NO 6

Shore Tank Inventory Report

Survey date: 31-Aug-2026

Shore tank measurement		Totals	R-2	R-3
Open measurement				
Date/time of measurement		31 Aug 2026 22:45	31 Aug 2026 23:15	
Average Innage	FT/IN	05 07-1/8	07 02-5/8	
Average temp.	°F	99.4	95.8	
T.O.V.	Barrels	288,545.21	279,254.31	
Free Water		Not detected	Not detected	
Ambient temp.	°F	78.00	78.00	
Tank shell temp.	°F	97.00	94.00	
CTsh		1.00046	1.00042	
G.O.V.	Barrels	288,677.94	279,371.60	
API 60°F		16.90	16.40	
V.C.F.	6B	0.98424	0.98575	
G.S.V.	barrels 60°F	284,128.38	275,390.55	
W.C.F.	MPMS 11.5.1.4.12	0.1488886712	0.1493926481	
W.C.F.	MPMS 11.5.1.4.15	0.1512778741	0.1517899382	
Long Tons		42,303.497	41,141.324	
Metric Tons Air		42,982.337	41,801.515	
Subtotals				
G.S.V.	barrels 60°F	559,518.93	284,128.38	275,390.55
Long Tons		83,444.821	42,303.497	41,141.324

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 CS-TANKINV-8-31-2026



Job No 13101/00018949.0000/01/I/26
 Report date 01 Sep 2026
 Installation Penuelas, Puerto Rico, Central Costa Sur

Shore tank End of Month Inventory 8-31-2026 / COSTA SUR
Product NO2 Fuel Oil

Shore Tank Inventory Report

Survey date: 31-Aug-2026

Shore tank measurement		Totals	TG-1
Open measurement			
Date/time of measurement			31 Aug 2026 23:35
Average Innage	FT/IN		17 10-5/8
Average temp.	°F		87.7
T.O.V.	Barrels		3,062.64
Free Water			
Water	FT/IN		00 02-3/8
Water	Barrels		33.86
Ambient temp.	°F		78.00
Tank shell temp.	°F		86.00
CTsh			1.00032
G.O.V.	Barrels		3,029.75
API 60°F			34.60
V.C.F.	6B		0.98719
G.S.V.	barrels 60°F		2,990.94
W.C.F.	MPMS 11.5.1.4.12		0.1330027507
W.C.F.	MPMS 11.5.1.4.15		0.1351370337
Long Tons			397.803
Metric Tons Air			404.187
Subtotals			
G.S.V.	barrels 60°F	2,990.94	2,990.94
Long Tons		397.803	397.803

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 CS-TANKINV-8-31-2026



Job No 13101/00018949.0000/01/I/26
 Report date 01 Sep 2026
 Installation Penuelas, Puerto Rico, Central Costa Sur

Shore tank End of Month Inventory 8-31-2026 / COSTA SUR
Product Fuel Oil NO 6

Survey date: 31-Aug-2026

Shore Tank Inventory Subtotals

Shore tank Subtotals	Totals	R-2	R-3
Gross Standard Volume			
Cu m 60°F	88,956.406	45,172.805	43,783.601
Barrels 60°F	559,518.93	284,128.38	275,390.55
US Gallons 60°F	23,499,795.06	11,933,391.96	11,566,403.10
Metric Tons Vac	84,877.778	43,030.044	41,847.734
Metric Tons Air	84,783.852	42,982.337	41,801.515
Long Tons Air	83,444.821	42,303.497	41,141.324
Short Tons Air	93,458.200	47,379.917	46,078.283
Pounds Air	186,916,400.00	94,759,834.00	92,156,566.00
Density 15°C		0.9530	0.9562
API 60°F		16.90	16.40
RD 60/60°F		0.9535	0.9567
Total Calculated Volume			
Barrels 60°F	559,518.93	284,128.38	275,390.55
US Gallons 60°F	23,499,795.06	11,933,391.96	11,566,403.10

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 CS-TANKINV-8-31-2026



Job No 13101/00018949.0000/01/I/26
 Report date 01 Sep 2026
 Installation Penuelas, Puerto Rico, Central Costa Sur

Shore tank End of Month Inventory 8-31-2026 / COSTA SUR
Product NO2 Fuel Oil

Survey date: 31-Aug-2026

Shore Tank Inventory Subtotals

Shore tank Subtotals	Totals	TG-1
Gross Standard Volume		
Cu m 60°F	475.521	475.521
Barrels 60°F	2,990.94	2,990.94
US Gallons 60°F	125,619.48	125,619.48
Metric Tons Vac	404.696	404.696
Metric Tons Air	404.187	404.187
Long Tons Air	397.803	397.803
Short Tons Air	445.539	445.539
Pounds Air	891,078.00	891,078.00
Density 15°C		0.8515
API 60°F		34.60
RD 60/60°F		0.8519
Total Calculated Volume		
Barrels 60°F	3,024.80	3,024.80
US Gallons 60°F	127,041.60	127,041.60

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
CS-TANKINV-8-31-2026



Job No 13101/00018949.0000/01/I/26
Report date 01 Sep 2026
Installation Penuelas, Puerto Rico, Central Costa Sur

Shore tank End of Month Inventory 8-31-2026 / COSTA SUR
Product Fuel Oil NO 6

Survey date: 31 Aug 2026

Certificate of Quantity

The undersigned Independent Saybolt Surveyor herewith declares that the quantity of product measured amounts to:

	Gross	Net
Cubic meters 60°F	88,956.406	88,956.406
Barrels 60°F	559,518.93	559,518.93
US Gallons 60°F	23,499,795.06	23,499,795.06
Metric Tons vac	84,877.778	84,877.778
Metric Tons air	84,783.852	84,783.852
Long Tons	83,444.821	83,444.821
Short Tons	93,458.200	93,458.200
Pounds	186,916,400.00	186,916,400.00

These quantities have been determined by Shore tank measurements taken by Manual measurements.

B/L API 60°F	16.65
B/L Density 15°C	0.9546
B/L Density 20°C	0.9512
B/L RD 60/60°F	0.9551

Criteria used

US Barrels 60°F to Cu m 60°F	MPMS 11.5 - Annex D	0.158987304
US Barrels 60°F to US Gallons 60°F	MPMS 11.5 - Annex D	42
Metric Tons Air to Metric Tons Vac	MPMS 11.5.3 - 4.5	1.00110775
Barrels 60°F to Metric Tons Air	MPMS 11.5.1 - 4.15	0.1515334741
Barrels 60°F to Long Tons	MPMS 11.5.1 - 4.12	0.1491402344
Long Tons to Short Tons	MPMS 11.5 - Annex D	1.12

Remark

Net via S&W Volume %

Signed by: Saybolt representative

Name:

Rank: Saybolt Inspector

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 CS-TANKINV-8-31-2026



Job No 13101/00018949.0000/01/I/26
 Report date 01 Sep 2026
 Installation Penuelas, Puerto Rico, Central Costa Sur

Shore tank End of Month Inventory 8-31-2026 / COSTA SUR
Product NO2 Fuel Oil

Survey date: 31 Aug 2026

Certificate of Quantity

The undersigned Independent Saybolt Surveyor herewith declares that the quantity of product measured amounts to:

	Gross	Net
Cubic meters 60°F	475.521	475.521
Barrels 60°F	2,990.94	2,990.94
US Gallons 60°F	125,619.48	125,619.48
Metric Tons vac	404.696	404.696
Metric Tons air	404.187	404.187
Long Tons	397.803	397.803
Short Tons	445.539	445.539
Pounds	891,078.00	891,078.00

These quantities have been determined by Shore tank measurements taken by Manual measurements.

B/L API 60°F	34.60
B/L Density 15°C	0.8515
B/L Density 20°C	0.8480
B/L RD 60/60°F	0.8519

Criteria used

US Barrels 60°F to Cu m 60°F	MPMS 11.5 - Annex D	0.158987304
US Barrels 60°F to US Gallons 60°F	MPMS 11.5 - Annex D	42
Metric Tons Air to Metric Tons Vac	MPMS 11.5.3 - 4.5	1.001260242
Barrels 60°F to Metric Tons Air	MPMS 11.5.1 - 4.15	0.1351370337
Barrels 60°F to Long Tons	MPMS 11.5.1 - 4.12	0.1330027507
Long Tons to Short Tons	MPMS 11.5 - Annex D	1.12

Remark

Net via S&W Volume %

Signed by: Saybolt representative

Name:

Rank: Saybolt Inspector