

Puerto Rico
Firm Delivery Carr 127 Km 19.1

Job#: PRPUE-26-00328-1

Date: 31-Aug-2026



Field Inspection Report

Cargo Operation: Inventory

Vessel(s)

Inventory

Product(s)

ULSD

Client(s)

Autoridad De Energia Electrica De Puerto Rico

Reference #

JB-TANKINV-8-31-26

Location(s)

Guayama | Genera PR - Jobos

All measurements contained in this report were performed according to the API manual of petroleum measurement standards:

Chapter 3 Tank Gauging; Chapter 7 Temperature Determination; Chapter 8 Sampling; Chapter 12 Calculation of Petroleum Quantities; Chapter 17 Marine Measurement.

All Bureau Veritas measurement devices and methods used for quantity and quality determination meet pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule).

All Operations to be carried out in accordance with Bureau Veritas Commodities Division General Conditions of Service (2014 Edition). An electronic version can also be viewed on our company website:
www.bureauveritas.com/terms_and_conditions/index.asp

Reinaldo LUGO
Bureau Veritas Commodities and Trade, Inc

Table of Contents

Shore Tanks Measurements - ULSD

1

RJ

Job #: PRPUE-26-00328-1

Date: 31-Aug-2026

Location(s): Guayama - Genera PR - Jobs

Vessel(s): Inventory

Product(s): ULSD

Client(s): Autoridad De Energia Electrica De Puerto Rico-JB-TANKINV-8-31-26

BUREAU
VERITAS

S-1	Crit Zone	Phase	Date/Time	Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
		Open	31-Aug-2026 22:48	N/A	77.0	1.00027	0.06		6B-60°F	
		Close		N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels	
Open	2-8 5/8	224.69	0-1	1.55	35.0	82.7	223.20	0.98947	220.85	
Close										
Difference		224.69		1.55			223.20		220.85	
Adjustments to GSV									220.85	

S-2	Crit Zone	Phase	Date/Time	Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
		Open	31-Aug-2026 23:00	N/A	77.0	1.00033	2.10		6B-60°F	
		Close		N/A					6B-60°F	
Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels	
Open	18-3 3/4	6,395.10	0-0 3/4	24.24	35.0	88.9	6,372.96	0.98659	6,287.50	
Close										
Difference		6,395.10		24.24			6,372.96		6,287.50	
Adjustments to GSV									6,287.50	

Shore Summary						
API-60°F	Adjustments (Bbls)			Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV	To Water			
35.0						KOLOR KUT
Shore Delivered	Shore Delivered	Total Calculated	Gross Standard			Density
	Cubic Meters 15°C	1,038.368	1,034.270			API 60°F
	Barrels 60°F	6,534.14	6,508.35			35.0
	Gallons 60°F	274,433.88	273,350.70			Table 8 Lbs/Gal (In Air)
	Pounds	1,942,008	1,934,343			7.076414596
	Long Tons	866.968	863.546			Table 11 LT/Bbl (In Air)
	MT (In Air)	880.880	877.403			0.1326827737
	Free Water	25.79				Table 13 MT/Bbl (In Air)
						0.1348119220
						Table 13 MT/Bbl (In Vac)
						0.1349823752

Date/Time

Date/Time

Reinaldo LUGO