

Puerto Rico
Firm Delivery Carr 127 Km 19.1

Job#: PRPUE-26-00327-1

Date: 31-Aug-2026



Field Inspection Report

Cargo Operation: Inventory

Vessel(s)

Inventory

Product(s)

ULSD

Client(s)

Autoridad De Energia Electrica De Puerto Rico

Reference #

MAY-TANKINV-8-31-26

Location(s)

Mayaguez | Genera PR

All measurements contained in this report were performed according to the API manual of petroleum measurement standards:

Chapter 3 Tank Gauging; Chapter 7 Temperature Determination; Chapter 8 Sampling; Chapter 12 Calculation of Petroleum Quantities; Chapter 17 Marine Measurement.

All Bureau Veritas measurement devices and methods used for quantity and quality determination meet pertinent requirements of 40 CFR 98.3 et. Seq. (Greenhouse Gas Mandatory Reporting Rule).

All Operations to be carried out in accordance with Bureau Veritas Commodities Division General Conditions of Service (2014 Edition). An electronic version can also be viewed on our company website:
www.bureauveritas.com/terms_and_conditions/index.asp

Reinaldo LUGO
Bureau Veritas Commodities and Trade, Inc

Table of Contents

Shore Tanks Measurements - ULSD

1

RB

Job #: PRPUE-26-00327-1

Date: 31-Aug-2026

Location(s): Mayaguez - Genera PR

Vessel(s): Inventory

Product(s): ULSD

Client(s): Autoridad De Energia Electrica De Puerto Rico-MAY-TANKINV-8-31-26

Shore Tanks Measurements

BUREAU
VERITAS

R-1	Crit Zone	Phase	Date/Time	Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
		Open	31-Aug-2026 22:20	N/A	80.0	1.00036	18.75		6B-60°F	
		Close		N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels
Open	16-9 7/8	52,624.76	0-4 3/8	533.77	37.4	89.8	52,109.74	0.98589	51,374.47
Close									
Difference		52,624.76		533.77			52,109.74		51,374.47

Adjustments to GSV

51,374.47

S-2	Crit Zone	Phase	Date/Time	Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
		Open	31-Aug-2026 23:58	N/A	80.0	1.00035	1.58		6B-60°F	
		Close		N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels
Open	26-3	4,500.00	0-0	0.00	38.4	89.3	4,501.58	0.98596	4,438.38
Close									
Difference		4,500.00		0.00			4,501.58		4,438.38

Adjustments to GSV

4,438.38

S-3	Crit Zone	Phase	Date/Time	Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
		Open	31-Aug-2026 23:50	N/A	80.0	1.00035	1.85		6B-60°F	
		Close		N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels
Open	27-8 7/8	5,303.59	0-0 1/2	7.96	38.4	89.3	5,297.48	0.98596	5,223.10
Close									
Difference		5,303.59		7.96			5,297.48		5,223.10

Adjustments to GSV

5,223.10

S-4	Crit Zone	Phase	Date/Time	Roof Adj	Amb °F	CTSh Factor	CTSh Bbls	Lines Adj	VCF Table	CoE
		Open	31-Aug-2026 22:45	N/A	80.0	1.00031	2.78		6B-60°F	
		Close		N/A					6B-60°F	

Operation Phase	Gauge ft	TOV Barrels	FW Gauge ft	FW Barrels	API-60°F	Temp °F	GOV Barrels	VCF 60°F	GSV Barrels
Open	15-6 1/2	8,977.86	0-0	0.00	37.1	85.9	8,980.64	0.98778	8,870.90
Close									
Difference		8,977.86		0.00			8,980.64		8,870.90

Adjustments to GSV

8,870.90

Shore Summary

API-60°F	Adjustments (Bbls)			Condition of Shore Lines	Method of Verification	Water Paste Used
	For Meters to GSV	For Lines to GSV	To Water			

37.8

KOLOR KUT

Shore Delivered	Shore Delivered	Total Calculated	Gross Standard
	Cubic Meters 15°C	11,195.167	11,109.080
	Barrels 60°F	70,448.58	69,906.85
	Gallons 60°F	2,958,840.36	2,936,087.70
	Pounds	20,591,205	20,432,864
	Long Tons	9,192.502	9,121.814
	MT (In Air)	9,340.013	9,268.191
	Free Water	541.73	

Density

API 60°F

37.8

Table 8 Lbs/Gal (In Air)

6.959214433

Table 11 LT/Bbl (In Air)

0.1304852706

Table 13 MT/Bbl (In Air)

0.1325791558

Table 13 MT/Bbl (In Vac)

0.1327499437

Date/Time

Date/Time

Reinaldo LUGO