

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
SJ-TANKINV-8-31-2026

Digitally Generated by : Saybolt
Reason : Reporting
Location : 13101 Saybolt Puerto Rico - All Activity
Date : 2026.09.01 14:23:37 -04:00



Job No 13101/00018948.0000/01/I/26
Report date 01 Sep 2026
Installation San Juan, Puerto Rico, Central San Juan Terminal

Shore tank End of Month Inventory 8-31-2026 / Central San Juan
Product Fuel Oil NO 6, NO2 Fuel Oil

Survey date: 31-Aug-2026, 31-Aug-2026

Contents page

Saybolt LP (Puerto Rico) has performed a survey and the findings of the survey are reflected in the following reports:

Title	Number of Pages
Contents page	one
Shore Tank Inventory Report	three
Shore Tank Measurement Details	eight
Shore Tank Inventory Subtotals	three
Certificate of Quantity	two

This report consists of 17 pages.

A copy of this report and all field documents and related correspondence will be retained for a period of 10 years, unless local law requires otherwise

Handled by: Rafael Rodriguez

This report reflects only the findings at the time and place of the inspection and testing. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions.

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 SJ-TANKINV-8-31-2026



Job No 13101/00018948.0000/01/I/26
 Report date 01 Sep 2026
 Installation San Juan, Puerto Rico, Central San Juan Terminal

Shore tank End of Month Inventory 8-31-2026 / Central San Juan
Product Fuel Oil NO 6

Survey date: 31-Aug-2026

Shore Tank Inventory Report - 1

Shore tank measurement		Totals	R-1	R-2	R-4	S-7
Open measurement						
Date/time of measurement		31 Aug 2026 22:30	31 Aug 2026 23:30	31 Aug 2026 23:10	31 Aug 2026 23:50	
Average Innage	FT/IN	26 10-5/8	27 01-5/8	00 05-3/8	15 02-3/4	
Average temp.	°F	97.0	104.6	88.8	91.0	
T.O.V.	Barrels	46,295.38	46,737.48	1,399.41	2,412.77	
Free Water		Not detected	Not detected	Not detected	Not detected	
Ambient temp.	°F	81.00	81.00	81.00	81.00	
Tank shell temp.	°F	95.00	102.00	88.00	90.00	
CTsh		1.00043	1.00052	1.00035	1.00037	
G.O.V.	Barrels	46,315.29	46,761.78	1,399.90	2,413.66	
API 60°F		16.90	17.00	18.70	14.20	
V.C.F.	6B	0.98521	0.98214	0.98831	0.98790	
G.S.V.	barrels 60°F	45,630.29	45,926.61	1,383.54	2,384.45	
W.C.F.	MPMS 11.5.1.4.12	0.1488886712	0.1487882831	0.1471021371	0.1516512391	
W.C.F.	MPMS 11.5.1.4.15	0.1512778741	0.1511758751	0.1494626716	0.1540847727	
Long Tons		6,793.833	6,833.341	203.522	361.605	
Metric Tons Air		6,902.853	6,942.995	206.788	367.407	
Subtotals						
G.S.V.	barrels 60°F	101,662.82	45,630.29	45,926.61	1,383.54	2,384.45
Long Tons		15,153.456	6,793.833	6,833.341	203.522	361.605

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
SJ-TANKINV-8-31-2026



Job No 13101/00018948.0000/01/I/26
Report date 01 Sep 2026
Installation San Juan, Puerto Rico, Central San Juan Terminal

Shore tank End of Month Inventory 8-31-2026 / Central San Juan
Product Fuel Oil NO 6

Survey date: 31-Aug-2026

Shore Tank Inventory Report - 2

Shore tank measurement		S-8	S-10
Open measurement			
Date/time of measurement		31 Aug 2026 23:15	31 Aug 2026 23:50
Average Innage	FT/IN	15 02-3/4	23 04-13/16
Average temp.	°F	90.4	106.4
T.O.V.	Barrels	2,429.50	4,006.99
Free Water		Not detected	Not detected
Ambient temp.	°F	81.00	81.00
Tank shell temp.	°F	89.00	103.00
CTsh		1.00036	1.00053
G.O.V.	Barrels	2,430.37	4,009.11
API 60°F		14.20	14.20
V.C.F.	6B	0.98814	0.98186
G.S.V.	barrels 60°F	2,401.55	3,936.38
W.C.F.	MPMS 11.5.1.4.12	0.1516512391	0.1516512391
W.C.F.	MPMS 11.5.1.4.15	0.1540847727	0.1540847727
Long Tons		364.198	596.957
Metric Tons Air		370.042	606.536
Subtotals			
G.S.V.	barrels 60°F	2,401.55	3,936.38
Long Tons		364.198	596.957

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 SJ-TANKINV-8-31-2026



Job No 13101/00018948.0000/01/I/26
 Report date 01 Sep 2026
 Installation San Juan, Puerto Rico, Central San Juan Terminal

Shore tank End of Month Inventory 8-31-2026 / Central San Juan
Product NO2 Fuel Oil

Survey date: 31-Aug-2026

Shore Tank Inventory Report

Shore tank measurement		Totals	D-5	D-6
Open measurement				
Date/time of measurement		31 Aug 2026 22:45	31 Aug 2026 22:45	
Average Innage	FT/IN	36 01-7/16	21 02-3/4	
Average temp.	°F	91.4	90.4	
T.O.V.	Barrels	37,292.74	21,862.55	
Free Water				
Water	FT/IN	00 05-1/8	00 05-1/4	
Water	Barrels	305.47	359.70	
Ambient temp.	°F	81.00	81.00	
Tank shell temp.	°F	90.00	89.00	
CTsh		1.00006	1.00005	
G.O.V.	Barrels	36,989.49	21,503.93	
API 60°F		37.20	36.70	
V.C.F.	6B	0.98516	0.98570	
G.S.V.	barrels 60°F	36,440.57	21,196.42	
W.C.F.	MPMS 11.5.1.4.12	0.1309500233	0.1313398500	
W.C.F.	MPMS 11.5.1.4.15	0.1330513663	0.1334474485	
Long Tons		4,771.893	2,783.935	
Metric Tons Air		4,848.468	2,828.608	
Subtotals				
G.S.V.	barrels 60°F	57,636.99	36,440.57	21,196.42
Long Tons		7,555.828	4,771.893	2,783.935

Remarks

Tables used: 6B and W.C.F. MPMS 11.5.1.4.12.

Net calculation via S&W% (API MPMS 12.1)

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
SJ-TANKINV-8-31-2026



Job No 13101/00018948.0000/01/I/26
Report date 01 Sep 2026
Installation San Juan, Puerto Rico, Central San Juan Terminal

Shore tank End of Month Inventory 8-31-2026 / Central San Juan
Product Fuel Oil NO 6

Survey date: 31-Aug-2026

Shore Tank Measurement Details

Shore tank R-1

Measurement data (Innage)		Open	Close
Average	FT/IN	26 10-5/8	
Temperature			
Average temp.	°F	97.0	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53315	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9A-9772	
Tank calibration table		valid from 19 Nov 2003	
Tank Calibration table nr.		R-1	
Inspector equipment used for verification?		No	
Inspector name		Hector Lopez	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 SJ-TANKINV-8-31-2026



Job No 13101/00018948.0000/01/I/26
 Report date 01 Sep 2026
 Installation San Juan, Puerto Rico, Central San Juan Terminal

Shore tank End of Month Inventory 8-31-2026 / Central San Juan
Product Fuel Oil NO 6

Survey date: 31-Aug-2026

Shore Tank Measurement Details

Shore tank R-2

Measurement data (Innage)		Open	Close
Average	FT/IN	27 01-5/8	
Temperature			
Average temp.	°F	104.6	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53314	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP8-1930	
Tank calibration table		valid from 20 Dec 2002	
Tank Calibration table nr.		R-2	
Inspector equipment used for verification?		No	
Inspector name		Jose Flores	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
SJ-TANKINV-8-31-2026



Job No 13101/00018948.0000/01/I/26
Report date 01 Sep 2026
Installation San Juan, Puerto Rico, Central San Juan Terminal

Shore tank End of Month Inventory 8-31-2026 / Central San Juan
Product Fuel Oil NO 6

Survey date: 31-Aug-2026

Shore Tank Measurement Details

Shore tank R-4

Measurement data (Innage)		Open	Close
Average	FT/IN	00 05-3/8	
Temperature			
Average temp.	°F	88.8	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53314	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP8-1930	
Tank calibration table		valid from 08 Dec 2004	
Tank Calibration table nr.		R-4	
Inspector equipment used for verification?		No	
Inspector name		Jose Flores	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
SJ-TANKINV-8-31-2026



Job No 13101/00018948.0000/01/I/26
Report date 01 Sep 2026
Installation San Juan, Puerto Rico, Central San Juan Terminal

Shore tank End of Month Inventory 8-31-2026 / Central San Juan
Product Fuel Oil NO 6

Survey date: 31-Aug-2026

Shore Tank Measurement Details

Shore tank S-10

Measurement data (Innage)		Open	Close
Average	FT/IN	23 04-13/16	
Temperature			
Average temp.	°F	106.4	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53315	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9A-9772	
Tank calibration table		valid from 21 Jan 2015	
Tank Calibration table nr.		S-10	
Inspector equipment used for verification?		No	
Inspector name		Hector Lopez	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
SJ-TANKINV-8-31-2026



Job No 13101/00018948.0000/01/I/26
Report date 01 Sep 2026
Installation San Juan, Puerto Rico, Central San Juan Terminal

Shore tank End of Month Inventory 8-31-2026 / Central San Juan
Product Fuel Oil NO 6

Survey date: 31-Aug-2026

Shore Tank Measurement Details

Shore tank S-7

Measurement data (Innage)		Open	Close
Average	FT/IN	15 02-3/4	
Temperature			
Average temp.	°F	91.0	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53314	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP8-1930	
Tank calibration table		valid from 04 Sep 2002	
Tank Calibration table nr.		S7	
Inspector equipment used for verification?		No	
Inspector name		Jose Flores	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
SJ-TANKINV-8-31-2026



Job No 13101/00018948.0000/01/I/26
Report date 01 Sep 2026
Installation San Juan, Puerto Rico, Central San Juan Terminal

Shore tank End of Month Inventory 8-31-2026 / Central San Juan
Product Fuel Oil NO 6

Shore Tank Measurement Details

Shore tank S-8

Measurement data (Innage)		Open	Close
Average	FT/IN	15 02-3/4	
Temperature			
Average temp.	°F	90.4	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53315	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9A-9772	
Tank calibration table		valid from 01 Sep 2026	
Tank Calibration table nr.		S-8	
Inspector equipment used for verification?		No	
Inspector name		Hector Lopez	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 SJ-TANKINV-8-31-2026



Job No 13101/00018948.0000/01/I/26
 Report date 01 Sep 2026
 Installation San Juan, Puerto Rico, Central San Juan Terminal

Shore tank End of Month Inventory 8-31-2026 / Central San Juan
Product NO2 Fuel Oil

Survey date: 31-Aug-2026

Shore Tank Measurement Details

Shore tank D-5

Measurement data (Innage)		Open	Close
Average	FT/IN	36 01-7/16	
Temperature			
Average temp.	°F	91.4	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53315	
Temperature equipment type		Shore Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP9A-9772	
Tank calibration table		valid from 21 Feb 2007	
Tank Calibration table nr.		D-5	
Inspector equipment used for verification?		No	
Inspector name		Hector Lopez	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
SJ-TANKINV-8-31-2026



Job No 13101/00018948.0000/01/I/26
Report date 01 Sep 2026
Installation San Juan, Puerto Rico, Central San Juan Terminal

Shore tank End of Month Inventory 8-31-2026 / Central San Juan
Product NO2 Fuel Oil

Survey date: 31-Aug-2026

Shore Tank Measurement Details

Shore tank D-6

Measurement data (Innage)		Open	Close
Average	FT/IN	21 02-3/4	
Temperature			
Average temp.	°F	90.4	
Measurement equipment Data		Open	
Water measurement used		Paste	
Water paste used		KK	
Gauging equipment type		Saybolt Equipment	
Gauging equipment used		Manual Tape	
Gauging equipment number		53314	
Temperature equipment type		Saybolt Equipment	
Temperature equipment used		Portable Electronic Thermometer	
Temperature equipment number		TP8-1930	
Tank calibration table		valid from 17 Apr 2007	
Tank Calibration table nr.		D-6	
Inspector equipment used for verification?		No	
Inspector name		Jose Flores	

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 SJ-TANKINV-8-31-2026



Job No 13101/00018948.0000/01/I/26
 Report date 01 Sep 2026
 Installation San Juan, Puerto Rico, Central San Juan Terminal

Shore tank End of Month Inventory 8-31-2026 / Central San Juan
Product Fuel Oil NO 6

Survey date: 31-Aug-2026

Shore Tank Inventory Subtotals - 1

Shore tank Subtotals	Totals	R-1	R-2	R-4	S-7
Gross Standard Volume					
Cu m 60°F	16,163.097	7,254.637	7,301.748	219.965	379.097
Barrels 60°F	101,662.82	45,630.29	45,926.61	1,383.54	2,384.45
US Gallons 60°F	4,269,838.44	1,916,472.18	1,928,917.62	58,108.68	100,146.90
Metric Tons Vac	15,413.688	6,910.515	6,950.707	207.021	367.806
Metric Tons Air	15,396.621	6,902.853	6,942.995	206.788	367.407
Long Tons Air	15,153.456	6,793.833	6,833.341	203.522	361.605
Short Tons Air	16,971.872	7,609.093	7,653.342	227.945	404.998
Pounds Air	33,943,744	15,218,186	15,306,684	455,890	809,996
Density 15°C		0.9530	0.9523	0.9415	0.9706
API 60°F		16.90	17.00	18.70	14.20
RD 60/60°F		0.9535	0.9529	0.9421	0.9712
Total Calculated Volume					
Barrels 60°F	101,662.82	45,630.29	45,926.61	1,383.54	2,384.45
US Gallons 60°F	4,269,838.44	1,916,472.18	1,928,917.62	58,108.68	100,146.90

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 SJ-TANKINV-8-31-2026



Job No 13101/00018948.0000/01/I/26
 Report date 01 Sep 2026
 Installation San Juan, Puerto Rico, Central San Juan Terminal

Shore tank End of Month Inventory 8-31-2026 / Central San Juan
Product Fuel Oil NO 6

Survey date: 31-Aug-2026

Shore Tank Inventory Subtotals - 2

Shore tank Subtotals	S-8	S-10
----------------------	-----	------

Gross Standard Volume

Cu m 60°F	381.816	625.834
Barrels 60°F	2,401.55	3,936.38
US Gallons 60°F	100,865.10	165,327.96
Metric Tons Vac	370.444	607.195
Metric Tons Air	370.042	606.536
Long Tons Air	364.198	596.957
Short Tons Air	407.902	668.592
Pounds Air	815,804	1,337,184
Density 15°C	0.9706	0.9706
API 60°F	14.20	14.20
RD 60/60°F	0.9712	0.9712

Total Calculated Volume

Barrels 60°F	2,401.55	3,936.38
US Gallons 60°F	100,865.10	165,327.96

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
 American International Plaza
 250 Muñoz Rivera Ave, Suite 1200
 00918 SAN JUAN
 Puerto Rico
 Mr. M. Rios
 SJ-TANKINV-8-31-2026



Job No 13101/00018948.0000/01/I/26
 Report date 01 Sep 2026
 Installation San Juan, Puerto Rico, Central San Juan Terminal

Shore tank End of Month Inventory 8-31-2026 / Central San Juan
Product NO2 Fuel Oil

Survey date: 31-Aug-2026

Shore Tank Inventory Subtotals

Shore tank Subtotals	Totals	D-5	D-6
Gross Standard Volume			
Cu m 60°F	9,163.550	5,793.588	3,369.962
Barrels 60°F	57,636.99	36,440.57	21,196.42
US Gallons 60°F	2,420,753.58	1,530,503.94	890,249.64
Metric Tons Vac	7,686.909	4,854.686	2,832.223
Metric Tons Air	7,677.076	4,848.468	2,828.608
Long Tons Air	7,555.828	4,771.893	2,783.935
Short Tons Air	8,462.527	5,344.520	3,118.007
Pounds Air	16,925,054	10,689,040	6,236,014
Density 15°C		0.8383	0.8408
API 60°F		37.20	36.70
RD 60/60°F		0.8388	0.8413
Total Calculated Volume			
Barrels 60°F	58,302.16	36,746.04	21,556.12
US Gallons 60°F	2,448,690.72	1,543,333.68	905,357.04

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
SJ-TANKINV-8-31-2026



Job No 13101/00018948.0000/01/I/26
Report date 01 Sep 2026
Installation San Juan, Puerto Rico, Central San Juan Terminal

Shore tank End of Month Inventory 8-31-2026 / Central San Juan
Product Fuel Oil NO 6

Survey date: 31 Aug 2026

Certificate of Quantity

The undersigned Independent Saybolt Surveyor herewith declares that the quantity of product measured amounts to:

	Gross	Net
Cubic meters 60°F	16,163.097	16,163.097
Barrels 60°F	101,662.82	101,662.82
US Gallons 60°F	4,269,838.44	4,269,838.44
Metric Tons vac	15,413.688	15,413.688
Metric Tons air	15,396.621	15,396.621
Long Tons	15,153.456	15,153.456
Short Tons	16,971.872	16,971.872
Pounds	33,943,744	33,943,744

These quantities have been determined by measurement of shore tanks.

B/L API 60°F	16.73
B/L Density 15°C	0.9540
B/L Density 20°C	0.9506
B/L RD 60/60°F	0.9546

Criteria used

US Barrels 60°F to Cu m 60°F	MPMS 11.5 - Annex D	0.158987304
US Barrels 60°F to US Gallons 60°F	MPMS 11.5 - Annex D	42
Metric Tons Air to Metric Tons Vac	MPMS 11.5.3 - 4.5	1.001108542
Barrels 60°F to Metric Tons Air	MPMS 11.5.1 - 4.15	0.1514515883
Barrels 60°F to Long Tons	MPMS 11.5.1 - 4.12	0.1490596419
Long Tons to Short Tons	MPMS 11.5 - Annex D	1.12

Remark

Net via S&W Volume %

Signed by: Saybolt representative

Name:

Rank: Saybolt Inspector

PUERTO RICO ELECTRIC (B/R) POWER AUTHORITY
American International Plaza
250 Muñoz Rivera Ave, Suite 1200
00918 SAN JUAN
Puerto Rico
Mr. M. Rios
SJ-TANKINV-8-31-2026



Job No 13101/00018948.0000/01/I/26
Report date 01 Sep 2026
Installation San Juan, Puerto Rico, Central San Juan Terminal

Shore tank End of Month Inventory 8-31-2026 / Central San Juan
Product NO2 Fuel Oil

Survey date: 31 Aug 2026

Certificate of Quantity

The undersigned Independent Saybolt Surveyor herewith declares that the quantity of product measured amounts to:

	Gross	Net
Cubic meters 60°F	9,163.550	9,163.550
Barrels 60°F	57,636.99	57,636.99
US Gallons 60°F	2,420,753.58	2,420,753.58
Metric Tons vac	7,686.909	7,686.909
Metric Tons air	7,677.076	7,677.076
Long Tons	7,555.828	7,555.828
Short Tons	8,462.527	8,462.527
Pounds	16,925,054	16,925,054

These quantities have been determined by measurement of shore tanks.

B/L API 60°F	37.02
B/L Density 15°C	0.8392
B/L Density 20°C	0.8357
B/L RD 60/60°F	0.8397

Criteria used

US Barrels 60°F to Cu m 60°F	MPMS 11.5 - Annex D	0.158987304
US Barrels 60°F to US Gallons 60°F	MPMS 11.5 - Annex D	42
Metric Tons Air to Metric Tons Vac	MPMS 11.5.3 - 4.5	1.00128094
Barrels 60°F to Metric Tons Air	MPMS 11.5.1 - 4.15	0.1331936852
Barrels 60°F to Long Tons	MPMS 11.5.1 - 4.12	0.1310900944
Long Tons to Short Tons	MPMS 11.5 - Annex D	1.12

Remark

Net via S&W Volume %

Signed by: Saybolt representative

Name:

Rank: Saybolt Inspector